

SYRACUSE CITY SCHOOL DISTRICT

FRANKLIN ELEMENTARY SCHOOL

SAMPLE DATE: 09/17/2016 ANALYSIS DATE: 10/03/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 004 - Boiler Room	Hose Bib at Meter Assembly	Secured - SCSD Staff Only	1	FN-M100	6.9	None
Rm. 005 - Gym Teacher's Bathroom	Sink	Secured - SCSD Staff Only	76	FN-S217	1.2	None
Rm. A100 - Hallway/Vestibule	Fountain	Public Access	88	FN-F207	< 1.0	None
Rm. A105 - Girl's Gym Bathroom	Sink	Public Access	77	FN-S218	< 1.0	None
Rm. A108 - Boy's Gym Bathroom	Sink	Public Access	75	FN-S216	< 1.0	None
Rm. 100 - Classroom	Sink	Public Access	62	FN-S203	2.8	None
Rm. 100 - Classroom	Fountain	Public Access	85	FN-F204	< 1.0	None
Rm. 102 - Classroom	Sink	Public Access	63	FN-S204	1.4	None
Rm. 102 - Classroom	Fountain	Public Access	86	FN-F205	3.8	None
Rm. 103 - Classroom	Sink	Public Access	64	FN-S205	1.4	None
Rm. 103 - Classroom	Fountain	Public Access	87	FN-F206	2.7	None
Rm. 104 - Classroom	Sink	Public Access	12	FN-S110	3.6	None
Rm. 104 - Classroom	Fountain	Public Access	51	FN-F107	2.6	None
Rm. 106 - Classroom	Sink	Public Access	11	FN-S109	1.6	None
Rm. 106 - Classroom	Fountain	Public Access	50	FN-F106	6.4	None
Rm. 112 - Classroom	Sink	Public Access	9	FN-S107	1.0	None
Rm. 112 - Classroom	Fountain	Public Access	49	FN-F105	2.6	None
Rm. 113 - Classroom	Sink	Public Access	8	FN-S106	1.4	None
Rm. 113 - Classroom	Fountain	Public Access	48	FN-F104	1.9	None
Rm. 114 - Classroom	Sink	Public Access	7	FN-S105	1.9	None
Rm. 114 - Classroom	Fountain	Public Access	47	FN-F103	1.8	None
Rm. 116 - Classroom	Sink	Public Access	6	FN-S104	1.3	None
Rm. 116 - Classroom	Fountain	Public Access	46	FN-F102	3.7	None
Rm. 117 - Classroom	Sink	Public Access	5	FN-S103	2.5	None
Rm. 117 - Classroom	Fountain	Public Access	45	FN-F101	2.4	None
Rm. 119 - Hallway/Vestibule	Sink	Public Access	2	FN-S100	< 1.0	None
Rm. 119 - Hallway/Vestibule	Sink	Public Access	3	FN-S101	< 1.0	None
Rm. 119 - Hallway/Vestibule	Sink	Public Access	4	FN-S102	< 1.0	None
Rm. 119 - Hallway/Vestibule	Fountain	Public Access	44	FN-F100	< 1.0	None

SYRACUSE CITY SCHOOL DISTRICT
FRANKLIN ELEMENTARY SCHOOL

SAMPLE DATE: 09/17/2016 ANALYSIS DATE: 10/03/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 123 - Classroom	Sink	Public Access	59	FN-S200	3.0	None
Rm. 123 - Classroom	Fountain	Public Access	81	FN-F200	< 1.0	None
Rm. 124 - Classroom	Sink	Public Access	60	FN-S201	3.1	None
Rm. 124 - Classroom	Fountain	Public Access	82	FN-F201	< 1.0	None
Rm. 125 - Classroom	Sink	Public Access	61	FN-S202	2.3	None
Rm. 125 - Classroom	Fountain	Public Access	84	FN-F203	< 1.0	None
Rm. 131 - Kitchen	Sink	Secured - SCSD Staff Only	14	FN-S112	19.0	SCSD to replace fixture
Rm. 131 - Kitchen	Sink	Secured - SCSD Staff Only	15	FN-S113	5.9	None
Rm. 131 - Kitchen	Sink	Secured - SCSD Staff Only	16	FN-S114	2.1	None
Rm. 131 - Kitchen	Sink	Secured - SCSD Staff Only	17	FN-S115	4.2	None
Rm. 131C - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	13	FN-S111	< 1.0	None
Rm. 138A - Teacher's Resource Bathroom	Sink	Secured - SCSD Staff Only	10	FN-S108	1.1	None
Rm. 146C - Cafeteria Passage	Fountain	Public Access	83	FN-F202	< 1.0	None
Rm. 146D - Boy's Bathroom	Sink	Public Access	66	FN-S207	4.2	None
Rm. 146E - Girl's Bathroom	Sink	Public Access	65	FN-S206	< 1.0	None
Rm. 201 - Nurse's Office	Sink	Public Access	67	FN-S208	1.1	None
Rm. 201C - Nurse's Office Bathroom	Sink	Public Access	68	FN-S209	5.9	None
Rm. 202 - Clinic Room	Sink	Public Access	70	FN-S211	8.1	None
Rm. 202 - Clinic Room	Sink	Public Access	71	FN-S212	4.6	None
Rm. 202 - Clinic/Examination Room	Sink	Public Access	72	FN-S213	4.0	None
Rm. 202 - Clinic/Examination Room	Sink	Public Access	73	FN-S214	14.0	None
Rm. 202 - Clinic Room	Sink	Public Access	74	FN-S215	1.7	None
Rm. 204 - Clinic Room	Sink	Public Access	69	FN-S210	3.0	None
Rm. 205 - Women's Bathroom	Sink	Public Access	36	FN-S134	< 1.0	None
Rm. 206 - Men's Bathroom	Sink	Public Access	35	FN-S133	1.4	None
Rm. 208 - Teacher's Lounge Kitchenette	Sink	Secured - SCSD Staff Only	32	FN-S130	1.3	None
Rm. 208A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	33	FN-S131	1.3	None
Rm. 208B - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	34	FN-S132	6.1	None
Rm. 209 - Classroom	Sink	Public Access	31	FN-S129	< 1.0	None

SYRACUSE CITY SCHOOL DISTRICT

FRANKLIN ELEMENTARY SCHOOL

SAMPLE DATE: 09/17/2016 ANALYSIS DATE: 10/03/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 210A - Classroom Bathroom	Sink	Public Access	30	FN-S128	5.5	None
Rm. 211 - Teacher's Resource	Sink	Public Access	29	FN-S127	3.3	None
Rm. 212B - Work Room	Sink	Secured - SCSD Staff Only	22	FN-S120	1.7	None
Rm. 212D - Hallway/Vestibule	Sink	Public Access	24	FN-S122	< 1.0	None
Rm. 212D - Hallway/Vestibule	Sink	Public Access	25	FN-S123	2.9	None
Rm. 212D - Hallway/Vestibule	Sink	Public Access	26	FN-S124	< 1.0	None
Rm. 212D - Hallway/Vestibule	Fountain	Public Access	52	FN-F108	< 1.0	None
Rm. 215 - Computer Room	Sink	Public Access	28	FN-S126	2.1	None
Rm. 215 - Computer Room	Fountain	Public Access	54	FN-F110	3.5	None
Rm. 216 - Computer Room	Sink	Public Access	27	FN-S125	2.1	None
Rm. 216 - Computer Room	Fountain	Public Access	53	FN-F109	1.3	None
Rm. 220A - Classroom Bathroom	Sink	Public Access	23	FN-S121	< 1.0	None
Rm. 224 - Principal's Bathroom	Sink	Secured - SCSD Staff Only	19	FN-S117	< 1.0	None
Rm. 226 - Main Office Bathroom	Sink	Secured - SCSD Staff Only	18	FN-S116	5.6	None
Rm. 228B - Office Kitchenette	Sink	Secured - SCSD Staff Only	20	FN-S118	< 1.0	None
Rm. 234 - Hallway/Corridor	Fountain	Public Access	55	FN-F111	< 1.0	None
Rm. 245 - Staff Bathroom	Sink	Secured - SCSD Staff Only	21	FN-S119	1.2	None
Rm. 307 - Hallway/Vestibule	Sink	Public Access	41	FN-S139	< 1.0	None
Rm. 307 - Hallway/Vestibule	Sink	Public Access	42	FN-S140	< 1.0	None
Rm. 307 - Hallway/Vestibule	Sink	Public Access	43	FN-S141	1.6	None
Rm. 307 - Hallway/Vestibule	Fountain	Public Access	58	FN-F114	< 1.0	None
Rm. 309 - Classroom	Sink	Public Access	40	FN-S138	2.1	None
Rm. 309 - Classroom	Fountain	Public Access	57	FN-F113	1.3	None
Rm. 310 - Classroom	Sink	Public Access	39	FN-S137	2.4	None
Rm. 310 - Classroom	Fountain	Public Access	56	FN-F112	1.2	None
Rm. 319 - Hallway/Vestibule	Sink	Public Access	78	FN-S219	2.7	None
Rm. 319 - Hallway/Vestibule	Sink	Public Access	79	FN-S220	< 1.0	None
Rm. 319 - Hallway/Vestibule	Sink	Public Access	80	FN-S221	5.2	None
Rm. 319 - Hallway/Vestibule	Fountain	Public Access	89	FN-F208	< 1.0	None

SYRACUSE CITY SCHOOL DISTRICT
FRANKLIN ELEMENTARY SCHOOL

SAMPLE DATE: 09/17/2016 ANALYSIS DATE: 10/03/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 330 - Staff Bathroom	Sink	Secured - SCSD Staff Only	38	FN-S136	1.7	None
Rm. 331 - Staff Bathroom	Sink	Secured - SCSD Staff Only	37	FN-S135	3.5	None

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-006
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1615915
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.