

# SYRACUSE CITY SCHOOL DISTRICT

## WEBSTER ELEMENTARY SCHOOL

SAMPLE DATE: 09/16/2016    ANALYSIS DATE: 09/27/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 002A - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	046	W-S136	12.0	None
Rm. 011A - Staff Bathroom	Sink	Secured - SCSD Staff Only	051	W-S141	4.2	None
Rm. 012A - Classroom (012) Bathroom	Sink	Public Access	047	W-S137	< 1.0	None
Rm. 021 - Hallway/Corridor	Fountain	Public Access	008	W-F107	< 1.0	None
Rm. 100D - Hallway/Corridor	Fountain	Public Access	002	W-F101	2.5	None
Rm. 100D - Hallway/Corridor	Fountain	Public Access	003	W-F102	2.0	None
Rm. 100Q - Hallway/Corridor	Fountain	Public Access	001	W-F100	1.5	None
Rm. 100T - Hallway/Corridor	Fountain	Public Access	005	W-F104	3.6	None
Rm. 110 - Hallway/Vestibule	Sink	Public Access	038	W-S128	1.8	None
Rm. 110 - Hallway/Vestibule	Sink	Public Access	039	W-S129	2.5	None
Rm. 110 - Hallway/Vestibule	Sink	Public Access	040	W-S130	2.9	None
Rm. 110 - Hallway/Vestibule	Fountain	Public Access	006	W-F105	3.2	None
Rm. 110 - Art Classroom	Sink	Public Access	032	W-S122	8.2	None
Rm. 110 - Art Classroom	Sink	Public Access	033	W-S123	6.3	None
Rm. 111 - Staff Bathroom	Sink	Secured - SCSD Staff Only	037	W-S127	4.0	None
Rm. 114 - Hallway/Vestibule	Sink	Public Access	048	W-S138	2.7	None
Rm. 114 - Hallway/Vestibule	Sink	Public Access	049	W-S139	3.5	None
Rm. 114 - Hallway/Vestibule	Sink	Public Access	050	W-S140	3.1	None
Rm. 114 - Hallway/Vestibule	Fountain	Public Access	009	W-F108	2.8	None
Rm. 114A - Nurse's Office Exam Room	Sink	Public Access	031	W-S121	2.5	None
Rm. 114B - Nurse's Office Bathroom	Sink	Public Access	030	W-S120	2.7	None
Rm. 118A - Library Office	Sink	Secured - SCSD Staff Only	029	W-S119	3.8	None
Rm. 137 - Classroom Bathroom	Sink	Public Access	015	W-S105	2.8	None
Rm. 139 - Classroom	Sink	Public Access	014	W-S104	6.3	None
Rm. 140 - Classroom	Sink	Public Access	013	W-S103	3.7	None
Rm. 144 - Classroom	Fountain	Public Access	004	W-F103	4.4	None
Rm. 144B - Classroom (144) Bathroom	Sink	Public Access	026	W-S116	2.1	None
Rm. 145 - Classroom	Sink	Public Access	025	W-S115	3.6	None
Rm. 149 - Girl's Bathroom	Sink	Public Access	016	W-S106	2.0	None

# SYRACUSE CITY SCHOOL DISTRICT

## WEBSTER ELEMENTARY SCHOOL

SAMPLE DATE: 09/16/2016    ANALYSIS DATE: 09/27/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 149 - Girl's Bathroom	Sink	Public Access	017	W-S107	1.8	None
Rm. 149 - Girl's Bathroom	Sink	Public Access	018	W-S108	3.1	None
Rm. 150 - Boy's Bathroom	Sink	Public Access	019	W-S109	1.2	None
Rm. 150 - Boy's Bathroom	Sink	Public Access	020	W-S110	2.5	None
Rm. 150 - Boy's Bathroom	Sink	Public Access	021	W-S111	2.2	None
Rm. 151 - Staff Bathroom	Sink	Secured - SCSD Staff Only	023	W-S113	4.0	None
Rm. 152A - Kitchen	Sink	Secured - SCSD Staff Only	010	W-S100	5.6	None
Rm. 152A - Kitchen	Sink	Secured - SCSD Staff Only	011	W-S101	1.1	None
Rm. 152A - Kitchen	Sink	Secured - SCSD Staff Only	012	W-S102	1.6	None
Rm. 155 - Classroom (145) Bathroom	Sink	Public Access	024	W-S114	1.6	None
Rm. 157 - Staff Bathroom (Men's)	Sink	Secured - SCSD Staff Only	027	W-S117	3.2	None
Rm. 158 - Staff Bathroom (Women's)	Sink	Secured - SCSD Staff Only	028	W-S118	3.7	None
Rm. 159 - Staff Bathroom	Sink	Secured - SCSD Staff Only	022	W-S112	3.4	None
Rm. 178 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	034	W-S124	2.9	None
Rm. 180A - Staff Bathroom (Men's)	Sink	Secured - SCSD Staff Only	035	W-S125	5.2	None
Rm. 180C - Staff Bathroom (Women's)	Sink	Secured - SCSD Staff Only	036	W-S126	1.9	None
Rm. 210D - Teacher's Resource Bathroom (Men's)	Sink	Secured - SCSD Staff Only	041	W-S131	3.6	None
Rm. 210E - Teacher's Resource Bathroom (Women's)	Sink	Secured - SCSD Staff Only	042	W-S132	2.6	None
Rm. 211 - Hallway/Vestibule	Sink	Public Access	043	W-S133	2.9	None
Rm. 211 - Hallway/Vestibule	Sink	Public Access	044	W-S134	1.3	None
Rm. 211 - Hallway/Vestibule	Sink	Public Access	045	W-S135	1.7	None
Rm. 211 - Hallway/Vestibule	Fountain	Public Access	007	W-F106	1.6	None

**Notes:**

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-001
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1615554
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.

