

SYRACUSE CITY SCHOOL DISTRICT
SALEM - HYDE ELEMENTARY SCHOOL

SAMPLE DATE: 09/17/2016 ANALYSIS DATE: 11/08/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 003 - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	SH-005	SH-S100	< 1.0	None
Rm. 005 - Boy's Lockerroom	Sink	Public Access	SH-006	SH-S101	4.5	None
Rm. 006 - Girl's Lockerroom	Sink	Public Access	SH-040	SH-S200	< 1.0	None
Rm. 012 - Cafeteria	Fountain	Public Access	SH-001	SH-F100	< 1.0	None
Rm. 013 - Girl's Bathroom	Sink	Public Access	SH-008	SH-S103	< 1.0	None
Rm. 014 - Boy's Bathroom	Sink	Public Access	SH-007	SH-S102	1.3	None
Rm. 022 - Kitchen	Sink	Secured - SCSD Staff Only	SH-009	SH-S104	1.8	None
Rm. 022 - Kitchen	Sink	Secured - SCSD Staff Only	SH-010	SH-S105	2.0	None
Rm. 022 - Kitchen	Sink	Secured - SCSD Staff Only	SH-011	SH-S106	< 1.0	None
Rm. 022 - Kitchen	Sink	Secured - SCSD Staff Only	SH-012	SH-S107	< 1.0	None
Rm. 023 - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	SH-013	SH-S108	< 1.0	None
Rm. 025 - Hallway/Corridor	Fountain	Public Access	SH-029	SH-F200	< 1.0	None
Rm. 101 - Classroom	Sink	Public Access	SH-041	SH-S201	31.0	SCSD to replace fixture
Rm. 101 - Classroom	Fountain	Public Access	SH-030	SH-F201	9.3	None
Rm. 101A - Classroom Bathroom	Sink	Public Access	SH-043	SH-S203	3.7	None
Rm. 102 - Classroom	Sink	Public Access	SH-045	SH-S205	4.0	None
Rm. 102 - Classroom	Fountain	Public Access	SH-032	SH-F203	1.6	None
Rm. 102A - Classroom Bathroom	Sink	Public Access	SH-046	SH-S206	1.4	None
Rm. 103 - Classroom	Sink	Public Access	SH-048	SH-S208	11.0	None
Rm. 104C - Office Bathroom	Sink	Secured - SCSD Staff Only	SH-047	SH-S207	< 1.0	None
Rm. 105A - Nurse's Office Exam Room	Sink	Public Access	SH-051	SH-S211	1.8	None
Rm. 105B - Nurse's Office Bathroom	Sink	Public Access	SH-052	SH-S212	< 1.0	None
Rm. 108 - Classroom	Sink	Public Access	SH-053	SH-S213	1.1	None
Rm. 109 - Classroom	Sink	Public Access	SH-054	SH-S214	< 1.0	None
Rm. 109 - Classroom	Fountain	Public Access	SH-033	SH-F204	< 1.0	None
Rm. 109A - Classroom Bathroom	Sink	Public Access	SH-055	SH-S215	3.0	None
Rm. 110 - Classroom	Fountain	Public Access	SH-034	SH-F205	2.1	None
Rm. 110 - Classroom	Sink	Public Access	SH-057	SH-S217	< 1.0	None
Rm. 110A - Classroom Bathroom	Sink	Public Access	SH-056	SH-S216	< 1.0	None

SYRACUSE CITY SCHOOL DISTRICT
SALEM - HYDE ELEMENTARY SCHOOL

SAMPLE DATE: 09/17/2016 ANALYSIS DATE: 11/08/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 111 - Classroom	Fountain	Public Access	SH-035	SH-F206	2.9	None
Rm. 111 - Classroom	Sink	Public Access	SH-058	SH-S218	< 1.0	None
Rm. 111A - Classroom Bathroom	Sink	Public Access	SH-059	SH-S219	< 1.0	None
Rm. 112 - Classroom	Sink	Public Access	SH-060	SH-S220	1.1	None
Rm. 112 - Classroom	Fountain	Public Access	SH-036	SH-F207	< 1.0	None
Rm. 112A - Classroom Bathroom	Sink	Public Access	SH-061	SH-S221	< 1.0	None
Rm. 113 - Classroom	Fountain	Public Access	SH-037	SH-F208	< 1.0	None
Rm. 113 - Classroom	Sink	Public Access	SH-062	SH-S222	< 1.0	None
Rm. 113A - Classroom Bathroom	Sink	Public Access	SH-063	SH-S223	3.4	None
Rm. 115B - Library Work Room	Sink	Secured -SCSD Staff Only	SH-067	SH-S227	7.1	None
Rm. 119 - Classroom	Fountain	Public Access	SH-039	SH-F210	4.7	None
Rm. 119 - Classroom	Sink	Public Access	SH-068	SH-S228	3.2	None
Rm. 119A - Classroom Bathroom	Sink	Public Access	SH-069	SH-S229	31.0	SCSD to replace fixture
Rm. 120 - Classroom	Sink	Public Access	SH-042	SH-S202	1.9	None
Rm. 120 - Classroom	Sink	Public Access	SH-044	SH-S204	6.4	None
Rm. 120 - Classroom	Fountain	Public Access	SH-031	SH-F202	35.0	SCSD to replace fixture
Rm. 131 - Hallway/Vestibule	Fountain	Public Access	SH-038	SH-F209	< 1.0	None
Rm. 131 - Hallway/Vestibule	Sink	Public Access	SH-064	SH-S224	< 1.0	None
Rm. 131 - Hallway/Vestibule	Sink	Public Access	SH-065	SH-S225	2.0	None
Rm. 131 - Hallway/Vestibule	Sink	Public Access	SH-066	SH-S226	1.7	None
Rm. 137 - Staff Bathroom	Sink	Secured - SCSD Staff Only	SH-049	SH-S209	< 1.0	None
Rm. 138 - Staff Bathroom	Sink	Secured - SCSD Staff Only	SH-050	SH-S210	1.2	None
Rm. 205 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	SH-018	SH-S113	3.6	None
Rm. 205A - Staff Bathroom	Sink	Secured - SCSD Staff Only	SH-019	SH-S114	1.4	None
Rm. 205B - Staff Bathroom	Sink	Secured - SCSD Staff Only	SH-020	SH-S115	1.7	None
Rm. 218 - Classroom	Fountain	Public Access	SH-002	SH-F101	13.0	None
Rm. 218 - Classroom	Sink	Public Access	SH-014	SH-S109	6.9	None
Rm. 224A - Hallway/Vestibule	Sink	Public Access	SH-015	SH-S110	< 1.0	None
Rm. 224A - Hallway/Vestibule	Sink	Public Access	SH-016	SH-S111	1.6	None

SYRACUSE CITY SCHOOL DISTRICT
SALEM - HYDE ELEMENTARY SCHOOL

SAMPLE DATE: 09/17/2016 ANALYSIS DATE: 11/08/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 224A - Hallway/Vestibule	Sink	Public Access	SH-017	SH-S112	< 1.0	None
Rm. 224A - Hallway/Vestibule	Fountain	Public Access	SH-003	SH-F102	< 1.0	None
Rm. 225 - Hallway/Corridor	Fountain	Public Access	SH-004	SH-F103	< 1.0	None
Rm. 237 - Boy's Bathroom	Sink	Public Access	SH-025	SH-S120	< 1.0	None
Rm. 237 - Boy's Bathroom	Sink	Public Access	SH-026	SH-S121	3.5	None
Rm. 237 - Boy's Bathroom	Sink	Public Access	SH-027	SH-S122	1.4	None
Rm. 238 - Girl's Bathroom	Sink	Public Access	SH-021	SH-S116	< 1.0	None
Rm. 238 - Girl's Bathroom	Sink	Public Access	SH-022	SH-S117	< 1.0	None
Rm. 238 - Girl's Bathroom	Sink	Public Access	SH-023	SH-S118	< 1.0	None
Rm. 238 - Girl's Bathroom	Sink	Public Access	SH-024	SH-S119	< 1.0	None
Rm. 239 - Staff Bathroom	Sink	Secured - SCSD Staff Only	SH-028	SH-S123	1.4	None

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-005
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1616044
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.