

SYRACUSE CITY SCHOOL DISTRICT
McCARTHY AT BEARD SPECIAL EDUCATION SCHOOL

SAMPLE DATE: 09/23/2016 ANALYSIS DATE: 11/18/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. B005 - Mechanical/Meter Room	Hose Bib at Meter Assembly	Secured - SCSD Staff Only	BD-001	BD-M100	3.1	None
Rm. 101A - Teacher's Lounge	Sink	Secured - SCSD Staff Only	BD-006	BD-S100	1.7	None
Rm. 101A - Kitchen	Sink	Secured - SCSD Staff Only	BD-014	BD-S108	3.0	None
Rm. 101A - Kitchen	Sink	Secured - SCSD Staff Only	BD-015	BD-S109	< 1.0	None
Rm. 101A - Kitchen	Sink	Secured - SCSD Staff Only	BD-016	BD-S110	< 1.0	None
Rm. 108 - Boy's Bathroom	Sink	Public Access	BD-017	BD-S111	2.7	None
Rm. 108 - Boy's Bathroom	Sink	Public Access	BD-018	BD-S112	1.4	None
Rm. 110 - Hallway/Corridor	Fountain	Public Access	BD-004	BD-F103	5.7	None
Rm. 111B - Clinic Room	Sink	Public Access	BD-012	BD-S106	1.8	None
Rm. 111C - Clinic Bathroom	Sink	Public Access	BD-013	BD-S107	< 1.0	None
Rm. 112 - Boy's Bathroom	Sink	Public Access	BD-008	BD-S102	1.1	None
Rm. 113 - Girl's Bathroom	Sink	Public Access	BD-009	BD-S103	1.0	None
Rm. 114D - Office Bathroom	Sink	Secured - SCSD Staff Only	BD-010	BD-S104	2.6	None
Rm. 129 - Hallway/Corridor	Fountain	Public Access	BD-002	BD-F100	1.9	None
Rm. 137 - Men's Bathroom	Sink	Secured - SCSD Staff Only	BD-007	BD-S101C	< 1.0	None
Rm. 158 - Storage Room Bathroom	Bathroom Sink	Secured - SCSD Staff Only	BD-011	BD-S105	14.0	None
Rm. 163 - Hallway/Corridor	Fountain	Public Access	BD-003	BD-F102	< 1.0	None
Rm. 210 - Boy's Bathroom	Sink	Public Access	BD-022	BD-S116	< 1.0	None
Rm. 210 - Boy's Bathroom	Sink	Public Access	BD-023	BD-S117	1.2	None
Rm. 211 - Girl's Bathroom	Sink	Public Access	BD-021	BD-S115	27.0	SCSD to replace fixture
Rm. 217 - Boy's Bathroom	Sink	Public Access	BD-019	BD-S113	5.0	None
Rm. 217 - Boy's Bathroom	Sink	Public Access	BD-020	BD-S114	1.2	None
Rm. 223 - Hallway/Corridor	Fountain	Public Access	BD-005	BD-F104	40.0	SCSD to replace fixture
Rm. 239 - Staff Bathroom	Bathroom Sink	Secured - SCSD Staff Only	BD-024	BD-S118	1.7	None

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-012
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1616195
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.

