

SYRACUSE CITY SCHOOL DISTRICT
CORCORAN HIGH SCHOOL FIELD HOUSE

SAMPLE DATE: 10/27/2016 ANALYSIS DATE: 11/28/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Outside Wall Mount	Fountain	Public Access	CNFH-016	CNFH-F100	< 1.0	None
Outside Wall Mount	Fountain	Public Access	CNFH-017	CNFH-F101	< 1.0	None
Rm. A1 - Concession Stand	Sink	Secured - SCSD Staff Only	CNFH-001	CNFH-S100	30.0	SCSD to replace fixture
Rm. A1 - Concession Stand	Sink	Secured - SCSD Staff Only	CNFH-002	CNFH-S101	5.9	None
Rm. A1 - Concession Stand	Sink	Secured - SCSD Staff Only	CNFH-003	CNFH-S102	2.8	None
Rm. A1 - Concession Stand	Hose Bib	Secured - SCSD Staff Only	CNFH-004	CNFH-S103	1.6	None
Rm. A3 - Men's Bathroom	Sink	Public Access	CNFH-005	CNFH-S104	1.5	None
Rm. A3 - Men's Bathroom	Sink	Public Access	CNFH-006	CNFH-S105	1.6	None
Rm. A4 - Women's Bathroom	Sink	Public Access	--	CNFH-S106	--	Fixture not operating
Rm. A4 - Women's Bathroom	Sink	Public Access	CNFH-007	CNFH-S107	1.0	None
Rm. A5 - Home Team Locker Room	Sink	Public Access	CNFH-008	CNFH-S108	3.0	None
Rm. A5 - Home Team Locker Room	Sink	Public Access	CNFH-009	CNFH-S109	< 1.0	None
Rm. A5 - Home Team Locker Room	Ice Machine	Public Access	CNFH-010	CNFH-S110	< 1.0	None
Rm. A5 - Home Team Locker Room	Hose Bib	Public Access	CNFH-011	CNFH-S111	< 1.0	None
Rm. A8 - Visiting Team Locker Room	High Hose Bib	Public Access	CNFH-012	CNFH-S112	< 1.0	None
Rm. A8 - Visiting Team Locker Room	Sink	Public Access	CNFH-013	CNFH-S113	1.2	None
Rm. A8 - Visiting Team Locker Room	Sink	Public Access	--	CNFH-S114	--	Fixture not operating
Rm. A8 - Visiting Team Locker Room	Low Hose Bib	Public Access	CNFH-014	CNFH-S115	< 1.0	None
Rm. A12 - Official's Bathroom/Lounge	Sink	Secured - SCSD Staff Only	CNFH-015	CNFH-S116	1.3	None

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-045
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1619197
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.