

# SYRACUSE CITY SCHOOL DISTRICT

## DR. KING ELEMENTARY SCHOOL

SAMPLE DATE: 09/25/2016 ANALYSIS DATE: 12/05/2016 and 12/06/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. A002 - Mechanical/Meter Room	Hose Bib at Meter Assembly	Secured - SCSD Staff Only	DKES-175	DK-M100	30.0	SCSD to post warning sign
Rm. A102 - Hallway/Corridor	Fountain	Public Access	DKES-151	DK-F301	< 1.0	None
Rm. A102 - Hallway/Corridor	Fountain	Public Access	DKES-152	DK-F302	< 1.0	None
Rm. A113 - Kitchenette	Sink	Secured - SCSD Staff Only	DKES-106	DK-S325	< 1.0	None
Rm. A116 - Classroom	Sink	Public Access	DKES-094	DK-S313	< 1.0	None
Rm. A116 - Classroom	Fountain	Public Access	DKES-157	DK-F307	< 1.0	None
Rm. A116A - Classroom Bathroom	Sink	Public Access	DKES-095	DK-S314	< 1.0	None
Rm. A117 - Classroom	Sink	Public Access	DKES-092	DK-S311	< 1.0	None
Rm. A117 - Classroom	Fountain	Public Access	DKES-156	DK-F306	< 1.0	None
Rm. A117A - Classroom Bathroom	Sink	Public Access	DKES-093	DK-S312	< 1.0	None
Rm. A118 - Classroom	Sink	Public Access	DKES-090	DK-S309	45.0	SCSD removed fixture from service and is to replace
Rm. A118 - Classroom	Fountain	Public Access	DKES-155	DK-F305	< 1.0	None
Rm. A118A - Classroom Bathroom	Sink	Public Access	DKES-091	DK-S310	< 1.0	None
Rm. A119 - Classroom	Sink	Public Access	DKES-088	DK-S307	< 1.0	None
Rm. A119 - Classroom	Fountain	Public Access	DKES-154	DK-F304	< 1.0	None
Rm. A119A - Classroom Bathroom	Sink	Public Access	DKES-089	DK-S308	< 1.0	None
Rm. A120 - Classroom	Sink	Public Access	DKES-086	DK-S305	< 1.0	None
Rm. A120 - Classroom	Fountain	Public Access	DKES-153	DK-F303	< 1.0	None
Rm. A120A - Classroom Bathroom	Sink	Public Access	DKES-087	DK-S306	< 1.0	None
Rm. A122 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	DKES-083	DK-S302	< 1.0	None
Rm. A123 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	DKES-085	DK-S304	< 1.0	None
Rm. A124 - Girl's Bathroom	Sink	Public Access	DKES-084	DK-S303	< 1.0	None
Rm. A125 - Boy's Bathroom	Sink	Public Access	DKES-082	DK-S301	< 1.0	None
Rm. A129 - Classroom	Sink	Public Access	DKES-104	DK-S323	< 1.0	None
Rm. A129 - Classroom	Fountain	Public Access	--	DK-F311	--	Fixture not operating
Rm. A129A - Classroom Bathroom	Sink	Public Access	DKES-105	DK-S324	< 1.0	None
Rm. A130 - Classroom	Sink	Public Access	DKES-102	DK-S321	< 1.0	None
Rm. A130 - Classroom	Fountain	Public Access	DKES-160	DK-F310	< 1.0	None
Rm. A130A - Classroom Bathroom	Sink	Public Access	DKES-103	DK-S322	< 1.0	None

# SYRACUSE CITY SCHOOL DISTRICT

## DR. KING ELEMENTARY SCHOOL

SAMPLE DATE: 09/25/2016 ANALYSIS DATE: 12/05/2016 and 12/06/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. A131 - Classroom	Sink	Public Access	DKES-100	DK-S319	< 1.0	None
Rm. A131 - Classroom	Fountain	Public Access	DKES-159	DK-F309	< 1.0	None
Rm. A131A - Classroom Bathroom	Sink	Public Access	DKES-101	DK-S320	< 1.0	None
Rm. A132 - Classroom	Sink	Public Access	DKES-098	DK-S317	< 1.0	None
Rm. A132A - Classroom Bathroom	Sink	Public Access	DKES-099	DK-S318	< 1.0	None
Rm. A133 - Classroom	Sink	Public Access	DKES-096	DK-S315	< 1.0	None
Rm. A133 - Classroom	Fountain	Public Access	DKES-158	DK-F308	< 1.0	None
Rm. A133A - Classroom Bathroom	Sink	Public Access	DKES-097	DK-S316	< 1.0	None
Rm. B102 - Hallway/Corridor	Fountain	Public Access	DKES-161	DK-F312	< 1.0	None
Rm. B102 - Hallway/Corridor	Fountain	Public Access	DKES-162	DK-F313	< 1.0	None
Rm. B112 - Classroom	Sink	Public Access	DKES-107	DK-S326	2.0	None
Rm. B112 - Classroom	Sink	Public Access	DKES-108	DK-S327	1.1	None
Rm. B112 - Classroom	Sink	Public Access	DKES-109	DK-S328	1.5	None
Rm. B112 - Classroom	Sink	Public Access	DKES-110	DK-S329	24.0	SCSD removed fixture from service and is to replace
Rm. B115 - Resource & Staff Development	Sink	Secured - SCSD Staff Only	DKES-027	DK-S125	< 1.0	None
Rm. B116 - Science Office	Sink	Public Access	DKES-111	DK-S330	< 1.0	None
Rm. B118A - Boy's/Girl's Bathroom	Sink	Public Access	DKES-029	DK-S127	< 1.0	None
Rm. B118B - Staff's Bathroom	Sink	Secured - SCSD Staff Only	DKES-028	DK-S126	< 1.0	None
Rm. B122 - Media Work Room	Sink	Public Access	DKES-030	DK-S128	2.7	None
Rm. B125 - Staff's Bathroom	Sink	Secured - SCSD Staff Only	DKES-026	DK-S124	< 1.0	None
Rm. B126 - Boy's Bathroom	Sink	Public Access	DKES-025	DK-S123	< 1.0	None
Rm. B127 - Girl's Bathroom	Sink	Public Access	DKES-024	DK-S122	< 1.0	None
Rm. B128 - Staff Lounge	Sink	Secured - SCSD Staff Only	DKES-023	DK-S121	< 1.0	None
Rm. B128A - Staff Bathroom	Sink	Secured - SCSD Staff Only	DKES-022	DK-S120	< 1.0	None
Rm. B129 - Classroom	Sink	Public Access	DKES-067	DK-S224	< 1.0	None
Rm. B129 - Classroom	Fountain	Public Access	DKES-147	DK-F203	2.2	None
Rm. B130 - Classroom	Sink	Public Access	DKES-066	DK-S223	< 1.0	None
Rm. B133 - Music Room	Sink	Public Access	DKES-065	DK-S222	< 1.0	None
Rm. B134 - Classroom	Sink	Public Access	DKES-021	DK-S119	< 1.0	None

# SYRACUSE CITY SCHOOL DISTRICT

## DR. KING ELEMENTARY SCHOOL

SAMPLE DATE: 09/25/2016 ANALYSIS DATE: 12/05/2016 and 12/06/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. B134 - Classroom	Fountain	Public Access	-	DK-F107	-	Fixture not operating
Rm. B134A - Classroom Bathroom	Sink	Public Access	DKES-020	DK-S118	< 1.0	None
Rm. B136 - Classroom	Sink	Public Access	DKES-018	DK-S117A	< 1.0	None
Rm. B136 - Classroom	Sink	Public Access	DKES-019	DK-S117B	1.4	None
Rm. B136A - Classroom Bathroom	Sink	Public Access	DKES-017	DK-S116	< 1.0	None
Rm. C106 - Hallway/Corridor	Fountain	Public Access	DKES-135	DK-F100	< 1.0	None
Rm. C106 - Hallway/Corridor	Fountain	Public Access	DKES-136	DK-F101	< 1.0	None
Rm. C108 - Hallway/Corridor	Sink	Public Access	DKES-057	DK-S214	< 1.0	None
Rm. C108 - Hallway/Corridor	Sink	Public Access	DKES-059	DK-S216	< 1.0	None
Rm. C111 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DKES-015	DK-S114	< 1.0	None
Rm. C112 - Café	Fountain	Public Access	DKES-145	DK-F201	< 1.0	None
Rm. C112 - Café	Fountain	Public Access	DKES-146	DK-F202	< 1.0	None
Rm. C113 - Girl's Bathroom	Sink	Public Access	DKES-046	DK-S203	< 1.0	None
Rm. C113 - Girl's Bathroom	Sink	Public Access	DKES-047	DK-S204	< 1.0	None
Rm. C115 - Boy's Bathroom	Sink	Public Access	DKES-044	DK-S201	< 1.0	None
Rm. C115 - Boy's Bathroom	Sink	Public Access	DKES-045	DK-S202	< 1.0	None
Rm. C117 - Kitchen	Sink	Secured - SCSD Staff Only	DKES-048	DK-S205	< 1.0	None
Rm. C117 - Kitchen	Sink	Secured - SCSD Staff Only	DKES-049	DK-S206	< 1.0	None
Rm. C117 - Kitchen	Sink	Secured - SCSD Staff Only	DKES-050	DK-S207	< 1.0	None
Rm. C117 - Kitchen	Sink	Secured - SCSD Staff Only	DKES-051	DK-S208	< 1.0	None
Rm.s C123 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	DKES-053	DK-S210	< 1.0	None
Rm. C126 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	DKES-054	DK-S211	< 1.0	None
Rm. C129 - Custodian Shop	Sink	Secured - SCSD Staff Only	DKES-052	DK-S209	< 1.0	None
Rm. C132 - Nurse's Bathroom	Sink	Public Access	DKES-064	DK-S221	10.0	None
Rm. C133 - Nurse's Room	Sink	Public Access	DKES-062	DK-S219	< 1.0	None
Rm. C136 - Clean Room	Sink	Secured - SCSD Staff Only	DKES-060	DK-S217	1.4	None
Rm. C137 - Staff's Bathroom	Sink	Secured - SCSD Staff Only	DKES-058	DK-S215	< 1.0	None
Rm. C138 - Sick Room	Sink	Public Access	DKES-063	DK-S220	< 1.0	None
Rm. C140 - Exam Room	Sink	Public Access	DKES-061	DK-S218	<1.0	None

# SYRACUSE CITY SCHOOL DISTRICT

## DR. KING ELEMENTARY SCHOOL

SAMPLE DATE: 09/25/2016 ANALYSIS DATE: 12/05/2016 and 12/06/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm.s C141 - Exam Room	Sink	Public Access	DKES-056	DK-S213	< 1.0	None
Rm. C142 - Dental Room	Sink	Public Access	DKES-055	DK-S212	< 1.0	None
Rm. C146A - Staff Bathroom	Sink	Secured - SCSD Staff Only	DKES-016	DK-S115	1.2	None
Rm. C147 - Mail Room	Sink	Secured - SCSD Staff Only	DKES-001	DK-S100	< 1.0	None
Rm. C148 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DKES-002	DK-S101	3.2	None
Rm. D101 - Hallway/Corridor	Fountain	Public Access	DKES-137	DK-F102	< 1.0	None
Rm. D101 - Hallway/Corridor	Fountain	Public Access	DKES-138	DK-F103	< 1.0	None
Rm. D108A - Hallway/Corridor	Fountain	Public Access	DKES-139	DK-F104	< 1.0	None
Rm. D108A - Hallway/Corridor	Fountain	Public Access	DKES-140	DK-F105	< 1.0	None
Rm. D113 - Kitchen	Sink	Secured - SCSD Staff Only	DKES-003	DK-S102	< 1.0	None
Rm. D114 - Staff's Bathroom	Sink	Secured - SCSD Staff Only	DKES-004	DK-S103	< 1.0	None
Rm. D115 - Staff's Bathroom	Sink	Secured - SCSD Staff Only	DKES-006	DK-S105	< 1.0	None
Rm. D121A - PE Bathroom	Sink	Secured - SCSD Staff Only	DKES-005	DK-S104	< 1.0	None
Rm. D127 - Classroom	Sink	Public Access	DKES-014	DK-S113	< 1.0	None
Rm. D127A - Classroom Bathroom	Sink	Public Access	DKES-013	DK-S112	< 1.0	None
Rm. D128 - Classroom	Sink	Public Access	DKES-012	DK-S111	< 1.0	None
Rm. D128A - Classroom Bathroom	Sink	Public Access	DKES-011	DK-S110	< 1.0	None
Rm. D130 - Boy's Locker Room	Sink	Public Access	DKES-007	DK-S106	< 1.0	None
Rm. D130 - Boy's Locker Room	Sink	Public Access	DKES-008	DK-S107	< 1.0	None
Rm. D131 - Girl's Locker Room	Sink	Public Access	DKES-009	DK-S108	< 1.0	None
Rm. D131 - Girl's Locker Room	Sink	Public Access	DKES-010	DK-S109	< 1.0	None
Rm. A202 - Hallway/Corridor	Fountain	Public Access	DKES-163	DK-F314	< 1.0	None
Rm. A202 - Hallway/Corridor	Fountain	Public Access	DKES-164	DK-F315	< 1.0	None
Rm. A213 - Kitchenette	Sink	Public Access	DKES-134	DK-S353	< 1.0	None
Rm. A217 - Classroom	Sink	Public Access	DKES-123	DK-S342	< 1.0	None
Rm. A217 - Classroom	Fountain	Public Access	DKES-169	DK-F320	< 1.0	None
Rm. A217A - Classroom Bathroom	Sink	Public Access	DKES-124	DK-S343	< 1.0	None
Rm. A218 - Classroom	Sink	Public Access	DKES-121	DK-S340	< 1.0	None
Rm. A218 - Classroom	Fountain	Public Access	DKES-168	DK-F319	< 1.0	None

# SYRACUSE CITY SCHOOL DISTRICT

## DR. KING ELEMENTARY SCHOOL

SAMPLE DATE: 09/25/2016 ANALYSIS DATE: 12/05/2016 and 12/06/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. A218A - Classroom Bathroom	Sink	Public Access	DKES-122	DK-S341	< 1.0	None
Rm. A219 - Classroom	Sink	Public Access	DKES-119	DK-S338	< 1.0	None
Rm. A219 - Classroom	Fountain	Public Access	DKES-167	DK-F318	< 1.0	None
Rm. A219A - Classroom Bathroom	Sink	Public Access	DKES-120	DK-S339	< 1.0	None
Rm. A220 - Classroom	Sink	Public Access	DKES-118	DK-S337	< 1.0	None
Rm. A220 - Classroom	Fountain	Public Access	DKES-166	DK-F317	< 1.0	None
Rm. A221 - Classroom	Sink	Public Access	DKES-116	DK-S335	< 1.0	None
Rm. A221 - Classroom	Fountain	Public Access	DKES-165	DK-F316	< 1.0	None
Rm. A221A - Classroom Bathroom	Sink	Public Access	DKES-117	DK-S336	1.3	None
Rm. A222 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DKES-115	DK-S334	< 1.0	None
Rm. A223 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DKES-114	DK-S333	< 1.0	None
Rm. A224 - Girl's Bathroom	Sink	Public Access	DKES-113	DK-S332	< 1.0	None
Rm. A225 - Boy's Bathroom	Sink	Public Access	DKES-112	DK-S331	< 1.0	None
Rm. A233 - Classroom	Sink	Public Access	DKES-132	DK-S351	< 1.0	None
Rm. A233 - Classroom	Fountain	Public Access	DKES-174	DK-F325	< 1.0	None
Rm. A233A - Classroom Bathroom	Sink	Public Access	DKES-133	DK-S352	< 1.0	None
Rm. A234 - Classroom	Sink	Public Access	DKES-131	DK-S350	< 1.0	None
Rm. A234 - Classroom	Fountain	Public Access	DKES-173	DK-F324	< 1.0	None
Rm. A235 - Classroom	Sink	Public Access	DKES-129	DK-S348	< 1.0	None
Rm. A235 - Classroom	Fountain	Public Access	DKES-172	DK-F323	< 1.0	None
Rm. A235A - Classroom Bathroom	Sink	Public Access	DKES-130	DK-S349	< 1.0	None
Rm. A236 - Classroom	Sink	Public Access	DKES-127	DK-S346	< 1.0	None
Rm. A236 - Classroom	Fountain	Public Access	DKES-171	DK-F222	< 1.0	None
Rm. A236A - Classroom Bathroom	Sink	Public Access	DKES-128	DK-S347	< 1.0	None
Rm. A237 - Classroom	Sink	Public Access	DKES-125	DK-S344	< 1.0	None
Rm. A237 - Classroom	Fountain	Public Access	DKES-170	DK-F321	< 1.0	None
Rm. A237A - Classroom Bathroom	Sink	Public Access	DKES-126	DK-S345	< 1.0	None
Rm. B202 - Hallway/Corridor	Fountain	Public Access	DKES-149	DK-F205	< 1.0	None
Rm. B202 - Hallway/Corridor	Fountain	Public Access	DKES-150	DK-F206	< 1.0	None

# SYRACUSE CITY SCHOOL DISTRICT

## DR. KING ELEMENTARY SCHOOL

SAMPLE DATE: 09/25/2016 ANALYSIS DATE: 12/05/2016 and 12/06/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. B211 - Classroom	Sink	Public Access	DKES-080	DK-S238	< 1.0	None
Rm. B211 - Classroom	Sink	Public Access	DKES-081	DK-S239	< 1.0	None
Rm. B214 - Boy's Bathroom	Sink	Public Access	DKES-078	DK-S236	< 1.0	None
Rm. B214 - Boy's Bathroom	Sink	Public Access	DKES-079	DK-S237	1.2	None
Rm. B216 - Girl's Bathroom	Sink	Public Access	DKES-076	DK-S234	< 1.0	None
Rm. B216 - Girl's Bathroom	Sink	Public Access	DKES-077	DK-S235	< 1.0	None
Rm. B217 - Classroom	Sink	Public Access	DKES-075	DK-S233	1.1	None
Rm. B217 - Classroom	Fountain	Public Access	DKES-148	DK-F204	< 1.0	None
Rm. B217A - Classroom Bathroom	Sink	Public Access	DKES-074	DK-S232	< 1.0	None
Rm. B218 - Classroom	Sink	Public Access	DKES-072	DK-S230	< 1.0	None
Rm. B222 - Commons Kitchenette	Sink	Secured - SCSD Staff Only	DKES-073	DK-S231	< 1.0	None
Rm. B223 - Classroom	Sink	Public Access	DKES-070	DK-S228	< 1.0	None
Rm. B224 - Classroom	Sink	Public Access	DKES-071	DK-S229	< 1.0	None
Rm. B225 - Classroom	Sink	Public Access	DKES-069	DK-S227	< 1.0	None
Rm. C202 - Hallway/Corridor	Fountain	Public Access	DKES-141	DK-F108	< 1.0	None
Rm. C202 - Hallway/Corridor	Fountain	Public Access	DKES-142	DK-F109	< 1.0	None
Rm. C213 - Staff's Bathroom	Sink	Secured - SCSD Staff Only	DKES-068	DK-S226	< 1.0	None
Rm. C216 - Kitchenette	Sink	Secured - SCSD Staff Only	DKES-032	DK-S130	< 1.0	None
Rm. C218 - Classroom	Sink	Public Access	DKES-031	DK-S129	< 1.0	None
Rm. C219 - Classroom	Sink	Public Access	DKES-033	DK-S131	< 1.0	None
Rm. C220 - Classroom	Sink	Public Access	DKES-034	DK-S132	< 1.0	None
Rm. C221 - Classroom	Sink	Public Access	DKES-035	DK-S133	< 1.0	None
Rm. C221 - Classroom	Fountain	Public Access	DKES-143	DK-F110	< 1.0	None
Rm. C221A - Classroom Bathroom	Sink	Public Access	DKES-036	DK-S134	< 1.0	None
Rm. C225 - Classroom	Sink	Public Access	DKES-038	DK-S136	< 1.0	None
Rm. C225 - Classroom	Fountain	Public Access	DKES-144	DK-F111	< 1.0	None
Rm. C225A - Classroom Bathroom	Sink	Public Access	DKES-037	DK-S135	< 1.0	None
Rm. C226 - Classroom	Sink	Public Access	DKES-039	DK-S137	< 1.0	None
Rm. C227 - Classroom	Sink	Public Access	DKES-040	DK-S138	< 1.0	None

# SYRACUSE CITY SCHOOL DISTRICT

## DR. KING ELEMENTARY SCHOOL

SAMPLE DATE: 09/25/2016 ANALYSIS DATE: 12/05/2016 and 12/06/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. C228 - Classroom	Sink	Public Access	DKES-041	DK-S139	< 1.0	None
Rm. C229 - Girl's Bathroom	Sink	Public Access	DKES-042	DK-S140	5.9	None
Rm. C230 - Boy's Bathroom	Sink	Public Access	DKES-043	DK-S141	< 1.0	None

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-018
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1619533
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.