

SYRACUSE CITY SCHOOL DISTRICT
VAN DUYN ELEMENTARY SCHOOL

SAMPLE DATE: 09/24/2016 ANALYSIS DATE: 12/13/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 001 - Cafeteria	Fountain	Public Access	069	VN-F100	< 1.0	None
Rm. 001 - Cafeteria	Fountain	Public Access	070	VN-F101	< 1.0	None
Rm. B10A - Receiving Room Bathroom	Sink	Secured - SCSD Staff Only	001	VN-S100	1.4	None
Rm. 0B8 - Kitchen	Sink	Secured - SCSD Staff Only	002	VN-S101	< 1.0	None
Rm. 0B8 - Kitchen	Sink	Secured - SCSD Staff Only	003	VN-S102	< 1.0	None
Rm. 0B8 - Kitchen	Sink	Secured - SCSD Staff Only	004	VN-S103	< 1.0	None
Rm. 0B8 - Kitchen	Sink	Secured - SCSD Staff Only	005	VN-S104	1.2	None
Rm. 031 - Hallway/Corridor	Fountain	Public Access	071	VN-F102	< 1.0	None
Rm. 0B1A - Hallway/Vestibule	Sink	Public Access	006	VN-S105	11.0	None
Rm. 0B1A - Hallway/Vestibule	Sink	Public Access	007	VN-S106	< 1.0	None
Rm. 0B1A - Hallway/Vestibule	Sink	Public Access	008	VN-S107	< 1.0	None
Rm. 0B1A - Hallway/Vestibule	Sink	Public Access	009	VN-S108	12.0	None
Rm. 005 - Classroom	Sink	Public Access	010	VN-S109	< 1.0	None
Rm. 010A - Office	Sink	Secured - SCSD Staff Only	011	VN-S110	3.6	None
Rm. 134 - Classroom	Sink	Public Access	012	VN-S111	1.8	None
Rm. 100M - Hallway/Corridor	Fountain	Public Access	072	VN-F103	< 1.0	None
Rm. 132 - Classroom	Sink	Public Access	013	VN-S112	1.5	None
Rm. 135 - Classroom	Sink	Public Access	014	VN-S113	< 1.0	None
Rm. 133 - Classroom	Sink	Public Access	015	VN-S114	< 1.0	None
Rm. 128 - Classroom	Sink	Public Access	016	VN-S115A	< 1.0	None
Rm. 129 - Classroom	Sink	Public Access	017	VN-S115B	< 1.0	None
Rm. 123 - Classroom	Sink	Public Access	018	VN-S117	1.4	None
Rm. 123 - Classroom	Fountain	Public Access	073	VN-F104	< 1.0	None
Rm. 120 - Classroom	Sink	Public Access	019	VN-S118	1.4	None
Rm. 120A - Classroom Bathroom	Sink	Public Access	020	VN-S119	14.0	None
Rm. 109 - Nurse's Room	Sink	Public Access	021	VN-S120	1.2	None
Rm. 109B - Nurse's Bathroom	Sink	Public Access	022	VN-S121	1.1	None
Rm. 117 - Classroom	Sink	Public Access	023	VN-S122	< 1.0	None
Rm. 109A - Exam Room	Sink	Public Access	024	VN-S123	2.5	None

**SYRACUSE CITY SCHOOL DISTRICT
VAN DUYN ELEMENTARY SCHOOL**

SAMPLE DATE: 09/24/2016 ANALYSIS DATE: 12/13/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 115A - Staff Bathroom	Sink	Secured - SCSD Staff Only	025	VN-S124	4.2	None
Rm. 115B - Staff Bathroom	Sink	Secured - SCSD Staff Only	026	VN-S125	9.5	None
Rm. 119D - Work Room	Sink	Secured - SCSD Staff Only	027	VN-S126	2.8	None
Rm. 115E - Lounge Kitchenette	Sink	Secured - SCSD Staff Only	028	VN-S127	< 1.0	None
Rm. 004 - Boiler/Meter Room	Hose Bib at Meter Assembly	Secured - SCSD Staff Only	029	VN-S200	10.0	None
Rm. 0A8 - Hallway/Corridor	Fountain	Public Access	074	VN-F200	< 1.0	None
Rm. 023 - Classroom	Sink	Public Access	030	VN-S201	< 1.0	None
Rm. 023 - Classroom	Sink	Public Access	031	VN-S202	< 1.0	None
Rm. 023A - Classroom	Sink	Public Access	032	VN-S203	< 1.0	None
Rm. 023A - Classroom	Sink	Public Access	033	VN-S204	< 1.0	None
Rm. 021 - Kitchen Room	Sink	Secured - SCSD Staff Only	034	VN-S205	< 1.0	None
Rm. 020A - Classroom	Sink	Public Access	035	VN-S206	< 1.0	None
Rm. 020A - Classroom	Sink	Public Access	036	VN-S207	< 1.0	None
Rm. 024 - Classroom	Sink	Public Access	037	VN-S208	< 1.0	None
Rm. 024 - Classroom	Sink	Public Access	038	VN-S209	< 1.0	None
Rm. 022 - Classroom	Sink	Public Access	039	VN-S210	< 1.0	None
Rm. 022 - Classroom	Sink	Public Access	040	VN-S211	< 1.0	None
Rm. 015 - Art Room	Sink	Public Access	041	VN-S212	1.2	None
Rm. 015 - Art Room	Sink	Public Access	042	VN-S213	2.2	None
Rm. 023A - Staff's Bathroom	Sink	Secured - SCSD Staff Only	043	VN-S214	< 1.0	None
Rm. 018A - Staff Resource Bathroom	Sink	Public Access	044	VN-S215	2.3	None
Rm. 100P - Hallway/Corridor	Fountain	Public Access	075	VN-F201	< 1.0	None
Rm. 102A - Boy's Locker Room	Sink	Public Access	045	VN-S216	9.0	None
Rm. 104A - Girl's Locker Room	Sink	Public Access	046	VN-S217	8.3	None
Rm. 103 - Gym	Fountain	Public Access	076	VN-F202	< 1.0	None
Rm. 103 - Gym	Fountain	Public Access	077	VN-F203	< 1.0	None
Rm. 103D - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	047	VN-S218	7.6	None
Rm. 108 - Classroom	Sink	Public Access	048	VN-S219	1.5	None
Rm. 110 - Classroom	Sink	Public Access	049	VN-S220	1.5	None

SYRACUSE CITY SCHOOL DISTRICT
VAN DUYN ELEMENTARY SCHOOL

SAMPLE DATE: 09/24/2016 ANALYSIS DATE: 12/13/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 111 - Classroom	Sink	Public Access	050	VN-S221	< 1.0	None
Rm. 113 - Office	Sink	Secured - SCSD Staff Only	051	VN-S222	27.0	SCSD removed fixture from service and is to replace
Rm. 113C - Principal's Bathroom	Sink	Secured - SCSD Staff Only	052	VN-S223	1.6	None
Rm. 230 - Hallway/Corridor	Fountain	Public Access	078	VN-F301	< 1.0	None
Rm. 230A - Girl's Bathroom	Sink	Public Access	053	VN-S301	4.7	None
Rm. 230A - Girl's Bathroom	Sink	Public Access	054	VN-S302	5.7	None
Rm. 230A - Girl's Bathroom	Sink	Public Access	055	VN-S303	3.8	None
Rm. 230B - Boy's Bathroom	Sink	Public Access	056	VN-S304	< 1.0	None
Rm. 230B - Boy's Bathroom	Sink	Public Access	057	VN-S305	6.4	None
Rm. 230B - Boy's Bathroom	Sink	Public Access	058	VN-S306	8.1	None
Rm. 207 - Teacher Resource	Sink	Secured - SCSD Staff Only	059	VN-S307	5.2	None
Rm. 221 - Staff Bathroom	Sink	Secured - SCSD Staff Only	060	VN-S308	< 1.0	None
Rm. 231 - Hallway/Corridor	Fountain	Public Access	079	VN-F302	< 1.0	None
Rm. 231B - Boy's Bathroom	Sink	Public Access	061	VN-S309	10.0	None
Rm. 231B - Boy's Bathroom	Sink	Public Access	062	VN-S310	2.4	None
Rm. 231B - Boy's Bathroom	Sink	Public Access	063	VN-S311	< 1.0	None
Rm. 231A - Girl's Bathroom	Sink	Public Access	064	VN-S312	< 1.0	None
Rm. 231A - Girl's Bathroom	Sink	Public Access	065	VN-S313	7.1	None
Rm. 231A - Girl's Bathroom	Sink	Public Access	066	VN-S314	3.7	None
Rm. 227A - Laboratory	Sink	Public Access	067	VN-S315	< 1.0	None
Rm. 227A - Laboratory	Sink	Public Access	068	VN-S316	1.8	None

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-015
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620400
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.