

SYRACUSE CITY SCHOOL DISTRICT
HUGHES and SYRACUSE LATIN ELEMENTARY SCHOOLS

SAMPLE DATE: 09/28/2016 ANALYSIS DATE: 12/18/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 001A - Staff Bathroom	Sink	Secured - SCSD Staff Only	HS-002	HS-S100	< 1.0	None
Rm. 002 - Music Room	Sink	Public Access	HS-004	HS-S102	< 1.0	None
Rm. 002 - Music Room	Fountain	Public Access	HS-074	HS-F101	< 1.0	None
Rm. 002A - Music Room Bathroom	Sink	Public Access	HS-003	HS-S101	2.3	None
Rm. 003 - Classroom	Sink	Public Access	HS-006	HS-S104	< 1.0	None
Rm. 003 - Classroom	Fountain	Public Access	HS-076	HS-F103	< 1.0	None
Rm. 004 - Classroom	Sink	Public Access	HS-005	HS-S103	< 1.0	None
Rm. 004 - Classroom	Fountain	Public Access	HS-075	HS-F102	< 1.0	None
Rm. 007 - Home & Careers Room	Sink	Public Access	--	HS-S106	--	Fixture not operating
Rm. 007 - Home & Careers Room	Sink	Public Access	HS-008	HS-S107	< 1.0	None
Rm. 008 - Classroom	Sink	Public Access	HS-009	HS-S108	< 1.0	None
Rm. 008 - Classroom	Fountain	Public Access	HS-077	HS-F104	1.2	None
Rm. 009 - Classroom	Sink	Public Access	HS-010	HS-S109	< 1.0	None
Rm. 009 - Classroom	Fountain	Public Access	HS-078	HS-F105	< 1.0	None
Rm. 010 - Classroom	Sink	Public Access	HS-011	HS-S110	1.0	None
Rm. 010 - Classroom	Fountain	Public Access	HS-079	HS-F106	1.5	None
Rm. 011 - Classroom	Sink	Public Access	HS-012	HS-S111	< 1.0	None
Rm. 011 - Classroom	Fountain	Public Access	HS-080	HS-F107	1.1	None
Rm. 012 - Classroom	Sink	Public Access	HS-013	HS-S112	< 1.0	None
Rm. 012 - Classroom	Fountain	Public Access	HS-081	HS-F108	1.1	None
Rm. 013 - Classroom	Sink	Public Access	HS-014	HS-S113	< 1.0	None
Rm. 013 - Classroom	Fountain	Public Access	HS-082	HS-F109	1.2	None
Rm. 019 - Meter/Boiler Room	Hose Bib at Meter Assembly	Secured - SCSD Staff Only	HS-001	HS-M100	20.0	SCSD to post warning sign
Rm. 024 - Hallway/Corridor	Fountain	Public Access	HS-087	HS-F114	< 1.0	None
Rm. 024 - Hallway/Corridor	Fountain	Public Access	HS-093	HS-F120	1.1	None
Rm. 024A - Custodian's Bathroom	Sink	Secured - SCSD Staff Only	HS-007	HS-S105	< 1.0	None
Rm. 037 - Staff Bathroom	Sink	Secured - SCSD Staff Only	HS-025	HS-S124	2.9	None
Rm. 037C - Hallway/Corridor	Fountain	Public Access	HS-073	HS-F100	< 1.0	None
Rm. 050 - Hallway/Corridor	Fountain	Public Access	HS-088	HS-F115	< 1.0	None

SYRACUSE CITY SCHOOL DISTRICT
HUGHES and SYRACUSE LATIN ELEMENTARY SCHOOLS

SAMPLE DATE: 09/28/2016 ANALYSIS DATE: 12/18/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 051 - Hallway/Corridor	Fountain	Public Access	HS-092	HS-F119	< 1.0	None
Rm. 057 - Boy's Bathroom	Sink	Public Access	HS-028	HS-S127	< 1.0	None
Rm. 057 - Boy's Bathroom	Sink	Public Access	HS-029	HS-S128	< 1.0	None
Rm. 093 - Girl's Bathroom	Sink	Public Access	HS-043	HS-S143	< 1.0	None
Rm. 093 - Girl's Bathroom	Sink	Public Access	HS-044	HS-S144	< 1.0	None
Rm. 103 - Kitchen	Sink	Secured - SCSD Staff Only	HS-062	HS-S162	1.3	None
Rm. 103 - Kitchen	Sink	Secured - SCSD Staff Only	HS-063	HS-S163	1.3	None
Rm. 103 - Kitchen	Sink	Secured - SCSD Staff Only	HS-064	HS-S164	1.7	None
Rm. 103 - Kitchen	Sink	Secured - SCSD Staff Only	HS-065	HS-S165	1.2	None
Rm. 103X - Classroom	Sink	Public Access	HS-015	HS-S114	< 1.0	None
Rm. 104X - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	HS-061	HS-S161	3.8	None
Rm. 106 - Classroom	Sink	Public Access	HS-016	HS-S115	< 1.0	None
Rm. 106 - Classroom	Fountain	Public Access	HS-083	HS-F110	1.2	None
Rm. 107 - Classroom	Sink	Public Access	HS-017	HS-S116	1.6	None
Rm. 108 - Classroom	Sink	Public Access	HS-018	HS-S117	< 1.0	None
Rm. 108 - Classroom	Fountain	Public Access	HS-084	HS-F111	< 1.0	None
Rm. 109 - Classroom	Sink	Public Access	HS-019	HS-S118	2.8	None
Rm. 109 - Classroom	Fountain	Public Access	HS-085	HS-F112	1.4	None
Rm. 110 - Classroom	Sink	Public Access	HS-020	HS-S119	< 1.0	None
Rm. 110 - Classroom	Fountain	Public Access	HS-086	HS-F113	< 1.0	None
Rm. 113 - Audiologist's Room	Sink	Public Access	HS-022	HS-S121	2.4	None
Rm. 113A - Audiologist's Bathroom	Sink	Public Access	HS-021	HS-S120	3.1	None
Rm. 114 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	HS-023	HS-S122	< 1.0	None
Rm. 114D - Teacher's Lounge Bathroom	Sink	Secured - SCSD Staff Only	HS-024	HS-S123	< 1.0	None
Rm. 121 - Girl's Bathroom	Sink	Public Access	HS-057	HS-S157	< 1.0	None
Rm. 121 - Girl's Bathroom	Sink	Public Access	HS-058	HS-S158	< 1.0	None
Rm. 122 - Boy's Bathroom	Sink	Public Access	HS-059	HS-S159	< 1.0	None
Rm. 122 - Boy's Bathroom	Sink	Public Access	HS-060	HS-S160	< 1.0	None
Rm. 123 - Classroom	Sink	Public Access	HS-037	HS-S137	2.0	None

SYRACUSE CITY SCHOOL DISTRICT
HUGHES and SYRACUSE LATIN ELEMENTARY SCHOOLS

SAMPLE DATE: 09/28/2016 ANALYSIS DATE: 12/18/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 123 - Classroom	Sink	Public Access	HS-038	HS-S138	5.4	None
Rm. 123 - Classroom	Fountain	Public Access	HS-091	HS-F118	1.7	None
Rm. 124 - Classroom	Sink	Public Access	HS-036	HS-S135	1.6	None
Rm. 124 - Classroom	Sink	Public Access	--	HS-S136	--	Fixture not operating
Rm. 125 - Classroom	Sink	Public Access	HS-034	HS-S133	5.9	None
Rm. 125 - Classroom	Sink	Public Access	HS-035	HS-S134	2.3	None
Rm. 125 - Classroom	Fountain	Public Access	HS-090	HS-F117	1.4	None
Rm. 126 - Classroom	Sink	Public Access	HS-032	HS-S131	< 1.0	None
Rm. 126 - Classroom	Sink	Public Access	HS-033	HS-S132	< 1.0	None
Rm. 126 - Classroom	Fountain	Public Access	HS-089	HS-F116	< 1.0	None
Rm. 127 - Classroom	Sink	Public Access	HS-030	HS-S129	2.2	None
Rm. 127 - Classroom	Sink	Public Access	HS-031	HS-S130	2.2	None
Rm. 128C - Office Bathroom	Sink	Secured - SCSD Staff Only	HS-039	HS-S139	< 1.0	None
Rm. 129 - Classroom	Sink	Public Access	HS-040	HS-S140	< 1.0	None
Rm. 129 - Classroom	Sink	Public Access	HS-041	HS-S141	7.5	None
Rm. 129B - Classroom Bathroom	Sink	Public Access	HS-042	HS-S142	3.0	None
Rm. 137D - Hallway/Corridor	Fountain	Public Access	HS-094	HS-F121	< 1.0	None
Rm. 138B - Resource Room Bathroom	Sink	Public Access	HS-047	HS-S147	< 1.0	None
Rm. 141 - Kitchen	Sink	Secured - SCSD Staff Only	HS-048	HS-S148	2.6	None
Rm. 141 - Kitchen	Sink	Secured - SCSD Staff Only	HS-049	HS-S149	< 1.0	None
Rm 142D - Main Office	Sink	Secured - SCSD Staff Only	HS-052	HS-S152	< 1.0	None
Rm. 144 - Nurse's Office	Sink	Public Access	HS-055	HS-S155	< 1.0	None
Rm. 144B - Nurse's Office Bathroom	Sink	Public Access	HS-054	HS-S154	2.4	None
Rm. 144C - Nurse's Office Bathroom	Sink	Public Access	HS-056	HS-S156	2.1	None
Rm. 144D - Exam Room	Sink	Public Access	HS-053	HS-S153	< 1.0	None
Rm. 144E - Main Office Bathroom	Sink	Secured - SCSD Staff Only	HS-051	HS-S151	< 1.0	None
Rm. 144F - Main Office Bathroom	Sink	Secured - SCSD Staff Only	HS-050	HS-S150	< 1.0	None
Rm. 146 - Girl's Bathroom	Sink	Public Access	HS-045	HS-S145	1.2	None
Rm. 146 - Girl's Bathroom	Sink	Public Access	HS-046	HS-S146	< 1.0	None

SYRACUSE CITY SCHOOL DISTRICT
HUGHES and SYRACUSE LATIN ELEMENTARY SCHOOLS

SAMPLE DATE: 09/28/2016 ANALYSIS DATE: 12/18/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 150 - Boy's Bathroom	Sink	Public Access	HS-026	HS-S125	2.9	None
Rm. 150 - Boy's Bathroom	Sink	Public Access	HS-027	HS-S126	1.1	None
Rm. 209 - Classroom	Sink	Public Access	HS-071	HS-S171	1.2	None
Rm. 209 - Classroom	Fountain	Public Access	HS-097	HS-F124	< 1.0	None
Rm. 211 - Classroom	Sink	Public Access	HS-072	HS-S172	1.4	None
Rm. 211 - Classroom	Fountain	Public Access	HS-098	HS-F125	5.6	None
Rm. 213A - Hallway/Corridor	Fountain	Public Access	HS-095	HS-F122	1.2	None
Rm. 213B - Hallway/Corridor	Fountain	Public Access	HS-096	HS-F123	< 1.0	None
Rm. 217 - Staff Bathroom	Sink	Secured - SCSO Staff Only	HS-068	HS-S168	< 1.0	None
Rm. 221 - Boy's Bathroom	Sink	Public Access	HS-066	HS-S166	3.6	None
Rm. 221 - Boy's Bathroom	Sink	Public Access	HS-067	HS-S167	< 1.0	None
Rm. 231 - Girl's Bathroom	Sink	Public Access	HS-069	HS-S169	< 1.0	None
Rm. 231 - Girl's Bathroom	Sink	Public Access	HS-070	HS-S170	2.9	None

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-024
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620674
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.