

**SYRACUSE CITY SCHOOL DISTRICT**  
**CLARY MIDDLE SCHOOL**

SAMPLE DATE: 10/14/2016 ANALYSIS DATE: 12/20/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 001 - Classroom	Sink	Public Access	--	CY-S114	--	Fixture not operating
Rm. 001 - Classroom	Sink	Public Access	--	CY-S115	--	Fixture not operating
Rm. 001D - Classroom	Fountain	Public Access	CY-069	CY-F105	1.3	None
Rm. 001E - Classroom	Sink	Public Access	CY-014	CY-S113	1.4	None
Rm. 002B - Main Office	Sink	Secured - SCSD Staff Only	CY-064	CY-S165	2.9	None
Rm. 004B - Nurse's Office Bathroom	Sink	Public Access	CY-059	CY-S160	7.0	None
Rm. 004D - Clinic Room	Sink	Public Access	CY-061	CY-S162	1.9	None
Rm. 005A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	CY-058	CY-S159	2.3	None
Rm. 005B - Staff Bathroom	Sink	Secured - SCSD Staff Only	CY-057	CY-S158	4.9	None
Rm. 008 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	CY-054	CY-S155	1.1	None
Rm. 008 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	CY-055	CY-S156	< 1.0	None
Rm. 022 - Boy's Bathroom	Sink	Public Access	CY-049	CY-S150	2.9	None
Rm. 022 - Boy's Bathroom	Sink	Public Access	CY-050	CY-S151	2.7	None
Rm. 022 - Boy's Bathroom	Sink	Public Access	CY-051	CY-S152	4.6	None
Rm. 022 - Boy's Bathroom	Sink	Public Access	CY-052	CY-S153	6.7	None
Rm. 022 - Boy's Bathroom	Sink	Public Access	CY-053	CY-S154	1.6	None
Rm. 023 - Girl's Bathroom	Sink	Public Access	CY-046	CY-S147	7.6	None
Rm. 023 - Girl's Bathroom	Sink	Public Access	CY-047	CY-S148	8.2	None
Rm. 023 - Girl's Bathroom	Sink	Public Access	CY-048	CY-S149	11.0	None
Rm. 029 - Boy's Bathroom	Sink	Public Access	CY-036	CY-S137	12.0	None
Rm. 029 - Boy's Bathroom	Sink	Public Access	CY-037	CY-S138	17.0	SCSD removed fixture from service and is to replace
Rm. 029 - Boy's Bathroom	Sink	Public Access	CY-038	CY-S139	4.1	None
Rm. 029 - Boy's Bathroom	Sink	Public Access	CY-039	CY-S140	13.0	None
Rm. 029 - Boy's Bathroom	Sink	Public Access	CY-040	CY-S141	18.0	SCSD removed fixture from service and is to replace
Rm. 030 - Girl's Bathroom	Sink	Public Access	CY-041	CY-S142	5.9	None
Rm. 030 - Girl's Bathroom	Sink	Public Access	CY-042	CY-S143	7.5	None
Rm. 030 - Girl's Bathroom	Sink	Public Access	CY-043	CY-S144	4.9	None
Rm. 030 - Girl's Bathroom	Sink	Public Access	CY-044	CY-S145	8.3	None
Rm. 030 - Girl's Bathroom	Sink	Public Access	CY-045	CY-S146	5.8	None

**SYRACUSE CITY SCHOOL DISTRICT**  
**CLARY MIDDLE SCHOOL**

SAMPLE DATE: 10/14/2016 ANALYSIS DATE: 12/20/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 039 - Home & Careers Room	Sink	Public Access	CY-029	CY-S130	10.0	None
Rm. 039 - Home & Careers Room	Sink	Public Access	CY-030	CY-S131	13.0	None
Rm. 039 - Home & Careers Room	Sink	Public Access	CY-031	CY-S132	1.4	None
Rm. 042 - Home & Careers Room	Sink	Public Access	CY-032	CY-S133	1.3	None
Rm. 042 - Home & Careers Room	Sink	Public Access	CY-033	CY-S134	11.0	None
Rm. 042 - Home & Careers Room	Sink	Public Access	CY-034	CY-S135	8.5	None
Rm. 055 - Staff Locker Room Bathroom	Sink	Secured - SCSD Staff Only	CY-016	CY-S117	4.6	None
Rm. 056 - Staff Locker Room Bathroom	Sink	Secured - SCSD Staff Only	CY-015	CY-S116	8.1	None
Rm. 060 - Girl's Locker Room	Fountain	Public Access	CY-066	CY-F101	2.3	None
Rm. 068 - Boy's Locker Room	Fountain	Public Access	--	CY-F102	--	Fixture not operating
Rm. 071 - Group Instruction Room	Sink	Public Access	CY-008	CY-S107	2.5	None
Rm. 076A - Classroom	Sink	Public Access	CY-013	CY-S112	1.5	None
Rm. 152 - Hallway/Corridor	Fountain	Public Access	CY-071	CY-F107	< 1.0	None
Rm. 153 - Hallway/Corridor	Fountain	Public Access	CY-072	CY-F108	2.1	None
Rm. 163 - Hallway/Corridor	Fountain	Public Access	CY-068	CY-F104	< 1.0	None
Rm. 202 - Hallway/Corridor	Fountain	Public Access	CY-065	CY-F100	1.4	None
Rm. 203 - Hallway/Corridor	Fountain	Public Access	CY-067	CY-F103	2.4	None
Rm. 208 - Men's Bathroom	Sink	Public Access	CY-009	CY-S108	3.0	None
Rm. 208 - Men's Bathroom	Sink	Public Access	CY-010	CY-S109	2.6	None
Rm. 210 - Women's Bathroom	Sink	Public Access	CY-011	CY-S110	2.8	None
Rm. 210 - Women's Bathroom	Sink	Public Access	CY-012	CY-S111	5.3	None
Rm. 217 - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	CY-007	CY-S106	7.9	None
Rm. 223 - Boy's Locker Room Bathroom	Sink	Public Access	CY-005	CY-S104	6.7	None
Rm. 223 - Boy's Locker Room Bathroom	Sink	Public Access	CY-006	CY-S105	5.4	None
Rm. 238 - Girl's Locker Room Bathroom	Sink	Public Access	CY-003	CY-S102	9.4	None
Rm. 238 - Girl's Locker Room Bathroom	Sink	Public Access	CY-004	CY-S103	6.6	None
Rm. 244 - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	CY-002	CY-S100	5.1	None
Rm. 245 - Boiler/Meter Room	Hose Bib at Meter Assembly	Secured - SCSD Staff Only	CY-001	CY-M100	2.2	None
Rm. 309A - Main Office Bathroom	Sink	Secured - SCSD Staff Only	CY-063	CY-S164	5.4	None

**SYRACUSE CITY SCHOOL DISTRICT**  
**CLARY MIDDLE SCHOOL**

SAMPLE DATE: 10/14/2016 ANALYSIS DATE: 12/20/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 309B - Main Office Bathroom	Sink	Secured - SCSD Staff Only	CY-062	CY-S163	12.0	None
Rm. 326 - Nurse's Office	Sink	Public Access	CY-060	CY-S161	1.2	None
Rm. 331 - Kitchen	Sink	Secured - SCSD Staff Only	CY-017	CY-S118	1.7	None
Rm. 331 - Kitchen	Sink	Secured - SCSD Staff Only	CY-018	CY-S119	1.2	None
Rm. 331 - Kitchen	Sink	Secured - SCSD Staff Only	CY-019	CY-S120	1.1	None
Rm. 331 - Kitchen	Sink	Secured - SCSD Staff Only	CY-020	CY-S121	2.9	None
Rm. 331 - Kitchen	Sink	Secured - SCSD Staff Only	CY-021	CY-S122	2.8	None
Rm. 331 - Kitchen	Sink	Secured - SCSD Staff Only	CY-022	CY-S123	< 1.0	None
Rm. 331 - Kitchen	Sink	Secured - SCSD Staff Only	CY-023	CY-S124	1.6	None
Rm. 331 - Kitchen	Kettle	Secured - SCSD Staff Only	CY-024	CY-S125	2.8	None
Rm. 331 - Kitchen	Kettle	Secured - SCSD Staff Only	CY-025	CY-S126	11.0	None
Rm. 331 - Kitchen	Steamer	Secured - SCSD Staff Only	CY-026	CY-S127	4.0	None
Rm. 331 - Kitchen	Steamer	Secured - SCSD Staff Only	CY-027	CY-S128	< 1.0	None
Rm. 339 - Kitchen	Sink	Secured - SCSD Staff Only	CY-028	CY-S129	2.7	None
Rm. 329 - Cafeteria	Fountain	Public Access	CY-070	CY-F106	< 1.0	None
Rm. 414 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	CY-056	CY-S157	3.0	None
Rm. 450 - Work Room	Sink	Secured - SCSD Staff Only	CY-035	CY-S136	58.0	SCSD removed fixture from service and is to replace

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-031
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620741
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.