

**SYRACUSE CITY SCHOOL DISTRICT
DELAWARE ELEMENTARY SCHOOL**

SAMPLE DATES: 09/28/2016 and 09/29/2016 ANALYSIS DATES: 12/19/2016, 12/21/2016 and 12/26/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 101 - Classroom	Sink	Public Access	DE-033	DE-S332	28.0	SCSD removed fixture from service and is to replace
Rm. 101 - Classroom	Fountain	Public Access	DE-078	DE-F310	1.8	None
Rm. 101A - Classroom Bathroom	Sink	Public Access	DE-034	DE-S333	11.0	None
Rm. 102 - Classroom	Sink	Public Access	DE-031	DE-S330	< 1.0	None
Rm. 102 - Classroom	Fountain	Public Access	DE-077	DE-F309	4.1	None
Rm. 102A - Classroom Bathroom	Sink	Public Access	DE-032	DE-S331	1.2	None
Rm. 103 - Classroom	Sink	Public Access	DE-026	DE-S325	3.0	None
Rm. 103 - Classroom	Fountain	Public Access	DE-075	DE-F307	2.7	None
Rm. 103A - Classroom Bathroom	Sink	Public Access	DE-027	DE-S326	< 1.0	None
Rm. 104 - Classroom	Sink	Public Access	DE-025	DE-S324	1.8	None
Rm. 104 - Classroom	Fountain	Public Access	DE-074	DE-F306	3.4	None
Rm. 104A - Classroom Bathroom	Sink	Public Access	DE-024	DE-S323	< 1.0	None
Rm. 105 - Classroom	Sink	Public Access	DE-029	DE-S328	< 1.0	None
Rm. 105 - Classroom	Fountain	Public Access	DE-076	DE-F308	1.1	None
Rm. 105A - Classroom Bathroom	Sink	Public Access	DE-028	DE-S327	< 1.0	None
Rm. 108 - Classroom	Sink	Public Access	DE-021	DE-S320	< 1.0	None
Rm. 108 - Classroom	Fountain	Public Access	DE-072	DE-F304	1.8	None
Rm. 108A - Classroom Bathroom	Sink	Public Access	DE-020	DE-S319	4.6	None
Rm. 110 - Classroom	Sink	Public Access	DE-019	DE-S318	2.1	None
Rm. 110 - Classroom	Fountain	Public Access	DE-071	DE-F303	1.7	None
Rm. 112 - Classroom	Sink	Public Access	DE-017	DE-S316	2.1	None
Rm. 112 - Classroom	Fountain	Public Access	DE-070	DE-F302	1.4	None
Rm. 112A - Classroom Bathroom	Sink	Public Access	DE-016	DE-S315	26.0	SCSD removed fixture from service and is to replace
Rm. 113 - Art Room	Sink	Public Access	DE-015	DE-S314	2.1	None
Rm. 114A - Girl's Locker Room Bathroom	Sink	Public Access	DE-013	DE-S312	4.3	None
Rm. 114A - Girl's Locker Room Bathroom	Sink	Public Access	DE-014	DE-S313	7.3	None
Rm. 115B - Boy's Locker Room Bathroom	Sink	Public Access	DE-012	DE-S311	2.1	None
Rm. 118 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	DE-007	DE-S306	1.3	None
Rm. 118A - Teacher's Lounge Bathroom	Sink	Secured - SCSD Staff Only	DE-008	DE-S307	< 1.0	None
Rm. 119D - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	DE-011	DE-S310	7.0	None

**SYRACUSE CITY SCHOOL DISTRICT
DELAWARE ELEMENTARY SCHOOL**

SAMPLE DATES: 09/28/2016 and 09/29/2016 ANALYSIS DATES: 12/19/2016, 12/21/2016 and 12/26/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 120 - Serving Room	Sink	Secured - SCSD Staff Only	DE-002	DE-S301	3.4	None
Rm. 120 - Serving Room	Sink	Secured - SCSD Staff Only	DE-003	DE-S302	3.5	None
Rm. 120 - Serving Room	Sink	Secured - SCSD Staff Only	DE-004	DE-S303	7.4	None
Rm. 120 - Serving Room	Sink	Secured - SCSD Staff Only	DE-005	DE-S304	39.0	SCSD removed fixture from service and is to replace
Rm. 120A - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	DE-006	DE-S305	27.0	SCSD removed fixture from service and is to replace
Rm. 123A - Hallway/Corridor	Fountain	Public Access	DE-069	DE-F301	< 1.0	None
Rm. 129 - Hallway/Corridor	Fountain	Public Access	DE-073	DE-F305	< 1.0	None
Rm. 134B - Staff Bathroom	Sink	Secured - SCSD Staff Only	DE-030	DE-S329	29.0	SCSD removed fixture from service and is to replace
Rm. 139 - Meter Room	Hose Bib at Meter Assembly	Secured - SCSD Staff Only	DE-001	DE-M300	36.0	SCSD to post warning sign
Rm. 141A - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	DE-022	DE-S321	170.0	SCSD removed fixture from service and is to replace
Rm. 141B - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	DE-023	DE-S322	46.0	SCSD removed fixture from service and is to replace
Rm. 145A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	DE-009	DE-S308	2.8	None
Rm. 145B - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	DE-010	DE-S309	28.0	SCSD removed fixture from service and is to replace
Rm. 190A - Classroom Bathroom	Sink	Public Access	DE-018	DE-S317	< 1.0	None
Rm. 206A - Clinic Bathroom	Sink	Public Access	DE-043	DE-S342	6.0	None
Rm. 206B - Clinical Lab	Sink	Public Access	DE-042	DE-S341	11.0	None
Rm. 206C - Treatment Center	Sink	Public Access	DE-041	DE-S340	6.7	None
Rm. 206D - Dental Room	Sink	Public Access	DE-040	DE-S339	5.7	None
Rm. 206E - Sick/Rest Room	Sink	Public Access	DE-039	DE-S338	11.0	None
Rm. 206F - Nurse's Room	Sink	Public Access	DE-038	DE-S337	2.3	None
Rm. 208C - Storage Room Bathroom	Sink	Secured - SCSD Staff Only	DE-044	DE-S343	< 1.0	None
Rm. 209 - Nurse's Room	Sink	Public Access	DE-046	DE-S345	< 1.0	None
Rm. 209A - Nurse's Bathroom	Sink	Public Access	DE-045	DE-S344	39.0	SCSD removed fixture from service and is to replace
Rm. 211A - Office Bathroom	Sink	Secured - SCSD Staff Only	DE-052	DE-S351	21.0	SCSD removed fixture from service and is to replace
Rm. 211B - Office Bathroom	Sink	Secured - SCSD Staff Only	DE-051	DE-S350	3.9	None
Rm. 232 - Hallway/Corridor	Fountain	Public Access	DE-079	DE-F311	< 1.0	None
Rm. 235 - Hallway/Vestibule	Sink	Public Access	DE-035	DE-S334	< 1.0	None
Rm. 235 - Hallway/Vestibule	Sink	Public Access	DE-036	DE-S335	< 1.0	None
Rm. 235 - Hallway/Vestibule	Sink	Public Access	DE-037	DE-S336	< 1.0	None
Rm. 240 - Hallway/Vestibule	Sink	Public Access	DE-047	DE-S346	< 1.0	None

SYRACUSE CITY SCHOOL DISTRICT DELAWARE ELEMENTARY SCHOOL

SAMPLE DATES: 09/28/2016 and 09/29/2016 ANALYSIS DATES: 12/19/2016, 12/21/2016 and 12/26/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 240 - Hallway/Vestibule	Sink	Public Access	DE-048	DE-S347	22.0	SCSD removed fixture from service and is to replace
Rm. 240 - Hallway/Vestibule	Sink	Public Access	DE-049	DE-S348	13.0	None
Rm. 240 - Hallway/Vestibule	Sink	Public Access	DE-050	DE-S349	1.2	None
Rm. 240 - Hallway/Vestibule	Fountain	Public Access	DE-080	DE-F312	< 1.0	None
Rm. 245 - Gym Lobby	Fountain	Public Access	DE-081	DE-F313	< 1.0	None
Rm. 306A - Classroom Bathroom	Sink	Public Access	DE-060	DE-S359	23.0	SCSD removed fixture from service and is to replace
Rm. 308A - Classroom Bathroom	Sink	Public Access	DE-059	DE-S358	1.6	None
Rm. 319 - Work Room	Sink	Public Access	DE-053	DE-S352	7.9	None
Rm. 324A - Hallway/Corridor	Fountain	Public Access	DE-082	DE-F314	< 1.0	None
Rm. 330A - Hallway/Vestibule	Fountain	Public Access	DE-085	DE-F317	1.5	None
Rm. 335 - Hallway/Vestibule	Sink	Public Access	DE-061	DE-S360	25.0	SCSD removed fixture from service and is to replace
Rm. 335 - Hallway/Vestibule	Sink	Public Access	DE-062	DE-S361	2.7	None
Rm. 335 - Hallway/Vestibule	Sink	Public Access	DE-063	DE-S362	4.4	None
Rm. 340 - Hallway/Vestibule	Sink	Public Access	DE-055	DE-S354	1.1	None
Rm. 340 - Hallway/Vestibule	Sink	Public Access	DE-056	DE-S355	< 1.0	None
Rm. 340 - Hallway/Vestibule	Sink	Public Access	DE-057	DE-S356	4.1	None
Rm. 340 - Hallway/Vestibule	Sink	Public Access	DE-058	DE-S357	< 1.0	None
Rm. 340 - Hallway/Vestibule	Fountain	Public Access	DE-083	DE-F315	< 1.0	None
Rm. 345A - Teacher's Lounge Bathroom	Sink	Secured - SCSD Staff Only	DE-054	DE-S353	21.0	SCSD removed fixture from service and is to replace
Rm. 405 - Girl's Bathroom	Sink	Public Access	DE-064	DE-S363	< 1.0	None
Rm. 405 - Girl's Bathroom	Sink	Public Access	DE-065	DE-S364	17.0	SCSD removed fixture from service and is to replace
Rm. 406 - Boy's Bathroom	Sink	Public Access	DE-067	DE-S366	5.8	None
Rm. 406 - Boy's Bathroom	Sink	Public Access	DE-068	DE-S367	3.2	None
Rm. 407 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DE-066	DE-S365	3.9	None
Rm. 429 - Hallway/Corridor	Fountain	Public Access	DE-084	DE-F316	< 1.0	None

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-023
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620673
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.