

SYRACUSE CITY SCHOOL DISTRICT
EXPEDITIONARY LEARNING CENTER MIDDLE SCHOOL

SAMPLE DATE: 10/14/2016 ANALYSIS DATES: 12/20/2016, 12/28/2016 and 01/04/2017

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 106 - Nurse's Office	Sink	Public Access	ELMS-017	ELMS-S316	6.0	None
Rm. 106A - Nurse's Office Bathroom	Sink	Public Access	ELMS-018	ELMS-S317	2.7	None
Rm. 110 - Hallway/Corridor	Fountain	Public Access	ELMS-012	ELMS-F311	< 1.0	None
Rm. 116A - Locker Room Bathroom	Sink	Public Access	ELMS-032	ELMS-S331	4.4	None
Rm. 119A - Classroom Bathroom	Sink	Public Access	ELMS-035	ELMS-S334	1.5	None
Rm. 120A - Classroom Bathroom	Sink	Public Access	ELMS-037	ELMS-S336	2.3	None
Rm. 123 - Hallway/Corridor	Fountain	Public Access	ELMS-033	ELMS-F332	< 1.0	None
Rm. 124 - Staff Bathroom	Sink	Secured - SCSD Staff Only	ELMS-038	ELMS-S337	1.7	None
Rm. 125A - Classroom Bathroom	Sink	Public Access	ELMS-036	ELMS-S335	2.0	None
Rm. 127A - Classroom Bathroom	Sink	Public Access	ELMS-034	ELMS-S333	< 1.0	None
Rm. 130A - Library Bathroom	Sink	Public Access	ELMS-031	ELMS-S330	9.1	None
Rm. 135 - Hallway/Corridor	Fountain	Public Access	ELMS-025	ELMS-F324	< 1.0	None
Rm. 137 - Girl's Locker Room Bathroom	Sink	Public Access	ELMS-026	ELMS-S325	5.4	None
Rm. 137 - Girl's Locker Room Bathroom	Sink	Public Access	ELMS-027	ELMS-S326	4.0	None
Rm. 143 - Gym Office	Sink	Secured - SCSD Staff Only	ELMS-030	ELMS-S329	6.9	None
Rm. 145 - Kitchen	Sink	Secured - SCSD Staff Only	ELMS-021	ELMS-S320	1.2	None
Rm. 145 - Kitchen	Sink	Secured - SCSD Staff Only	ELMS-022	ELMS-S321	1.9	None
Rm. 145 - Kitchen	Sink	Secured - SCSD Staff Only	ELMS-023	ELMS-S322	21.0	SCSD removed fixture from service and is to replace
Rm. 145 - Kitchen	Sink	Secured - SCSD Staff Only	ELMS-024	ELMS-S323	3.5	None
Rm. 147 - Boy's Locker Room Bathroom	Sink	Public Access	ELMS-028	ELMS-S327	5.6	None
Rm. 147 - Boy's Locker Room Bathroom	Sink	Public Access	ELMS-029	ELMS-S328	8.3	None
Rm. 150 - Staff's Bathroom	Sink	Secured - SCSD Staff Only	ELMS-020	ELMS-S319	1.4	None
Rm. 154 - Kitchenette	Sink	Secured - SCSD Staff Only	ELMS-019	ELMS-S318	1500.0	SCSD removed fixture from service and is to replace
Rm. 165 - Break Room	Sink	Secured - SCSD Staff Only	ELMS-016	ELMS-S315	< 1.0	None
Rm. 165A - Break Room Bathroom	Sink	Secured - SCSD Staff Only	ELMS-014	ELMS-S313	6.1	None
Rm. 165B - Break Room Bathroom	Sink	Secured - SCSD Staff Only	ELMS-015	ELMS-S314	16.0	SCSD removed fixture from service and is to replace
Rm. 167 - Principal's Bathroom	Sink	Secured - SCSD Staff Only	ELMS-013	ELMS-S312	2.3	None
Rm. 168 - Hallway/Vestibule	Sink	Public Access	ELMS-010	ELMS-S309	7.6	None
Rm. 168 - Hallway/Vestibule	Sink	Public Access	ELMS-011	ELMS-S310	6.2	None

SYRACUSE CITY SCHOOL DISTRICT
EXPEDITIONARY LEARNING CENTER MIDDLE SCHOOL

SAMPLE DATE: 10/14/2016 ANALYSIS DATES: 12/20/2016, 12/28/2016 and 01/04/2017

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 172A - Classroom Bathroom	Sink	Public Access	ELMS-009	ELMS-S308	< 1.0	None
Rm. 176A - Classroom Bathroom	Sink	Public Access	ELMS-008	ELMS-S307	< 1.0	None
Rm. 178 - Classroom	Sink	Public Access	ELMS-005	ELMS-S304	1.3	None
Rm. 178 - Classroom	Sink	Public Access	ELMS-006	ELMS-S305	2.7	None
Rm. 178A - Classroom Bathroom	Sink	Public Access	ELMS-007	ELMS-S306	1.2	None
Rm. 182 - Hallway/Corridor	Fountain	Public Access	ELMS-004	ELMS-F303	< 1.0	None
Rm. 188 - Sprinkler/Meter Room	Hose Bib at Meter Assembly	Secured - SCSD Staff Only	ELMS-001	ELMS-M300	55.0	SCSD to post warning sign
Rm. 189 - Art Room	Sink	Public Access	ELMS-003	ELMS-S302	< 1.0	None
Rm. 190 - Kitchen	Sink	Secured - SCSD Staff Only	ELMS-002	ELMS-S301	2.1	None

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-032
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620740
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.