

SYRACUSE CITY SCHOOL DISTRICT

DANFORTH MIDDLE SCHOOL

SAMPLE DATE: 10/07/2016 ANALYSIS DATE: 12/15/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 015 - Office	Sink	Secured - SCSD Staff Only	DH-006	DH-S309	< 1.0	None
Rm. 101 - Classroom	Sink	Secured - SCSD Staff Only	DH-018	DH-S320	1.1	None
Rm. 106 - Hallway/Corridor	Fountain	Public Access	DH-026	DH-F328	< 1.0	None
Rm. 110 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DH-024	DH-S326	4.6	None
Rm. 111 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DH-023	DH-S325	< 1.0	None
Rm. 113 - Classroom	Sink	Public Access	DH-032	DH-S334	< 1.0	None
Rm. 115 - Classroom	Fountain	Public Access	DH-030	DH-F332	< 1.0	None
Rm. 115 - Classroom	Sink	Public Access	DH-031	DH-S333	< 1.0	None
Rm. 115A - Classroom Bathroom	Sink	Public Access	DH-029	DH-S331	< 1.0	None
Rm. 116 - Classroom	Sink	Public Access	DH-025	DH-S327	< 1.0	None
Rm. 116 - Classroom	Fountain	Public Access	DH-028	DH-F330	< 1.0	None
Rm. 116A - Classroom Bathroom	Sink	Public Access	DH-027	DH-S329	1.2	None
Rm. 119B - Work Room Bathroom	Sink	Secured - SCSD Staff Only	DH-022	DH-S324	2.4	None
Rm. 122 - Nurse's Office	Sink	Public Access	DH-020	DH-S322	< 1.0	None
Rm. 122A - Nurse's Office Bathroom	Sink	Public Access	DH-021	DH-S323	1.7	None
Rm. 123 - Classroom	Sink	Public Access	DH-019	DH-S321	2.4	None
Rm. 124 - Classroom	Sink	Public Access	DH-017	DH-S319B	1.3	None
Rm. 125 - Teacher's Resource Room	Sink	Public Access	DH-005	DH-S307	7.5	None
Rm. 127 - Art Room	Sink	Public Access	--	DH-S305	--	Fixture not operating
Rm. 127 - Art Room	Sink	Public Access	--	DH-S306	--	Fixture not operating
Rm. 127 - Art Room	Sink	Public Access	--	DH-S308	--	Fixture not operating
Rm. 131 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	DH-008	DH-S311	< 1.0	None
Rm. 132 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DH-007	DH-S310	< 1.0	None
Rm. 134 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DH-009	DH-S312	1.4	None
Rm. 143 - Kitchen	Sink	Secured - SCSD Staff Only	DH-010	DH-S313	2.0	None
Rm. 143 - Kitchen	Sink	Secured - SCSD Staff Only	DH-011	DH-S314	2.6	None
Rm. 143 - Kitchen	Sink	Secured - SCSD Staff Only	DH-012	DH-S315	6.5	None
Rm. 143 - Kitchen	Sink	Secured - SCSD Staff Only	DH-014	DH-S317	12.0	None
Rm. 143 - Kitchen	Sink	Secured - SCSD Staff Only	DH-015	DH-S318	2.2	None

SYRACUSE CITY SCHOOL DISTRICT
DANFORTH MIDDLE SCHOOL
SAMPLE DATE: 10/07/2016 ANALYSIS DATE: 12/15/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 143 - Kitchen	Sink	Secured - SCSD Staff Only	DH-016	DH-S319A	< 1.0	None
Rm. 145 - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	DH-013	DH-S316	2.1	None
Rm. 152 - Hallway/Vestibule	Sink	Public Access	DH-001	DH-S301	< 1.0	None
Rm. 152 - Hallway/Vestibule	Sink	Public Access	DH-002	DH-S302	< 1.0	None
Rm. 152 - Hallway/Vestibule	Sink	Public Access	DH-003	DH-S303	< 1.0	None
Rm. 152 - Hallway/Vestibule	Sink	Public Access	DH-004	DH-S304	< 1.0	None
Rm. 157 - Classroom	Sink	Public Access	DH-033	DH-S335	< 1.0	None
Rm. 157 - Classroom	Sink	Public Access	DH-035	HE-F337	< 1.0	None
Rm. 157A - Classroom Bathroom	Sink	Public Access	DH-034	DH-S336	< 1.0	None
Rm. 158 - Classroom	Sink	Public Access	DH-038	DH-S340	< 1.0	None
Rm. 158 - Classroom	Fountain	Public Access	DH-040	DH-F342	< 1.0	None
Rm. 158A - Classroom Bathroom	Sink	Public Access	DH-039	DH-S341	< 1.0	None
Rm. 159 - Classroom	Sink	Public Access	DH-044	DH-S346	< 1.0	None
Rm. 159 - Classroom	Fountain	Public Access	DH-046	DH-F348	< 1.0	None
Rm. 159A - Classroom Bathroom	Sink	Public Access	DH-045	DH-S347	< 1.0	None
Rm. 161 - Classroom	Sink	Public Access	DH-042	DH-S344	< 1.0	None
Rm. 161 - Classroom	Fountain	Public Access	DH-043	DH-F345	< 1.0	None
Rm. 161A - Classroom Bathroom	Sink	Public Access	DH-041	DH-S343	2.3	None
Rm. 162 - Classroom	Sink	Public Access	DH-037	DH-S339	< 1.0	None
Rm. 162A - Classroom Bathroom	Sink	Public Access	DH-036	DH-S338	< 1.0	None
Rm. 203C - Storage Room Bathroom	Sink	Secured - SCSD Staff Only	DH-054	DH-S356	1.0	None
Rm. 204 - Hallway/Corridor	Fountain	Public Access	DH-051	DH-F353	< 1.0	None
Rm. 206 - Girl's Bathroom	Sink	Public Access	DH-049	DH-S351	< 1.0	None
Rm. 206 - Girl's Bathroom	Sink	Public Access	DH-050	DH-S352	< 1.0	None
Rm. 207 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	DH-047	DH-S349	< 1.0	None
Rm. 209 - Hallway/Corridor	Fountain	Public Access	DH-048	DH-F350	1.1	None
Rm. 222 - Classroom	Sink	Public Access	DH-066	DH-S368	< 1.0	None
Rm. 226B - Boy's Bathroom	Sink	Public Access	DH-052	DH-S354	< 1.0	None
Rm. 226B - Boy's Bathroom	Sink	Public Access	DH-053	DH-S355	< 1.0	None

SYRACUSE CITY SCHOOL DISTRICT
DANFORTH MIDDLE SCHOOL

SAMPLE DATE: 10/07/2016 ANALYSIS DATE: 12/15/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 227 - Hallway/Corridor	Fountain	Public Access	DH-068	DH-F370	7.3	None
Rm. 227A - Staff Bathroom	Sink	Secured - SCSD Staff Only	DH-067	DH-S369	< 1.0	None
Rm. 229 - Classroom	Sink	Public Access	DH-069	DH-S371	< 1.0	None
Rm. 231 - Fitness Room	Fountain	Public Access	DH-070	DH-F372	< 1.0	None
Rm. 234B - Boy's Locker Room Bathroom	Sink	Public Access	DH-073	DH-S375	7.5	None
Rm. 234B - Boy's Locker Room Bathroom	Sink	Public Access	DH-074	DH-S376	7.1	None
Rm. 235A - Girl's Locker Room Bathroom	Sink	Public Access	DH-075	DH-S377	< 1.0	None
Rm. 236 - Hallway/Corridor	Fountain	Public Access	DH-071	DH-F373	< 1.0	None
Rm. 238 - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	DH-072	DH-S374	4.4	None
Rm. 303 - Hallway/Corridor	Fountain	Public Access	DH-061	DH-F363	< 1.0	None
Rm. 305 - Girl's Bathroom	Sink	Public Access	DH-057	DH-S359	1.7	None
Rm. 305 - Girl's Bathroom	Sink	Public Access	DH-058	DH-S360	1.4	None
Rm. 306 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	DH-056	DH-S358	< 1.0	None
Rm. 308 - Hallway/Corridor	Fountain	Public Access	DH-055	DH-F357	2.0	None
Rm. 309 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	DH-059	DH-S361	8.5	None
Rm. 324 - Technology Room	Sink	Public Access	DH-064	DH-S366	< 1.0	None
Rm. 324A - Lobby	Sink	Public Access	DH-063	DH-S365	6.5	None
Rm. 326A - Boy's Bathroom	Sink	Public Access	DH-060	DH-S362	1.1	None
Rm. 326A - Boy's Bathroom	Sink	Public Access	DH-062	DH-S364	1.8	None
Rm. 327 - Hallway/Corridor	Fountain	Public Access	DH-065	DH-F367	< 1.0	None

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-027
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620495
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.