

**SYRACUSE CITY SCHOOL DISTRICT**  
**MEACHEM ELEMENTARY SCHOOL**

SAMPLE DATE: 09/27/2016 ANALYSIS DATE: 12/07/2016, 12/08/2016, 12/12/2016 and 12/14/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 002 - Cafeteria	Fountain	Public Access	060	MM-F100	< 1.0	None
Rm. 03C - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	003	MM-S101	1.4	None
Rm. 005 - Hallway/Vestibule	Sink	Public Access	008	MM-S106	8.2	None
Rm. 005 - Hallway/Vestibule	Sink	Public Access	009	MM-S107	< 1.0	None
Rm. 005 - Hallway/Vestibule	Sink	Public Access	010	MM-S108	1.9	None
Rm. 005 - Hallway/Vestibule	Sink	Public Access	011	MM-S109	1.2	None
Rm. 005 - Hallway/Corridor	Fountain	Public Access	061	MM-F101	< 1.0	None
Rm. 005 - Hallway/Corridor	Fountain	Public Access	062	MM-F102	< 1.0	None
Rm. 08A - Custodian's Bathroom	Sink	Secured - SCSD Staff Only	002	MM-S100	< 1.0	None
Rm. 016 - Art Room	Sink	Public Access	012	MM-S110	1.7	None
Rm. 016 - Art Room	Sink	Public Access	013	MM-S111	< 1.0	None
Rm. 020C - Unisex Bathroom	Sink	Public Access	014	MM-S112	< 1.0	None
Rm. 022 - Water Sprinkler/Meter Room	Hose Bib at Meter Assembly	Secured - SCSD Staff Only	001	MM-M100	340.0	SCSD to post warning sign
Rm. 023 - Hallway/Corridor	Fountain	Public Access	063	MM-F103	< 1.0	None
Rm. 026 - Kitchen	Sink	Secured - SCSD Staff Only	004	MM-S102	< 1.0	None
Rm. 026 - Kitchen	Sink	Secured - SCSD Staff Only	005	MM-S103	1.1	None
Rm. 026 - Kitchen	Sink	Secured - SCSD Staff Only	006	MM-S104	1.6	None
Rm. 026 - Kitchen	Sink	Secured - SCSD Staff Only	007	MM-S105	2.6	None
Rm. 100C - Hallway/Vestibule	Sink	Public Access	016	MM-S114	1.7	None
Rm. 100C - Hallway/Vestibule	Sink	Public Access	017	MM-S115	5.1	None
Rm. 100E - Hallway/Corridor	Fountain	Public Access	064	MM-F104	< 1.0	None
Rm. 100E - Hallway/Corridor	Fountain	Public Access	065	MM-F105	< 1.0	None
Rm. 100E - Hallway/Corridor	Fountain	Public Access	066	MM-F106	< 1.0	None
Rm. 100G - Hallway/Vestibule	Sink	Public Access	018	MM-S116	2.2	None
Rm. 100G - Hallway/Vestibule	Sink	Public Access	019	MM-S117	< 1.0	None
Rm. 101B - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	020	MM-S118	2.3	None
Rm. 103 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	023	MM-S121	< 1.0	None
Rm. 103C - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	022	MM-S120	< 1.0	None
Rm. 103D - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	021	MM-S119	< 1.0	None

**SYRACUSE CITY SCHOOL DISTRICT**  
**MEACHEM ELEMENTARY SCHOOL**

SAMPLE DATE: 09/27/2016 ANALYSIS DATE: 12/07/2016, 12/08/2016, 12/12/2016 and 12/14/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 104A - Exam Room	Sink	Public Access	025	MM-S123	3.2	None
Rm. 104B - Nurse's Bathroom	Sink	Public Access	024	MM-S122	< 1.0	None
Rm. 105 - Computer Lab	Sink	Public Access	026	MM-S124	27.0	SCSD permanently removed fixture from service
Rm. 108 - Classroom	Sink	Public Access	030	MM-S128	2.4	None
Rm. 108 - Classroom	Fountain	Public Access	067	MM-F107	1.1	None
Rm. 108 - Classroom	Sink	Public Access	031	MM-S129	< 1.0	None
Rm. 108B - Classroom Bathroom	Sink	Public Access	028	MM-S126	< 1.0	None
Rm. 108B - Classroom Bathroom	Sink	Public Access	029	MM-S127	3.0	None
Rm. 109F - Main Office Bathroom	Sink	Secured - SCSD Staff Only	027	MM-S125	< 1.0	None
Rm. 110 - Classroom	Sink	Public Access	033	MM-S131	8.0	None
Rm. 110 - Classroom	Fountain	Public Access	068	MM-F108	1.4	None
Rm. 110A - Classroom Bathroom	Sink	Public Access	032	MM-S130	5.5	None
Rm. 111 - Classroom	Sink	Public Access	042	MM-S140	7.4	None
Rm. 111 - Classroom	Fountain	Public Access	073	MM-F113	< 1.0	None
Rm. 112 - Classroom	Sink	Public Access	040	MM-S138	52.0	SCSD removed fixture from service and is to replace
Rm. 112 - Classroom	Fountain	Public Access	071	MM-F111	< 1.0	None
Rm. 113 - Classroom	Sink	Public Access	043	MM-S141	< 1.0	None
Rm. 113 - Classroom	Fountain	Public Access	074	MM-F114	< 1.0	None
Rm. 114 - Classroom	Sink	Public Access	041	MM-S139	1.5	None
Rm. 114 - Classroom	Fountain	Public Access	072	MM-F112	< 1.0	None
Rm. 115 - Classroom	Sink	Public Access	044	MM-S142	< 1.0	None
Rm. 115 - Classroom	Fountain	Public Access	075	MM-F115	< 1.0	None
Rm. 116 - Classroom	Sink	Public Access	045	MM-S143	< 1.0	None
Rm. 116 - Classroom	Fountain	Public Access	076	MM-F116	1.4	None
Rm. 117 - Classroom	Sink	Public Access	046	MM-S144	< 1.0	None
Rm. 117 - Classroom	Fountain	Public Access	077	MM-F117	1.7	None
Rm. 119 - Classroom	Sink	Public Access	047	MM-S145	< 1.0	None
Rm. 119 - Classroom	Fountain	Public Access	078	MM-F118	< 1.0	None
Rm. 122 - Staff Bathroom	Sink	Secured - SCSD Staff Only	034	MM-S132	1.4	None

**SYRACUSE CITY SCHOOL DISTRICT**  
**MEACHEM ELEMENTARY SCHOOL**

SAMPLE DATE: 09/27/2016 ANALYSIS DATE: 12/07/2016, 12/08/2016, 12/12/2016 and 12/14/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 128 - Hallway/Corridor	Fountain	Public Access	069	MM-F109	< 1.0	None
Rm. 128 - Hallway/Corridor	Fountain	Public Access	070	MM-F110	< 1.0	None
Rm. 130A - Hallway/Vestibule	Sink	Public Access	035	MM-S133	< 1.0	None
Rm. 130A - Hallway/Vestibule	Sink	Public Access	036	MM-S134	2.2	None
Rm. 130A - Hallway/Vestibule	Sink	Public Access	037	MM-S135	1.4	None
Rm. 130A - Hallway/Vestibule	Sink	Public Access	038	MM-S136	2.8	None
Rm. 130A - Hallway/Vestibule	Sink	Public Access	039	MM-S137	3.5	None
Rm. 141 - Group Instruction Room	Sink	Secured - SCSD Staff Only	015	MM-S113	1.4	None
Rm. 219 - Hallway/Corridor	Fountain	Public Access	081	MM-F121	< 1.0	None
Rm. 219 - Hallway/Corridor	Fountain	Public Access	082	MM-F122	< 1.0	None
Rm. 221 - Staff Bathroom	Sink	Secured - SCSD Staff Only	053	MM-S151	1.6	None
Rm. 223A - Library Office	Sink	Secured - SCSD Staff Only	059	MM-S157	2.3	None
Rm. 226 - Hallway/Vestibule	Sink	Public Access	054	MM-S152	< 1.0	None
Rm. 226 - Hallway/Vestibule	Sink	Public Access	055	MM-S153	3.2	None
Rm. 226 - Hallway/Vestibule	Sink	Public Access	056	MM-S154	1.2	None
Rm. 226 - Hallway/Vestibule	Sink	Public Access	057	MM-S155	3.0	None
Rm. 226 - Hallway/Vestibule	Sink	Public Access	058	MM-S156	< 1.0	None
Rm. 228 - Hallway/Corridor	Fountain	Public Access	079	MM-F119	< 1.0	None
Rm. 228 - Hallway/Corridor	Fountain	Public Access	080	MM-F120	< 1.0	None
Rm. 228C - Staff Bathroom	Sink	Secured - SCSD Staff Only	048	MM-S146	< 1.0	None
Rm. 231 - Hallway/Vestibule	Sink	Public Access	049	MM-S147	< 1.0	None
Rm. 231 - Hallway/Vestibule	Sink	Public Access	050	MM-S148	< 1.0	None
Rm. 231 - Hallway/Vestibule	Sink	Public Access	051	MM-S149	2.8	None
Rm. 231 - Hallway/Vestibule	Sink	Public Access	052	MM-S150	< 1.0	None

**Notes:**

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-022
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1619913
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.

