

SYRACUSE CITY SCHOOL DISTRICT

MSAP (SHEA) SCHOOL

SAMPLE DATE: 10/21/2016 ANALYSIS DATES: 12/28/2016 and 01/05/2017

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	MSAP-017	MSAP-S115	14.0	None
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	MSAP-018	MSAP-S116	18.0	SCSD removed fixture from service and is to replace
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	MSAP-019	MSAP-S117	14.0	None
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	MSAP-020	MSAP-S118	38.0	SCSD removed fixture from service and is to replace
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	MSAP-021	MSAP-S119	7.4	None
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	MSAP-022	MSAP-S120	15.0	SCSD removed fixture from service and is to replace
Rm. 106 - Kitchen	Kettle	Secured - SCSD Staff Only	MSAP-023	MSAP-S121	110.0	SCSD permanently removed this fixture from service
Rm. 106 - Kitchen	Steamer	Secured - SCSD Staff Only	MSAP-024	MSAP-S122	69.0	SCSD removed fixture from service and is to replace
Rm. 106E - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	MSAP-025	MSAP-S123	2.7	None
Rm. 110A - Office Bathroom	Sink	Secured - SCSD Staff Only	MSAP-008	MSAP-S106	19.0	SCSD removed fixture from service and is to replace
Rm. 114 - Classroom	Sink	Public Access	MSAP-007	MSAP-S105	11.0	None
Rm. 116 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	MSAP-002	MSAP-S100	13.0	None
Rm. 116E - Boiler/Meter Room	Hose Bib at Meter Assembly	Secured - SCSD Staff Only	MSAP-001	MSAP-M100	8.2	None
Rm. 117A - Office Bathroom	Sink	Secured - SCSD Staff Only	MSAP-005	MSAP-S103	6.3	None
Rm. 117A - Boy's Bathroom	Sink	Public Access	MSAP-010	MSAP-S108	6.9	None
Rm. 117A - Boy's Bathroom	Sink	Public Access	MSAP-011	MSAP-S109	3.0	None
Rm. 117A - Boy's Bathroom	Sink	Public Access	MSAP-012	MSAP-S110	3.8	None
Rm. 117B - Girl's Bathroom	Sink	Public Access	MSAP-013	MSAP-S111	14.0	None
Rm. 117B - Girl's Bathroom	Sink	Public Access	MSAP-014	MSAP-S112	2.4	None
Rm. 117B - Girl's Bathroom	Sink	Public Access	MSAP-015	MSAP-S113	19.0	SCSD removed fixture from service and is to replace
Rm. 117B - Girl's Bathroom	Sink	Public Access	MSAP-016	MSAP-S114	24.0	SCSD removed fixture from service and is to replace
Rm. 118 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	MSAP-004	MSAP-S102	3.4	None
Rm. 118A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	MSAP-003	MSAP-S101	3.3	None
Rm. 120 - Girl's Locker Room	Fountain	Public Access	MSAP-054	MSAP-F101	6.7	None
Rm. 122 - Girl's Locker Room Bathroom	Sink	Public Access	MSAP-006	MSAP-S104	10.0	None
Rm. 127 - Boy's Locker Room	Fountain	Public Access	MSAP-055	MSAP-F102	120.0	SCSD permanently removed this fixture from service
Rm. 128 - Boy's Locker Room Bathroom	Sink	Public Access	MSAP-009	MSAP-S107	310.0	SCSD removed fixture from service and is to replace
Rm. 130A - Hallway/Corridor	Fountain	Public Access	MSAP-056	MSAP-F103	1.4	None
Rm. 130J - Hallway/Corridor	Fountain	Public Access	MSAP-053	MSAP-F100	1.3	None

SYRACUSE CITY SCHOOL DISTRICT

MSAP (SHEA) SCHOOL

SAMPLE DATE: 10/21/2016 ANALYSIS DATES: 12/28/2016 and 01/05/2017

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 211P - Storage Room	Sink	Secured - SCSD Staff Only	MSAP-040	MSAP-S138	4.3	None
Rm. 211Q - Main Office Bathroom	Sink	Secured - SCSD Staff Only	MSAP-041	MSAP-S139	1.7	None
Rm. 211R - Main Office	Sink	Secured - SCSD Staff Only	MSAP-042	MSAP-S140	< 1.0	None
Rm. 212 - Classroom	Sink	Public Access	MSAP-029	MSAP-S127	7.3	None
Rm. 212 - Classroom	Sink	Public Access	MSAP-030	MSAP-S128	17.0	SCSD removed fixture from service and is to replace
Rm. 212 - Classroom	Sink	Public Access	MSAP-031	MSAP-S129	12.0	None
Rm. 215 - Home & Careers Room	Sink	Public Access	MSAP-026	MSAP-S124	34.0	SCSD removed fixture from service and is to replace
Rm. 215 - Home & Careers Room	Sink	Public Access	MSAP-027	MSAP-S125	13.0	None
Rm. 215 - Home & Careers Room	Sink	Public Access	MSAP-028	MSAP-S126	26.0	SCSD removed fixture from service and is to replace
Rm. 220 - Girl's Bathroom	Sink	Public Access	MSAP-036	MSAP-S134	9.1	None
Rm. 220 - Girl's Bathroom	Sink	Public Access	MSAP-037	MSAP-S135	4.6	None
Rm. 220 - Girl's Bathroom	Sink	Public Access	MSAP-038	MSAP-S136	13.0	None
Rm. 220 - Girl's Bathroom	Sink	Public Access	MSAP-039	MSAP-S137	2.9	None
Rm. 221 - Boy's Bathroom	Sink	Public Access	MSAP-032	MSAP-S130	3.4	None
Rm. 221 - Boy's Bathroom	Sink	Public Access	MSAP-033	MSAP-S131	3.5	None
Rm. 221 - Boy's Bathroom	Sink	Public Access	MSAP-034	MSAP-S132	9.6	None
Rm. 221 - Boy's Bathroom	Sink	Public Access	MSAP-035	MSAP-S133	16.0	SCSD removed fixture from service and is to replace
Rm. 225 - Hallway/Corridor	Fountain	Public Access	MSAP-057	MSAP-F104	< 1.0	None
Rm. 225H - Hallway/Corridor	Fountain	Public Access	MSAP-060	MSAP-F107	1.2	None
Rm. 225J - Hallway/Vestibule	Fountain	Public Access	MSAP-059	MSAP-F106	2.1	None
Rm. 225N - Hallway/Corridor	Fountain	Public Access	MSAP-058	MSAP-F105	< 1.0	None
Rm. 227 - Work Room	Sink	Secured - SCSD Staff Only	MSAP-048	MSAP-S146	3.5	None
Rm. 233 - Health Service Bathroom	Sink	Public Access	MSAP-046	MSAP-S144	3.8	None
Rm. 235 - Principal's Office	Sink	Secured - SCSD Staff Only	MSAP-043	MSAP-S141	5.7	None
Rm. 237 - Nurse's Office	Sink	Public Access	MSAP-047	MSAP-S145	4.6	None
Rm. 238 - Exam Room	Sink	Public Access	MSAP-045	MSAP-S143	6.1	None
Rm. 239 - Conference Room	Sink	Secured - SCSD Staff Only	MSAP-044	MSAP-S142	2.0	None
Rm. 239 - Girl's Bathroom	Sink	Public Access	MSAP-049	MSAP-S147	5.2	None
Rm. 239 - Girl's Bathroom	Sink	Public Access	MSAP-050	MSAP-S148	4.7	None

SYRACUSE CITY SCHOOL DISTRICT

MSAP (SHEA) SCHOOL

SAMPLE DATE: 10/21/2016 ANALYSIS DATES: 12/28/2016 and 01/05/2017

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 240 - Boy's Bathroom	Sink	Public Access	MSAP-051	MSAP-S149	5.4	None
Rm. 245 - Clinic Office	Sink	Public Access	MSAP-052	MSAP-S150	3.0	None

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-034
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620837
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.