

**SYRACUSE CITY SCHOOL DISTRICT**  
**GRANT MIDDLE SCHOOL**

SAMPLE DATE: 10/27/2016 ANALYSIS DATES: 12/23/2016, 12/26/2016, 12/28/2016 and 01/05/2017

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. B-2 - Storage Room	Sink	Secured - SCSD Staff Only	GT-069	GT-S204	1.5	None
Rm. B-13 - Girl's Locker Room Bathroom	Sink	Public Access	GT-067	GT-S202	160.0	SCSD permanently removed fixture from service
Rm. B-13 - Girl's Locker Room Bathroom	Sink	Public Access	GT-068	GT-S203	15.0	SCSD permanently removed fixture from service
Rm. B-16 - Boy's Locker Room	Fountain	Public Access	GT-104	GT-F201	3.6	None
Rm. B-18 - Boy's Locker Room Bathroom	Sink	Public Access	GT-065	GT-S(M)200	25.0	SCSD permanently removed fixture from service
Rm. B-18 - Boy's Locker Room Bathroom	Sink	Public Access	GT-066	GT-S201	7.8	SCSD permanently removed fixture from service
Rm. 107D - Office Bathroom	Sink	Secured - SCSD Staff Only	GT-081	GT-S216	4.7	None
Rm. 108B - Exam Room	Sink	Public Access	GT-082	GT-S217	3.5	None
Rm. 109 - Nurse's Office	Sink	Public Access	GT-083	GT-S218	2.8	None
Rm. 109A - Nurse's Office Bathroom	Sink	Public Access	GT-084	GT-S219	1.6	None
Rm. 110 - Classroom	Sink	Public Access	GT-085	GT-S220	2.8	None
Rm. 115 - Music Room	Sink	Public Access	GT-091	GT-S226	19.0	SCSD removed fixture from service and is to replace
Rm. 117 - Main Office Bathroom	Sink	Secured - SCSD Staff Only	GT-088	GT-S223	6.2	None
Rm. 118 - Main Office Bathroom	Sink	Secured - SCSD Staff Only	GT-087	GT-S222	2.8	None
Rm. 120 - Hallway/Corridor	Fountain	Public Access	GT-107	GT-F206	< 1.0	None
Rm. 120 - Hallway/Corridor	Fountain	Public Access	--	GT-F204	--	Fixture not operating
Rm. 120 - Hallway/Corridor	Fountain	Public Access	--	GT-F205	--	Fixture not operating
Rm. 123 - Work Room	Sink	Secured - SCSD Staff Only	GT-086	GT-S221	5.8	None
Rm. 131 - Serving Room	Sink	Secured - SCSD Staff Only	GT-077	GT-S212	1.8	None
Rm. 132A - Medical Assistance Waiting Room	Sink	Public Access	GT-010	GT-S109	< 1.0	None
Rm. 132A - Medical Assistance Waiting Room	Sink	Public Access	GT-013	GT-S112	< 1.0	None
Rm. 132A - Medical Assistance Waiting Room	Sink	Public Access	GT-014	GT-S113	< 1.0	None
Rm. 132A - Medical Assistance Waiting Room	Sink	Public Access	GT-015	GT-S114	2.7	None
Rm. 132B - Dental Office	Sink	Public Access	GT-016	GT-S115	3.0	None
Rm. 132B - Dental Office	Sink (Chair)	Public Access	GT-017	GT-S116	< 1.0	None
Rm. 132F - Examination Room	Sink	Public Access	GT-012	GT-S111	< 1.0	None
Rm. 132G - Medical Assistance Bathroom	Sink	Public Access	GT-011	GT-S110	< 1.0	None
Rm. 133A - Kitchen	Sink	Secured - SCSD Staff Only	GT-071	GT-S206	1.2	None
Rm. 133A - Kitchen	Sink	Secured - SCSD Staff Only	GT-072	GT-S207	15.0	SCSD removed fixture from service and is to replace

**SYRACUSE CITY SCHOOL DISTRICT**  
**GRANT MIDDLE SCHOOL**

SAMPLE DATE: 10/27/2016 ANALYSIS DATES: 12/23/2016, 12/26/2016, 12/28/2016 and 01/05/2017

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 133A - Kitchen	Sink	Secured - SCSD Staff Only	GT-073	GT-S208	1.4	None
Rm. 133A - Kitchen	Sink	Secured - SCSD Staff Only	GT-074	GT-S209	< 1.0	None
Rm. 133A - Kitchen	Sink	Secured - SCSD Staff Only	GT-075	GT-S210	3.6	None
Rm. 133A - Kitchen	Sink	Secured - SCSD Staff Only	GT-078	GT-S213	< 1.0	None
Rm. 134A - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	GT-076	GT-S211	6.4	None
Rm. 137 - Girl's Locker Room Bathroom	Sink	Public Access	GT-018	GT-S117	5.7	None
Rm. 139 - Hallway/Corridor	Fountain	Public Access	GT-105	GT-F202	< 1.0	None
Rm. 139 - Hallway/Corridor	Fountain	Public Access	GT-106	GT-F203	< 1.0	None
Rm. 140 - Boy's Locker Room Bathroom	Sink	Public Access	GT-019	GT-S118	8.6	None
Rm. 140B - Swimming Pool Office	Sink	Secured - SCSD Staff Only	GT-020	GT-S119	5.6	None
Rm. 151 - Hallway/Vestibule	Fountain	Public Access	GT-057	GT-F100	< 1.0	None
Rm. 151 - Hallway/Vestibule	Sink	Public Access	GT-001	GT-S100	21.0	SCSD removed fixture from service and is to replace
Rm. 151 - Hallway/Vestibule	Sink	Public Access	GT-002	GT-S101	2.3	None
Rm. 162 - Hallway/Vestibule	Sink	Public Access	GT-092	GT-S227	1.1	None
Rm. 162 - Hallway/Vestibule	Sink	Public Access	GT-093	GT-S228	3.4	None
Rm. 169 - Work Room	Sink	Secured - SCSD Staff Only	GT-089	GT-S224	3.8	None
Rm. 170 - Audio/Video Storage	Sink	Secured - SCSD Staff Only	GT-090	GT-S225	16.0	SCSD removed fixture from service and is to replace
Rm. 175 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	GT-070	GT-S205	3.6	None
Rm. 177A - Computer Lab Bathroom	Sink	Public Access	GT-096	GT-S231	7.3	None
Rm. 177B - Computer Lab Bathroom	Sink	Public Access	GT-097	GT-S232	15.0	SCSD removed fixture from service and is to replace
Rm. 182 - Classroom	Sink	Public Access	GT-004	GT-S103	< 1.0	None
Rm. 182A - Nurse's Waiting Room	Sink	Public Access	GT-007	GT-S106	< 1.0	None
Rm. 182B - Classroom Office	Sink	Public Access	GT-005	GT-S104	5.5	None
Rm. 182D - Examination Room	Sink	Public Access	GT-009	GT-S108	5.8	None
Rm. 182E - Nurse's Office Bathroom	Sink	Public Access	GT-008	GT-S107	< 1.0	None
Rm. 182G - Sick/Rest Waiting Room	Sink	Public Access	GT-006	GT-S105	< 1.0	None
Rm. 183 - Girl's Bathroom	Sink	Public Access	GT-079	GT-S214	3.7	None
Rm. 183 - Girl's Bathroom	Sink	Public Access	GT-080	GT-S215	3.2	None
Rm. 184 - Swimming Pool	Fountain	Public Access	GT-058	GT-F101	3.7	None

**SYRACUSE CITY SCHOOL DISTRICT**  
**GRANT MIDDLE SCHOOL**

SAMPLE DATE: 10/27/2016 ANALYSIS DATES: 12/23/2016, 12/26/2016, 12/28/2016 and 01/05/2017

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 185C - Office	Sink	Secured - SCSD Staff Only	GT-003	GT-S102	3.3	None
Rm. 189 - Boy's Bathroom	Sink	Public Access	GT-094	GT-S229	1.4	None
Rm. 189 - Boy's Bathroom	Sink	Public Access	GT-095	GT-S230	1.1	None
Rm. 203 - Classroom	Sink	Public Access	GT-025	GT-S124	1.7	None
Rm. 204 - Classroom Bathroom	Sink	Public Access	GT-024	GT-S123	3.4	None
Rm. 207 - Girl's Bathroom	Sink	Public Access	GT-033	GT-S132	6.1	None
Rm. 208 - Hallway/Corridor	Fountain	Public Access	GT-061	GT-F104	< 1.0	None
Rm. 211 - Girl's Locker Room	Sink	Public Access	GT-031	GT-S130	8.4	None
Rm. 211 - Girl's Locker Room	Sink	Public Access	GT-032	GT-S131	5.5	None
Rm. 212 - Girl's Coach Office	Sink	Secured - SCSD Staff Only	GT-030	GT-S129	5.0	None
Rm. 214 - Boy's Bathroom	Sink	Public Access	GT-034	GT-S133	26.0	SCSD removed fixture from service and is to replace
Rm. 218 - Hallway/Vestibule	Sink	Public Access	GT-047	GT-S146	7.7	None
Rm. 218 - Hallway/Vestibule	Sink	Public Access	GT-048	GT-S147	5.4	None
Rm. 227 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	GT-043	GT-S142	2.0	None
Rm. 227B - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	GT-041	GT-S140	13.0	None
Rm. 228A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	GT-042	GT-S141	8.9	None
Rm. 234A - Art Storage Room	Sink	Public Access	GT-046	GT-S145	12.0	None
Rm. 238A - Classroom Bathroom	Sink	Public Access	GT-037	GT-S136	5.4	None
Rm. 242A - Work Room	Sink	Secured - SCSD Staff Only	GT-049	GT-S148	10.0	None
Rm. 242A - Work Room	Sink	Secured - SCSD Staff Only	GT-050	GT-S149	24.0	SCSD to post warning sign
Rm. 250 - Boy's Bathroom	Sink	Public Access	GT-044	GT-S143	5.9	None
Rm. 250 - Boy's Bathroom	Sink	Public Access	GT-045	GT-S144	8.0	None
Rm. 255 - Hallway/Corridor	Fountain	Public Access	GT-062	GT-F105	< 1.0	None
Rm. 255 - Hallway/Corridor	Fountain	Public Access	GT-063	GT-F106	< 1.0	None
Rm. 260 - Girl's Bathroom	Sink	Public Access	GT-038	GT-S137	5.2	None
Rm. 260 - Girl's Bathroom	Sink	Public Access	GT-039	GT-S138	4.5	None
Rm. 260 - Girl's Bathroom	Sink	Public Access	GT-040	GT-S139	5.7	None
Rm. 262 - Hallway/Vestibule	Sink	Public Access	GT-035	GT-S134	4.8	None
Rm. 262 - Hallway/Vestibule	Sink	Public Access	GT-036	GT-S135	2.3	None

**SYRACUSE CITY SCHOOL DISTRICT**  
**GRANT MIDDLE SCHOOL**

SAMPLE DATE: 10/27/2016 ANALYSIS DATES: 12/23/2016, 12/26/2016, 12/28/2016 and 01/05/2017

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 270 - Hallway/Vestibule	Fountain	Public Access	GT-059	GT-F102	< 1.0	None
Rm. 272 - Boy's Coach Bathroom	Sink	Secured - SCSD Staff Only	GT-028	GT-S127	8.3	None
Rm. 273 - Boy's Locker Room Bathroom	Sink	Public Access	GT-029	GT-S128	2.7	None
Rm. 275 - Boy's Locker Room	Fountain	Public Access	GT-060	GT-F103	1.8	None
Rm. 294 - Home & Careers Room	Sink	Public Access	GT-026	GT-S125	2.3	None
Rm. 294 - Home & Careers Room	Sink	Public Access	GT-027	GT-S126	3.8	None
Rm. 296 - Home & Careers Room	Sink	Public Access	GT-021	GT-S120	11.0	None
Rm. 296 - Home & Careers Room	Sink	Public Access	GT-022	GT-S121	2.2	None
Rm. 296 - Home & Careers Room	Sink	Public Access	GT-023	GT-S122	< 1.0	None
Rm. 308 - Hallway/Corridor	Fountain	Public Access	GT-064	GT-F107	< 1.0	None
Rm. 308 - Hallway/Corridor	Fountain	Public Access	GT-110	GT-F209	< 1.0	None
Rm. 308 - Hallway/Corridor	Fountain	Public Access	GT-111	GT-F210	< 1.0	None
Rm. 315 - Hallway/Vestibule	Sink	Public Access	GT-051	GT-S150	4.7	None
Rm. 315 - Hallway/Vestibule	Sink	Public Access	GT-052	GT-S151	1.9	None
Rm. 315 - Hallway/Vestibule	Sink	Public Access	GT-098	GT-S233	2.0	None
Rm. 315 - Hallway/Vestibule	Sink	Public Access	GT-099	GT-S234	3.2	None
Rm. 317 - Work Room	Sink	Secured - SCSD Staff Only	GT-102	GT-S237	5.3	None
Rm. 317 - Work Room	Sink	Secured - SCSD Staff Only	GT-103	GT-S238	14.0	None
Rm. 319 - Art Storage Room	Sink	Public Access	GT-056	GT-S155	1200.0	SCSD permanently removed fixture from service
Rm. 326 - Hallway/Corridor	Fountain	Public Access	GT-108	GT-F207	1.2	None
Rm. 326 - Hallway/Corridor	Fountain	Public Access	GT-109	GT-F208	< 1.0	None
Rm. 344 - Girl's Bathroom	Sink	Public Access	GT-053	GT-S152	7.7	None
Rm. 344 - Girl's Bathroom	Sink	Public Access	GT-054	GT-S153	2.6	None
Rm. 344 - Girl's Bathroom	Sink	Public Access	GT-055	GT-S154	7.8	None
Rm. 375 - Boy's Bathroom	Sink	Public Access	GT-100	GT-S235	3.7	None
Rm. 375 - Boy's Bathroom	Sink	Public Access	GT-101	GT-S236	7.2	None

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-043
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1621052
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.