

SYRACUSE CITY SCHOOL DISTRICT
INSTITUTE OF TECHNOLOGY AT SYRACUSE CENTRAL

SAMPLE DATE: 10/16/2016 ANALYSIS DATES: 12/23/2016, 12/28/2016 and 01/04/2017

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 005 - Mechanical/Meter Room	Hose Bib at Meter Assembly	Secured - SCSD Staff Only	IT-001	IT-M100	24.0	SCSD to post warning sign
Rm. 007 - Storage Room	Sink	Secured - SCSD Staff Only	IT-002	IT-S100	3.3	None
Rm. 100 - Hallway/Corridor	Fountain	Public Access	IT-063	IT-F106	< 1.0	None
Rm. 100 - Hallway/Corridor	Fountain	Public Access	IT-064	IT-F107	< 1.0	None
Rm. 102 - Concessions Room	Sink	Secured - SCSD Staff Only	IT-041	IT-S139	1.1	None
Rm. 102 - Concessions Room	Sink	Secured - SCSD Staff Only	IT-042	IT-S140	3.2	None
Rm. 103 - Patient Room	Sink	Public Access	IT-040	IT-S138	< 1.0	None
Rm. 110 - Boy's Gym Office Bathroom	Sink	Secured - SCSD Staff Only	IT-050	IT-S148	< 1.0	None
Rm. 111 - Boy's Locker Room Bathroom	Sink	Public Access	IT-047	IT-S145	< 1.0	None
Rm. 111 - Boy's Locker Room Bathroom	Sink	Public Access	IT-048	IT-S146	< 1.0	None
Rm. 111 - Boy's Locker Room Bathroom	Sink	Public Access	IT-049	IT-S147	< 1.0	None
Rm. 113 - Girl's Locker Room Bathroom	Sink	Public Access	IT-043	IT-S141	< 1.0	None
Rm. 113 - Girl's Locker Room Bathroom	Sink	Public Access	IT-044	IT-S142	< 1.0	None
Rm. 113 - Girl's Locker Room Bathroom	Sink	Public Access	IT-045	IT-S143	1.1	None
Rm. 115 - Girl's Gym Office Bathroom	Sink	Secured - SCSD Staff Only	IT-046	IT-S144	1.6	None
Rm. 116 - Hallway/Corridor	Fountain	Public Access	IT-065	IT-F108	< 1.0	None
Rm. 117 - Boy's Bathroom	Sink	Public Access	IT-051	IT-S149	< 1.0	None
Rm. 117 - Boy's Bathroom	Sink	Public Access	IT-052	IT-S150	< 1.0	None
Rm. 117 - Boy's Bathroom	Sink	Public Access	IT-053	IT-S151	< 1.0	None
Rm. 118 - Girl's Bathroom	Sink	Public Access	IT-054	IT-S152	< 1.0	None
Rm. 118 - Girl's Bathroom	Sink	Public Access	IT-055	IT-S153	< 1.0	None
Rm. 118 - Girl's Bathroom	Sink	Public Access	IT-056	IT-S154	< 1.0	None
Rm. 133 - Nurse's Office	Sink	Public Access	IT-008	IT-S106	< 1.0	None
Rm. 134 - Nurse's Office Bathroom	Sink	Public Access	IT-007	IT-S105	< 1.0	None
Rm. 135 - Exam Room	Sink	Public Access	IT-006	IT-S104	< 1.0	None
Rm. 138 - Library Bathroom	Sink	Public Access	IT-036	IT-S134	< 1.0	None
Rm. 138 - Library	Sink	Public Access	IT-037	IT-S135	1.3	None
Rm. 140 - Hallway/Corridor	Fountain	Public Access	IT-057	IT-F100	< 1.0	None
Rm. 147 - Main Office	Sink	Secured - SCSD Staff Only	IT-039	IT-S137	< 1.0	None

SYRACUSE CITY SCHOOL DISTRICT
INSTITUTE OF TECHNOLOGY AT SYRACUSE CENTRAL

SAMPLE DATE: 10/16/2016 ANALYSIS DATES: 12/23/2016, 12/28/2016 and 01/04/2017

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 148 - Main Office Bathroom	Sink	Secured - SCSD Staff Only	IT-038	IT-S136	< 1.0	None
Rm. 157 - Tech Lab Bathroom	Sink	Public Access	IT-033	IT-S131	2.0	None
Rm. 157 - Tech Lab	Fountain	Public Access	IT-062	IT-F105	2.8	None
Rm. 157 - Tech Lab	Sink	Public Access	IT-034	IT-S132	1.6	None
Rm. 157 - Tech Lab	Sink	Public Access	IT-035	IT-S133	8.9	None
Rm. 163 - Lockers Bathroom	Sink	Public Access	IT-032	IT-S130	2.4	None
Rm. 165 - Tech Lab	Fountain	Public Access	IT-061	IT-F104	< 1.0	None
Rm. 172 - Hallway/Corridor	Fountain	Public Access	IT-060	IT-F103	< 1.0	None
Rm. 174 - Teaching Kitchen	Sink	Public Access	IT-023	IT-S121	4.5	None
Rm. 174 - Teaching Kitchen	Sink	Public Access	IT-024	IT-S122	1.1	None
Rm. 174 - Teaching Kitchen	Sink	Public Access	IT-025	IT-S123	3.4	None
Rm. 174 - Teaching Kitchen	Sink	Public Access	IT-026	IT-S124	4.6	None
Rm. 174 - Teaching Kitchen	Sink	Public Access	IT-027	IT-S125	7.6	None
Rm. 174 - Teaching Kitchen	Sink	Public Access	IT-028	IT-S126	2.6	None
Rm. 174 - Teaching Kitchen	Sink	Public Access	IT-029	IT-S127	1.4	None
Rm. 174 - Teaching Kitchen	Sink	Public Access	IT-030	IT-S128	210.0	SCSD to post warning sign
Rm. 174 - Teaching Kitchen	Sink	Public Access	IT-031	IT-S129	1.4	None
Rm. 177 - Home & Careers Room	Sink	Public Access	IT-020	IT-S118	3.5	None
Rm. 177 - Home & Careers Room	Sink	Public Access	IT-021	IT-S119	1.7	None
Rm. 179 - Unisex Bathroom	Sink	Public Access	IT-022	IT-S120	1.8	None
Rm. 183 - Boy's Bathroom	Sink	Public Access	IT-018	IT-S116	1.3	None
Rm. 183 - Boy's Bathroom	Sink	Public Access	IT-019	IT-S117	1.3	None
Rm. 184 - Girl's Bathroom	Sink	Public Access	IT-016	IT-S114	5.6	None
Rm. 184 - Girl's Bathroom	Sink	Public Access	IT-017	IT-S115	1.8	None
Rm. 190 - Cafeteria	Fountain	Public Access	IT-058	IT-F101	< 1.0	None
Rm. 190 - Cafeteria	Fountain	Public Access	IT-059	IT-F102	< 1.0	None
Rm. 192 - Warming Kitchen	Sink	Secured - SCSD Staff Only	IT-009	IT-S107	1.0	None
Rm. 192 - Warming Kitchen	Sink	Secured - SCSD Staff Only	IT-010	IT-S108	1.0	None
Rm. 192 - Warming Kitchen	Sink	Secured - SCSD Staff Only	IT-011	IT-S109	1.8	None

SYRACUSE CITY SCHOOL DISTRICT
INSTITUTE OF TECHNOLOGY AT SYRACUSE CENTRAL

SAMPLE DATE: 10/16/2016 ANALYSIS DATES: 12/23/2016, 12/28/2016 and 01/04/2017

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 192 - Warming Kitchen	Sink	Secured - SCSD Staff Only	IT-012	IT-S110	1.8	None
Rm. 192 - Warming Kitchen	Sink	Secured - SCSD Staff Only	IT-013	IT-S111	2.5	None
Rm. 192 - Warming Kitchen	Sink	Secured - SCSD Staff Only	IT-014	IT-S112	3.1	None
Rm. 192 - Warming Kitchen	Steamer	Secured - SCSD Staff Only	IT-015	IT-S113	39.0	SCSD to post warning sign
Rm. 193 - Staff Bathroom	Sink	Secured - SCSD Staff Only	IT-004	IT-S102	< 1.0	None
Rm. 194 - Staff Bathroom	Sink	Secured - SCSD Staff Only	IT-003	IT-S101	< 1.0	None
Rm. 195 - Receiving/Maintenance Bathroom	Sink	Secured - SCSD Staff Only	IT-005	IT-S103	< 1.0	None
Rm. 202 - Girl's Bathroom	Sink	Public Access	IT-078	IT-S512	< 1.0	None
Rm. 202 - Girl's Bathroom	Sink	Public Access	IT-079	IT-S513	< 1.0	None
Rm. 202 - Girl's Bathroom	Sink	Public Access	IT-080	IT-S514	< 1.0	None
Rm. 202 - Girl's Bathroom	Sink	Public Access	IT-081	IT-S515	< 1.0	None
Rm. 212 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	IT-076	IT-S510	< 1.0	None
Rm. 213 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	IT-075	IT-S509	1.5	None
Rm. 2XX - Staff Bathroom	Sink	Secured - SCSD Staff Only	IT-069	IT-S503	2.9	None
Rm. 220 - Staff Kitchenette	Sink	Secured - SCSD Staff Only	IT-068	IT-S502	< 1.0	None
Rm. 224 - Boy's Bathroom	Sink	Public Access	IT-070	IT-S504	< 1.0	None
Rm. 224 - Boy's Bathroom	Sink	Public Access	IT-071	IT-S505	< 1.0	None
Rm. 224 - Boy's Bathroom	Sink	Public Access	IT-072	IT-S506	< 1.0	None
Rm. 224 - Boy's Bathroom	Sink	Public Access	IT-073	IT-S507	< 1.0	None
Rm. 228 - Director's Office Bathroom	Sink	Secured - SCSD Staff Only	IT-067	IT-S501	3.9	None
Rm. 242 - Biology Room	Sink	Public Access	IT-088	IT-S522	4.6	None
Rm. 242 - Biology Room	Sink	Public Access	IT-089	IT-S523	5.1	None
Rm. 242 - Biology Room	Sink	Public Access	IT-090	IT-S524	13.0	None
Rm. 244 - Music Room	Sink	Public Access	IT-066	IT-S500	< 1.0	None
Rm. 254 - Teacher's Work Room	Sink	Secured - SCSD Staff Only	IT-074	IT-S508	< 1.0	None
Rm. 255 - OT/PT Room	Sink	Secured - SCSD Staff Only	IT-077	IT-S511	< 1.0	None
Rm. 261 - Classroom	Sink	Public Access	IT-086	IT-S520	4.7	None
Rm. 261 - Classroom	Sink	Public Access	IT-087	IT-S521	4.9	None
Rm. 263 - Classroom	Sink	Public Access	IT-084	IT-S518	2.9	None

SYRACUSE CITY SCHOOL DISTRICT
INSTITUTE OF TECHNOLOGY AT SYRACUSE CENTRAL

SAMPLE DATE: 10/16/2016 ANALYSIS DATES: 12/23/2016, 12/28/2016 and 01/04/2017

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 263 - Classroom	Sink	Public Access	IT-085	IT-S519	2.0	None
Rm. 265 - Hallway/Corridor	Fountain	Public Access	--	IT-F500	--	Fixture not operating
Rm. 266 - Storage Room	Sink	Secured - SCSD Staff Only	IT-083	IT-S517	6.4	None
Rm. 266 - Storage Room	Sink	Secured - SCSD Staff Only	IT-091	IT-S525	31.0	SCSD to post warning sign
Rm. 267 - H & BS Team Room	Sink	Public Access	IT-082	IT-S516	1.9	None

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-006
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No.
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.