

**SYRACUSE CITY SCHOOL DISTRICT
PSLA and FOWLER HIGH SCHOOL**

SAMPLE DATE: 10/16/2016 ANALYSIS DATE: 12/16/2016, 12/17/2016, 12/26/2016, 12/28/2016 and 12/29/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
BUILDING SECTION 'A'						
Rm. 108 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	FR-046	FR-S145	< 1.0	None
Rm. 109 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	FR-047	FR-S146	1.4	None
Rm. 111 - Cosmetology Room	Sink	Public Access	FR-049	FR-S148	< 1.0	None
Rm. 113 - Faculty Lounge	Sink	Secured - SCSD Staff Only	FR-045	FR-S144	2.1	None
Rm. 117 - Safety Classroom	Sink	Public Access	FR-048	FR-S147	6.5	None
Rm. 119 - Home & Careers Room	Sink	Public Access	FR-041	FR-S140	3.6	None
Rm. 119 - Home & Careers Room	Sink	Public Access	FR-042	FR-S141	4.6	None
Rm. 119 - Home & Careers Room	Sink	Public Access	FR-043	FR-S142	4.6	None
Rm. 119 - Home & Careers Room	Sink	Public Access	FR-044	FR-S143	3.0	None
Rm. 121 - Hallway/Corridor	Fountain	Public Access	FR-069	FR-F102	< 1.0	None
Rm. 121 - Hallway/Corridor	Fountain	Public Access	FR-070	FR-F103	< 1.0	None
Rm. 124 - Boy's Bathroom	Sink	Public Access	FR-035	FR-S134	< 1.0	None
Rm. 124 - Boy's Bathroom	Sink	Public Access	FR-036	FR-S135	< 1.0	None
Rm. 124 - Boy's Bathroom	Sink	Public Access	FR-037	FR-S136	< 1.0	None
Rm. 125 - Girl's Bathroom	Sink	Public Access	FR-038	FR-S137	< 1.0	None
Rm. 125 - Girl's Bathroom	Sink	Public Access	FR-039	FR-S138	< 1.0	None
Rm. 125 - Girl's Bathroom	Sink	Public Access	FR-040	FR-S139	< 1.0	None
Rm. 128 - Serving Room	Sink	Secured - SCSD Staff Only	FR-014	FR-S112	2.1	None
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	FR-015	FR-S113	10.0	None
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	FR-016	FR-S114	11.0	None
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	FR-017	FR-S115	1.6	None
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	FR-018	FR-S116	< 1.0	None
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	FR-019	FR-S117	2.2	None
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	FR-020	FR-S118	1.3	None
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	FR-021	FR-S119	< 1.0	None
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	FR-022	FR-S120	3.7	None
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	FR-023	FR-S121	< 1.0	None
Rm. 128C - Kitchen	Kettle	Secured - SCSD Staff Only	FR-024	FR-S122	6.3	None

SYRACUSE CITY SCHOOL DISTRICT
PSLA and FOWLER HIGH SCHOOL

SAMPLE DATE: 10/16/2016 ANALYSIS DATE: 12/16/2016, 12/17/2016, 12/26/2016, 12/28/2016 and 12/29/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
BUILDING SECTION 'A', cont.						
Rm. 128C - Kitchen	Sink	Secured - SCSD Staff Only	FR-025	FR-S123	< 1.0	None
Rm. 128C - Kitchen	Wash Hose	Secured - SCSD Staff Only	FR-026	FR-S124	4.6	None
Rm. 128C - Kitchen	Wash Hose	Secured - SCSD Staff Only	--	FR-S125	--	Fixture not operating
Rm. 128C - Kitchen	Steamer	Secured - SCSD Staff Only	FR-027	FR-S126	3.8	None
Rm. 128C - Kitchen	Steamer	Secured - SCSD Staff Only	FR-028	FR-S127	18.0	SCSD to post warning sign
Rm. 128C - Kitchen	Steamer	Secured - SCSD Staff Only	FR-029	FR-S128	7.2	None
Rm. 128C - Kitchen	Steamer	Secured - SCSD Staff Only	FR-030	FR-S129	2.5	None
Rm. 128C - Kitchen	Hose Spray Stand	Secured - SCSD Staff Only	FR-031	FR-S130	< 1.0	None
Rm. 128C - Kitchen	Hose Spray Stand	Secured - SCSD Staff Only	FR-032	FR-S131	< 1.0	None
Rm. 128D - Kitchen/Corridor	Ice Machine	Secured - SCSD Staff Only	FR-033	FR-S132	< 1.0	None
Rm. 128E - Storage Room	Sink	Secured - SCSD Staff Only	FR-034	FR-S133	4.8	None
Rm. 129 - Hallway/Corridor	Fountain	Public Access	FR-068	FR-F101	< 1.0	None
Rm. 131C - Storage Room Bathroom	Sink	Secured - SCSD Staff Only	FR-004	FR-S102	< 1.0	None
Rm. 131G - Nurse's Office Bathroom	Sink	Public Access	FR-008	FR-S106	< 1.0	None
Rm. 131H - Exam Room Bathroom	Sink	Public Access	FR-007	FR-S105	< 1.0	None
Rm. 131I - Exam Room	Sink	Public Access	FR-006	FR-S104	1.4	None
Rm. 131J - Nurse's Office	Sink	Public Access	FR-005	FR-S103	1.9	None
Rm. 131R - Practical Treatment Room	Sink	Secured - SCSD Staff Only	FR-013	FR-S111	< 1.0	None
Rm. 131U - Practical Treatment Room	Sink	Secured - SCSD Staff Only	FR-012	FR-S110	< 1.0	None
Rm. 131V - Soiled Meds Room	Sink	Secured - SCSD Staff Only	FR-009	FR-S107	< 1.0	None
Rm. 131W - Meds Room Bathroom	Sink	Secured - SCSD Staff Only	FR-010	FR-S108	< 1.0	None
Rm. 131Y - Dental Office	Sink	Public Access	FR-011	FR-S109	1.4	None
Rm. 137B - Boy's Locker Room Bathroom	Sink	Public Access	FR-002	FR-S100	2.2	None
Rm. 137B - Boy's Locker Room Bathroom	Sink	Public Access	FR-003	FR-S101	3.4	None
Rm. 137B - Boy's Locker Room Bathroom	Fountain	Public Access	FR-067	FR-F100	< 1.0	None
Rm. 141 - Meter Room	Hose Bib at Meter Assembly	Secured - SCSD Staff Only	FR-001	FR-M100	1000.0	SCSD to post warning sign
Rm. 141 - Meter Room	Sink	Public Access	FR-066	FR-S165	< 1.0	None
Rm. 210A - Hallway/Corridor	Fountain	Public Access	FR-095	FR-F518	< 1.0	None

SYRACUSE CITY SCHOOL DISTRICT
PSLA and FOWLER HIGH SCHOOL

SAMPLE DATE: 10/16/2016 ANALYSIS DATE: 12/16/2016, 12/17/2016, 12/26/2016, 12/28/2016 and 12/29/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
BUILDING SECTION 'A', cont.						
Rm. 210A - Hallway/Corridor	Fountain	Public Access	FR-105	FR-F528	< 1.0	None
Rm. 215 - Special Edu. Room	Sink	Public Access	FR-118	FR-S541	< 1.0	None
Rm. 216 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	FR-113	FR-S536	< 1.0	None
Rm. 217 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	FR-114	FR-S537	1.1	None
Rm. 224 - Girl's Bathroom	Sink	Public Access	FR-106	FR-S529	< 1.0	None
Rm. 224 - Girl's Bathroom	Sink	Public Access	FR-107	FR-S530	< 1.0	None
Rm. 224 - Girl's Bathroom	Sink	Public Access	FR-108	FR-S531	< 1.0	None
Rm. 225 - Boy's Bathroom	Sink	Public Access	FR-109	FR-S532	< 1.0	None
Rm. 225 - Boy's Bathroom	Sink	Public Access	FR-110	FR-S533	< 1.0	None
Rm. 225 - Boy's Bathroom	Sink	Public Access	FR-111	FR-S534	< 1.0	None
Rm. 231 - Concession Room	Sink	Secured - SCSD Staff Only	FR-104	FR-S527	< 1.0	None
Rm. 245 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	FR-103	FR-S526	1.1	None
Rm. 246 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	FR-102	FR-S525	< 1.0	None
Rm. 257 - Boy's Bathroom	Sink	Public Access	FR-096	FR-S519	< 1.0	None
Rm. 257 - Boy's Bathroom	Sink	Public Access	FR-097	FR-S520	< 1.0	None
Rm. 257 - Boy's Bathroom	Sink	Public Access	FR-098	FR-S521	< 1.0	None
Rm. 257/285 - Hallway/Corridor	Fountain	Public Access	FR-093	FR-F516	< 1.0	None
Rm. 257/285 - Hallway/Corridor	Fountain	Public Access	FR-094	FR-F517	< 1.0	None
Rm. 258 - Girl's Bathroom	Sink	Public Access	FR-099	FR-S522	< 1.0	None
Rm. 258 - Girl's Bathroom	Sink	Public Access	FR-100	FR-S523	< 1.0	None
Rm. 258 - Girl's Bathroom	Sink	Public Access	FR-101	FR-S524	< 1.0	None
Rm. 273 - Girl's Locker Room	Fountain	Public Access	FR-078	FR-F501	3.0	None
Rm. 273B - Girl's Locker Room Bathroom	Sink	Public Access	FR-081	FR-S504	15.0	SCSD to post warning sign
Rm. 273B - Girl's Locker Room Bathroom	Sink	Public Access	FR-082	FR-S505	4.5	None
Rm. 274B - Boy's Locker Room Bathroom	Sink	Public Access	FR-079	FR-S502	50.0	SCSD to post warning sign
Rm. 274B - Boy's Locker Room Bathroom	Sink	Public Access	FR-080	FR-S503	11.0	None
Rm. 278 - Hallway/Corridor	Fountain	Public Access	FR-077	FR-F500	< 1.0	None
Rm. 280 Boy's Locker Room	Fountain	Public Access	FR-083	FR-F506	< 1.0	None

**SYRACUSE CITY SCHOOL DISTRICT
PSLA and FOWLER HIGH SCHOOL**

SAMPLE DATE: 10/16/2016 ANALYSIS DATE: 12/16/2016, 12/17/2016, 12/26/2016, 12/28/2016 and 12/29/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
BUILDING SECTION 'A', cont.						
Rm. 280 Boy's Locker Room	Fountain	Public Access	FR-084	FR-F507	< 1.0	None
Rm. 280A - Boy's Locker Room Bathroom	Sink	Public Access	FR-085	FR-S508	< 1.0	None
Rm. 280A - Boy's Locker Room Bathroom	Sink	Public Access	FR-086	FR-S509	< 1.0	None
Rm. 280D - Boy's PE Office Bathroom	Sink	Secured - SCSD Staff Only	FR-087	FR-S510	3.1	None
Rm. 281 - Girl's Locker Room	Fountain	Public Access	FR-088	FR-F511	< 1.0	None
Rm. 281 - Girl's Locker Room	Fountain	Public Access	FR-089	FR-F512	< 1.0	None
Rm. 281A - Girl's Locker Room Bathroom	Sink	Public Access	FR-090	FR-S513	< 1.0	None
Rm. 281A - Girl's Locker Room Bathroom	Sink	Public Access	FR-091	FR-S514	< 1.0	None
Rm. 281D - Girl's PE Bathroom	Sink	Secured - SCSD Staff Only	FR-092	FR-S515	< 1.0	None
Rm. 292E - Staff's Bathroom	Sink	Secured - SCSD Staff Only	FR-112	FR-S535	1.2	None
Rm. 333 - Hallway/Corridor	Fountain	Public Access	FR-073	FR-F106	< 1.0	None
Rm. 333 - Hallway/Corridor	Fountain	Public Access	FR-074	FR-F107	< 1.0	None
Rm. 334 - Boy's Bathroom	Sink	Public Access	FR-055	FR-S154	< 1.0	None
Rm. 334 - Boy's Bathroom	Sink	Public Access	FR-056	FR-S155	< 1.0	None
Rm. 334 - Boy's Bathroom	Sink	Public Access	FR-057	FR-S156	< 1.0	None
Rm. 336 - Girl's Bathroom	Sink	Public Access	FR-052	FR-S151	< 1.0	None
Rm. 336 - Girl's Bathroom	Sink	Public Access	FR-053	FR-S152	< 1.0	None
Rm. 336 - Girl's Bathroom	Sink	Public Access	FR-054	FR-S153	< 1.0	None
Rm. 352 - Boy's Bathroom	Sink	Public Access	FR-058	FR-S157	< 1.0	None
Rm. 352 - Boy's Bathroom	Sink	Public Access	FR-059	FR-S158	< 1.0	None
Rm. 352 - Boy's Bathroom	Sink	Public Access	FR-060	FR-S159	< 1.0	None
Rm. 352 - Hallway/Corridor	Fountain	Public Access	FR-075	FR-F108	< 1.0	None
Rm. 352 - Hallway/Corridor	Fountain	Public Access	FR-076	FR-F109	< 1.0	None
Rm. 354 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	FR-061	FR-S160	1.2	None
Rm. 355 - Girl's Bathroom	Sink	Public Access	FR-062	FR-S161	1.1	None
Rm. 355 - Girl's Bathroom	Sink	Public Access	FR-063	FR-S162	< 1.0	None
Rm. 355 - Girl's Bathroom	Sink	Public Access	FR-064	FR-S163	< 1.0	None
Rm. 364 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	FR-065	FR-S164	< 1.0	None

SYRACUSE CITY SCHOOL DISTRICT
PSLA and FOWLER HIGH SCHOOL

SAMPLE DATE: 10/16/2016 ANALYSIS DATE: 12/16/2016, 12/17/2016, 12/26/2016, 12/28/2016 and 12/29/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
BUILDING SECTION 'B'						
Rm. 316 - Hallway/Corridor	Fountain	Public Access	FR-071	FR-F104	< 1.0	None
Rm. 316 - Hallway/Corridor	Fountain	Public Access	FR-072	FR-F105	< 1.0	None
Rm. 313 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	FR-050	FR-S149	1.4	None
Rm. 314 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	FR-051	FR-S150	1.1	None
Rm. 298 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	FR-115	FR-S538	1.1	None
Rm. 297 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	FR-116	FR-S539	1.1	None
Rm. 201A - Work Room	Sink	Secured - SCSD Staff Only	FR-117	FR-S540	< 1.0	None

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-036
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620584
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.