

**SYRACUSE CITY SCHOOL DISTRICT**  
**LEVY K-8 SCHOOL**

SAMPLE DATE: 10/27/2016 ANALYSIS DATES: 12/27/2016 and 12/29/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. B05 - Boiler/Meter Room	Hose Bib at Meter Assembly	Secured - SCSD Staff Only	LY-031	LY-M200	2.4	None
Rm. 108 - Classroom	Sink	Public Access	LY-049	LY-S218	7.4	None
Rm. 109A - Classroom	Sink	Public Access	LY-048	LY-S217	7.4	None
Rm. 111A - Hallway/Corridor	Fountain	Public Access	LY-067	LY-F205	6.0	None
Rm. 114 - Girl's Bathroom	Sink	Public Access	LY-045	LY-S214	7.6	None
Rm. 114 - Girl's Bathroom	Sink	Public Access	LY-046	LY-S215	2.8	None
Rm. 114 - Girl's Bathroom	Sink	Public Access	LY-047	LY-S216	7.5	None
Rm. 117 - Boy's Bathroom	Sink	Public Access	LY-042	LY-S211	6.3	None
Rm. 117 - Boy's Bathroom	Sink	Public Access	LY-043	LY-S212	2.8	None
Rm. 117 - Boy's Bathroom	Sink	Public Access	LY-044	LY-S213	4.2	None
Rm. 119 - Hallway/Corridor	Fountain	Public Access	LY-066	LY-F204	3.3	None
Rm. 120 - Hallway/Corridor	Fountain	Public Access	LY-064	LY-F202	1.2	None
Rm. 121A - Classroom	Fountain	Public Access	LY-065	LY-F203	< 1.0	None
Rm. 121A - Classroom	Sink	Public Access	LY-039	LY-S208	8.3	None
Rm. 125A - Staff Bathroom	Sink	Secured - SCSD Staff Only	LY-035	LY-S204	5.3	None
Rm. 125D - Work Room	Sink	Secured - SCSD Staff Only	LY-034	LY-S203	10.0	None
Rm. 126 - Guidance Office	Sink	Public Access	LY-033	LY-S202	3.8	None
Rm. 129C-1 - Work Room	Sink	Secured - SCSD Staff Only	LY-038	LY-S207	6.8	None
Rm. 129E - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	LY-037	LY-S206	7.3	None
Rm. 129F - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	LY-036	LY-S205	2.0	None
Rm. 132A - Clinic Office	Sink	Public Access	LY-040	LY-S209	1.1	None
Rm. 132B - Clinic Bathroom	Sink	Public Access	LY-041	LY-S210	49.0	Building vacant, SCSD to re-sample prior to re-occupancy
Rm. 134 - Girl's Bathroom	Sink	Public Access	LY-032	LY-S201	16.0	Building vacant, SCSD to re-sample prior to re-occupancy
Rm. 135A - Hallway/Corridor	Fountain	Public Access	-	LY-F201	-	Fixture not operating
Rm. 136 - Boy's Bathroom	Sink	Public Access	LY-001	LY-S100	< 1.0	None
Rm. 141 - Girl's Locker Room	Sink	Public Access	LY-002	LY-S101	3.9	None
Rm. 141 - Girl's Locker Room	Sink	Public Access	LY-003	LY-S102	9.5	None
Rm. 141B - Girl's Coach Bathroom	Sink	Secured - SCSD Staff Only	LY-004	LY-S103	15.0	Building vacant, SCSD to re-sample prior to re-occupancy
Rm. 142 - Hallway/Corridor	Fountain	Public Access	LY-028	LY-F100	< 1.0	None

**SYRACUSE CITY SCHOOL DISTRICT**  
**LEVY K-8 SCHOOL**

SAMPLE DATE: 10/27/2016 ANALYSIS DATES: 12/27/2016 and 12/29/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 145 - Boy's Locker Room	Fountain	Public Access	LY-029	LY-F101	60.0	Building vacant, SCSD to re-sample prior to re-occupancy
Rm. 145 - Boy's Locker Room	Sink	Public Access	LY-007	LY-S106	25.0	Building vacant, SCSD to re-sample prior to re-occupancy
Rm. 145 - Boy's Locker Room	Sink	Public Access	LY-010	LY-S109	71.0	Building vacant, SCSD to re-sample prior to re-occupancy
Rm. 145A-1 - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	LY-005	LY-S104	20.0	Building vacant, SCSD to re-sample prior to re-occupancy
Rm. 145B-1 - Boy's Coach Bathroom	Sink	Secured - SCSD Staff Only	LY-006	LY-S105	4.4	None
Rm. 145D - Boy's Locker Room Bathroom	Sink	Public Access	LY-009	LY-S108	18.0	Building vacant, SCSD to re-sample prior to re-occupancy
Rm. 145F - Boy's Shower	Sink	Public Access	LY-008	LY-S107	6.8	None
Rm. 151 - Kitchen	Sink	Secured - SCSD Staff Only	LY-016	LY-S115	5.3	None
Rm. 151 - Kitchen	Sink	Secured - SCSD Staff Only	LY-017	LY-S116	4.0	None
Rm. 151 - Kitchen	Sink	Secured - SCSD Staff Only	LY-018	LY-S117	11.0	None
Rm. 151 - Kitchen	Sink	Secured - SCSD Staff Only	LY-019	LY-S118	13.0	None
Rm. 151 - Kitchen	Steamer	Secured - SCSD Staff Only	LY-021	LY-S120	1.4	None
Rm. 151B - Staff Lockers	Sink	Secured - SCSD Staff Only	LY-015	LY-S114	3.6	None
Rm. 152 - Receiving Room	Sink	Secured - SCSD Staff Only	LY-020	LY-S119	12.0	None
Rm. 154 - Cafeteria	Fountain	Public Access	--	LY-F102	--	Fixture not operating
Rm. 154C - Boy's Bathroom	Sink	Public Access	LY-013	LY-S112	12.0	None
Rm. 154C - Boy's Bathroom	Sink	Public Access	LY-014	LY-S113	2.2	None
Rm. 154D - Girl's Bathroom	Sink	Public Access	LY-011	LY-S110	3.4	None
Rm. 154D - Girl's Bathroom	Sink	Public Access	LY-012	LY-S111	1.8	None
Rm. 211A - Hallway/Corridor	Fountain	Public Access	LY-068	LY-F206	5.3	None
Rm. 213 - Girl's Bathroom	Sink	Public Access	LY-053	LY-S222	26.0	Building vacant, SCSD to re-sample prior to re-occupancy
Rm. 213 - Girl's Bathroom	Sink	Public Access	LY-054	LY-S223	46.0	Building vacant, SCSD to re-sample prior to re-occupancy
Rm. 213 - Girl's Bathroom	Sink	Public Access	LY-055	LY-S224	13.0	None
Rm. 215 - Boy's Bathroom	Sink	Public Access	LY-050	LY-S219	6.3	None
Rm. 215 - Boy's Bathroom	Sink	Public Access	LY-051	LY-S220	6.3	None
Rm. 215 - Boy's Bathroom	Sink	Public Access	LY-052	LY-S221	6.9	None
Rm. 221 - Classroom	Sink	Public Access	LY-023	LY-S122	13.0	None
Rm. 221 - Classroom	Sink (hot water only)	Public Access	LY-024	LY-S123	210.0	Building vacant, SCSD to re-sample prior to re-occupancy
Rm. 230 - Hallway/Corridor	Fountain	Public Access	LY-030	LY-F103	7.8	None

**SYRACUSE CITY SCHOOL DISTRICT**  
**LEVY K-8 SCHOOL**

SAMPLE DATE: 10/27/2016 ANALYSIS DATES: 12/27/2016 and 12/29/2016

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	RESULTS (ppb)	ACTIONS
Rm. 231 - Staff Bathroom	Sink	Secured - SCSD Staff Only	LY-022	LY-S121	3.0	None
Rm. 311 - Hallway/Corridor	Fountain	Public Access	LY-069	LY-F207	4.8	None
Rm. 311B - Hallway/Corridor	Fountain	Public Access	LY-070	LY-F208	1.8	None
Rm. 313 - Girl's Bathroom	Sink	Public Access	LY-061	LY-S230	23.0	Building vacant, SCSD to re-sample prior to re-occupancy
Rm. 313 - Girl's Bathroom	Sink	Public Access	LY-062	LY-S231	6.5	None
Rm. 313 - Girl's Bathroom	Sink	Public Access	LY-063	LY-S232	28.0	Building vacant, SCSD to re-sample prior to re-occupancy
Rm. 315A - Teacher's Resource Bathroom	Sink	Secured - SCSD Staff Only	LY-060	LY-S229	16.0	Building vacant, SCSD to re-sample prior to re-occupancy
Rm. 317 - Boy's Bathroom	Sink	Public Access	LY-056	LY-S225	140.0	Building vacant, SCSD to re-sample prior to re-occupancy
Rm. 317 - Boy's Bathroom	Sink	Public Access	LY-057	LY-S226	3.2	None
Rm. 317 - Boy's Bathroom	Sink	Public Access	LY-058	LY-S227	8.7	None
Rm. 319 - Art Room	Sink	Public Access	LY-059	LY-S228	5.8	None
Rm. 321 - Staff Bathroom	Sink	Secured - SCSD Staff Only	LY-027	LY-S126	5.4	None
Rm. 322 - Staff Bathroom	Sink	Secured - SCSD Staff Only	LY-026	LY-S125	25.0	Building vacant, SCSD to re-sample prior to re-occupancy
Rm. 323 - Teacher's Resource	Sink	Public Access	LY-025	LY-S124	16.0	Building vacant, SCSD to re-sample prior to re-occupancy

Notes:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-041
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620931
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.