

**SYRACUSE CITY SCHOOL DISTRICT
FRANKLIN ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/17/2016 SAMPLE RESULTS (ppb)	09/17/2016 ORIGINAL ACTIONS	03/14/2017 RESAMPLE RESULTS (ppb)	03/14/2017 RESAMPLE ACTIONS
Rm. 004 - Boiler Room	Hose Bib at Meter	Secured - SCSD Staff Only	1	FN-M100	6.9	None	--	--
Rm. 005 - Gym Teacher's Bathroom	Sink	Secured - SCSD Staff Only	76	FN-S217	1.2	None	--	--
Rm. A100 - Hallway/Vestibule	Fountain	Public Access	88	FN-F207	< 1.0	None	--	--
Rm. A105 - Girl's Gym Bathroom	Sink	Public Access	77	FN-S218	< 1.0	None	--	--
Rm. A108 - Boy's Gym Bathroom	Sink	Public Access	75	FN-S216	< 1.0	None	--	--
Rm. 100 - Classroom	Sink	Public Access	62	FN-S203	2.8	None	--	--
Rm. 100 - Classroom	Fountain	Public Access	85	FN-F204	< 1.0	None	--	--
Rm. 102 - Classroom	Sink	Public Access	63	FN-S204	1.4	None	--	--
Rm. 102 - Classroom	Fountain	Public Access	86	FN-F205	3.8	None	--	--
Rm. 103 - Classroom	Sink	Public Access	64	FN-S205	1.4	None	--	--
Rm. 103 - Classroom	Fountain	Public Access	87	FN-F206	2.7	None	--	--
Rm. 104 - Classroom	Sink	Public Access	12	FN-S110	3.6	None	--	--
Rm. 104 - Classroom	Fountain	Public Access	51	FN-F107	2.6	None	--	--
Rm. 106 - Classroom	Sink	Public Access	11	FN-S109	1.6	None	--	--
Rm. 106 - Classroom	Fountain	Public Access	50	FN-F106	6.4	None	--	--
Rm. 112 - Classroom	Sink	Public Access	9	FN-S107	1.0	None	--	--
Rm. 112 - Classroom	Fountain	Public Access	49	FN-F105	2.6	None	--	--
Rm. 113 - Classroom	Sink	Public Access	8	FN-S106	1.4	None	--	--
Rm. 113 - Classroom	Fountain	Public Access	48	FN-F104	1.9	None	--	--
Rm. 114 - Classroom	Sink	Public Access	7	FN-S105	1.9	None	--	--
Rm. 114 - Classroom	Fountain	Public Access	47	FN-F103	1.8	None	--	--
Rm. 116 - Classroom	Sink	Public Access	6	FN-S104	1.3	None	--	--
Rm. 116 - Classroom	Fountain	Public Access	46	FN-F102	3.7	None	--	--
Rm. 117 - Classroom	Sink	Public Access	5	FN-S103	2.5	None	--	--
Rm. 117 - Classroom	Fountain	Public Access	45	FN-F101	2.4	None	--	--
Rm. 119 - Hallway/Vestibule	Sink	Public Access	2	FN-S100	< 1.0	None	--	--
Rm. 119 - Hallway/Vestibule	Sink	Public Access	3	FN-S101	< 1.0	None	--	--
Rm. 119 - Hallway/Vestibule	Sink	Public Access	4	FN-S102	< 1.0	None	--	--
Rm. 119 - Hallway/Vestibule	Fountain	Public Access	44	FN-F100	< 1.0	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT
FRANKLIN ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/17/2016 SAMPLE RESULTS (ppb)	09/17/2016 ORIGINAL ACTIONS	03/14/2017 RESAMPLE RESULTS (ppb)	03/14/2017 RESAMPLE ACTIONS
Rm. 123 - Classroom	Sink	Public Access	59	FN-S200	3.0	None	--	--
Rm. 123 - Classroom	Fountain	Public Access	81	FN-F200	< 1.0	None	--	--
Rm. 124 - Classroom	Sink	Public Access	60	FN-S201	3.1	None	--	--
Rm. 124 - Classroom	Fountain	Public Access	82	FN-F201	< 1.0	None	--	--
Rm. 125 - Classroom	Sink	Public Access	61	FN-S202	2.3	None	--	--
Rm. 125 - Classroom	Fountain	Public Access	84	FN-F203	< 1.0	None	--	--
Rm. 131 - Kitchen	Sink	Secured - SCSD Staff Only	14 / FN-001	FN-S112 / FN-S112B	19.0	*See Note 6	3.6	None
Rm. 131 - Kitchen	Sink	Secured - SCSD Staff Only	15	FN-S113	5.9	None	--	--
Rm. 131 - Kitchen	Sink	Secured - SCSD Staff Only	16	FN-S114	2.1	None	--	--
Rm. 131 - Kitchen	Sink	Secured - SCSD Staff Only	17	FN-S115	4.2	None	--	--
Rm. 131C - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	13	FN-S111	< 1.0	None	--	--
Rm. 138A - Teacher's Resource Bathroom	Sink	Secured - SCSD Staff Only	10	FN-S108	1.1	None	--	--
Rm. 146C - Cafeteria Passage	Fountain	Public Access	83	FN-F202	< 1.0	None	--	--
Rm. 146D - Boy's Bathroom	Sink	Public Access	66	FN-S207	4.2	None	--	--
Rm. 146E - Girl's Bathroom	Sink	Public Access	65	FN-S206	< 1.0	None	--	--
Rm. 201 - Nurse's Office	Sink	Public Access	67	FN-S208	1.1	None	--	--
Rm. 201C - Nurse's Office Bathroom	Sink	Public Access	68	FN-S209	5.9	None	--	--
Rm. 202 - Clinic Room	Sink	Public Access	70	FN-S211	8.1	None	--	--
Rm. 202 - Clinic Room	Sink	Public Access	71	FN-S212	4.6	None	--	--
Rm. 202 - Clinic/Examination Room	Sink	Public Access	72	FN-S213	4.0	None	--	--
Rm. 202 - Clinic/Examination Room	Sink	Public Access	73	FN-S214	14.0	None	--	--
Rm. 202 - Clinic Room	Sink	Public Access	74	FN-S215	1.7	None	--	--
Rm. 204 - Clinic Room	Sink	Public Access	69	FN-S210	3.0	None	--	--
Rm. 205 - Women's Bathroom	Sink	Public Access	36	FN-S134	< 1.0	None	--	--
Rm. 206 - Men's Bathroom	Sink	Public Access	35	FN-S133	1.4	None	--	--
Rm. 208 - Teacher's Lounge Kitchenette	Sink	Secured - SCSD Staff Only	32	FN-S130	1.3	None	--	--
Rm. 208A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	33	FN-S131	1.3	None	--	--
Rm. 208B - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	34	FN-S132	6.1	None	--	--
Rm. 209 - Classroom	Sink	Public Access	31	FN-S129	< 1.0	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT
FRANKLIN ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/17/2016 SAMPLE RESULTS (ppb)	09/17/2016 ORIGINAL ACTIONS	03/14/2017 RESAMPLE RESULTS (ppb)	03/14/2017 RESAMPLE ACTIONS
Rm. 210A - Classroom Bathroom	Sink	Public Access	30	FN-S128	5.5	None	--	--
Rm. 211 - Teacher's Resource	Sink	Public Access	29	FN-S127	3.3	None	--	--
Rm. 212B - Work Room	Sink	Secured - SCSD Staff Only	22	FN-S120	1.7	None	--	--
Rm. 212D - Hallway/Vestibule	Sink	Public Access	24	FN-S122	< 1.0	None	--	--
Rm. 212D - Hallway/Vestibule	Sink	Public Access	25	FN-S123	2.9	None	--	--
Rm. 212D - Hallway/Vestibule	Sink	Public Access	26	FN-S124	< 1.0	None	--	--
Rm. 212D - Hallway/Vestibule	Fountain	Public Access	52	FN-F108	< 1.0	None	--	--
Rm. 215 - Computer Room	Sink	Public Access	28	FN-S126	2.1	None	--	--
Rm. 215 - Computer Room	Fountain	Public Access	54	FN-F110	3.5	None	--	--
Rm. 216 - Computer Room	Sink	Public Access	27	FN-S125	2.1	None	--	--
Rm. 216 - Computer Room	Fountain	Public Access	53	FN-F109	1.3	None	--	--
Rm. 220A - Classroom Bathroom	Sink	Public Access	23	FN-S121	< 1.0	None	--	--
Rm. 224 - Principal's Bathroom	Sink	Secured - SCSD Staff Only	19	FN-S117	< 1.0	None	--	--
Rm. 226 - Main Office Bathroom	Sink	Secured - SCSD Staff Only	18	FN-S116	5.6	None	--	--
Rm. 228B - Office Kitchenette	Sink	Secured - SCSD Staff Only	20	FN-S118	< 1.0	None	--	--
Rm. 234 - Hallway/Corridor	Fountain	Public Access	55	FN-F111	< 1.0	None	--	--
Rm. 245 - Staff Bathroom	Sink	Secured - SCSD Staff Only	21	FN-S119	1.2	None	--	--
Rm. 307 - Hallway/Vestibule	Sink	Public Access	41	FN-S139	< 1.0	None	--	--
Rm. 307 - Hallway/Vestibule	Sink	Public Access	42	FN-S140	< 1.0	None	--	--
Rm. 307 - Hallway/Vestibule	Sink	Public Access	43	FN-S141	1.6	None	--	--
Rm. 307 - Hallway/Vestibule	Fountain	Public Access	58	FN-F114	< 1.0	None	--	--
Rm. 309 - Classroom	Sink	Public Access	40	FN-S138	2.1	None	--	--
Rm. 309 - Classroom	Fountain	Public Access	57	FN-F113	1.3	None	--	--
Rm. 310 - Classroom	Sink	Public Access	39	FN-S137	2.4	None	--	--
Rm. 310 - Classroom	Fountain	Public Access	56	FN-F112	1.2	None	--	--
Rm. 319 - Hallway/Vestibule	Sink	Public Access	78	FN-S219	2.7	None	--	--
Rm. 319 - Hallway/Vestibule	Sink	Public Access	79	FN-S220	< 1.0	None	--	--
Rm. 319 - Hallway/Vestibule	Sink	Public Access	80	FN-S221	5.2	None	--	--
Rm. 319 - Hallway/Vestibule	Fountain	Public Access	89	FN-F208	< 1.0	None	--	--

SYRACUSE CITY SCHOOL DISTRICT
FRANKLIN ELEMENTARY SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/17/2016 SAMPLE RESULTS (ppb)	09/17/2016 ORIGINAL ACTIONS	03/14/2017 RESAMPLE RESULTS (ppb)	03/14/2017 RESAMPLE ACTIONS
Rm. 330 - Staff Bathroom	Sink	Secured - SCSD Staff Only	38	FN-S136	1.7	None	--	--
Rm. 331 - Staff Bathroom	Sink	Secured - SCSD Staff Only	37	FN-S135	3.5	None	--	--

Original Sampling Notes (September 17, 2016 Event):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-006
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1615915
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. SCSD to replace fixture

Resampling Notes (March 14, 2017 Event):

1. Water samples collected By: SCSD Facilities Personnel
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1703692
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
5. Resample ID Numbers are indicated with a "B".