

**SYRACUSE CITY SCHOOL DISTRICT
LEMOYNE ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/17/2016 SAMPLE RESULTS (ppb)	09/17/2016 ORIGINAL ACTIONS	03/14/2017 RESAMPLE RESULTS (ppb)	03/14/2017 RESAMPLE ACTIONS
Rm. 005 - Classroom	Sink	Public Access	LM-014	LM-S101	2.9	None	--	--
Rm. 005 - Classroom	Fountain	Public Access	LM-001	LM-F101	< 1.0	None	--	--
Rm. 005C - Classroom Bathroom	Sink	Public Access	LM-015	LM-S102	2.3	None	--	--
Rm. 100E - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	LM-028	LM-S115	5.8	None	--	--
Rm. 100F - Kitchen Serving Room	Sink	Secured - SCSD Staff Only	LM-029	LM-S116	1.7	None	--	--
Rm. 100F - Kitchen Serving Room	Sink	Secured - SCSD Staff Only	LM-030	LM-S117	1.5	None	--	--
Rm. 100F - Kitchen Serving Room	Sink	Secured - SCSD Staff Only	LM-031	LM-S118	1.8	None	--	--
Rm. 100F - Kitchen Serving Room	Sink	Secured - SCSD Staff Only	LM-032	LM-S119	2.9	None	--	--
Rm. 101 - Classroom	Sink	Public Access	LM-026	LM-S113	< 1.0	None	--	--
Rm. 101 - Classroom	Fountain	Public Access	LM-005	LM-F105	< 1.0	None	--	--
Rm. 101A - Classroom Bathroom	Sink	Public Access	LM-027	LM-S114	5.1	None	--	--
Rm. 101B - Hallway/Corridor	Fountain	Public Access	LM-002	LM-F102	< 1.0	None	--	--
Rm. 101J - Hallway/Corridor	Fountain	Public Access	LM-006	LM-F106	< 1.0	None	--	--
Rm. 101J - Hallway/Corridor	Fountain	Public Access	LM-007	LM-F107	< 1.0	None	--	--
Rm. 102A - Classroom Bathroom	Sink	Public Access	LM-023	LM-S110	6.8	None	--	--
Rm. 103 - Classroom	Sink	Public Access	LM-025	LM-S112	2.3	None	--	--
Rm. 103 - Classroom	Fountain	Public Access	LM-004	LM-F104	1.6	None	--	--
Rm. 103A - Classroom Bathroom	Sink	Public Access	LM-024	LM-S111	< 1.0	None	--	--
Rm. 104 - Classroom Bathroom	Sink	Public Access	LM-022	LM-S109	1.2	None	--	--
Rm. 105 - Classroom	Sink	Public Access	LM-021	LM-S108	< 1.0	None	--	--
Rm. 105 - Classroom	Fountain	Public Access	LM-003	LM-F103	1.1	None	--	--
Rm. 105A - Classroom Bathroom	Sink	Public Access	LM-020	LM-S107	5.1	None	--	--
Rm. 106B - Storage Room	Sink	Secured - SCSD Staff Only	LM-016	LM-S103	1.1	None	--	--
Rm. 110A - Clinic Room	Sink	Public Access	LM-037	LM-S124	2.5	None	--	--
Rm. 110B - Nurse's Bathroom	Sink	Public Access	LM-038	LM-S125	2.7	None	--	--
Rm. 113 - Classroom	Sink	Public Access	LM-043	LM-S130	1.3	None	--	--
Rm. 113 - Classroom	Fountain	Public Access	LM-008	LM-F108	1.4	None	--	--
Rm. 113A - Classroom Bathroom	Sink	Public Access	LM-042	LM-S129	< 1.0	None	--	--
Rm. 115 - Classroom	Sink	Public Access	LM-045	LM-S132	< 1.0	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT
LEMOYNE ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/17/2016 SAMPLE RESULTS (ppb)	09/17/2016 ORIGINAL ACTIONS	03/14/2017 RESAMPLE RESULTS (ppb)	03/14/2017 RESAMPLE ACTIONS
Rm. 115 - Classroom	Fountain	Public Access	LM-009	LM-F109	1.6	None	--	--
Rm. 115A - Classroom Bathroom	Sink	Public Access	LM-044	LM-S131	7.0	None	--	--
Rm. 118 - Classroom	Sink	Public Access	LM-046	LM-S133	< 1.0	None	--	--
Rm. 118 - Classroom	Fountain	Public Access	LM-010	LM-F110	2.3	None	--	--
Rm. 118A - Classroom Bathroom	Sink	Public Access	LM-047	LM-S134	2.2	None	--	--
Rm. 121A - Storage Room	Sink	Secured - SCSD Staff Only	LM-039	LM-S126	4.7	None	--	--
Rm. 121A - Storage Room	Sink	Secured - SCSD Staff Only	LM-041	LM-S128	< 1.0	None	--	--
Rm. 121E - Office Bathroom	Sink	Secured - SCSD Staff Only	LM-040	LM-S127	1.8	None	--	--
Rm. 134 - Boy's Bathroom	Sink	Public Access	LM-033	LM-S120	3.3	None	--	--
Rm. 134 - Boy's Bathroom	Sink	Public Access	LM-034	LM-S121	5.6	None	--	--
Rm. 134A - Girl's Bathroom	Sink	Public Access	LM-035	LM-S122	6.1	None	--	--
Rm. 134A - Girl's Bathroom	Sink	Public Access	LM-036	LM-S123	1.4	None	--	--
Rm. 138 - Gym Bathroom	Sink	Public Access	LM-017	LM-S104	< 1.0	None	--	--
Rm. 141 - Girl's Bathroom	Sink	Public Access	LM-019	LM-S106	4.8	None	--	--
Rm. 141A - Boy's Bathroom	Sink	Public Access	LM-018	LM-S105	3.5	None	--	--
Rm. 201F - Hallway/Corridor	Fountain	Public Access	LM-011	LM-F111	< 1.0	None	--	--
Rm. 201F - Hallway/Corridor	Fountain	Public Access	LM-012	LM-F112	< 1.0	None	--	--
Rm. 204 - Lounge	Sink	Secured - SCSD Staff Only	LM-059	LM-S146	< 1.0	None	--	--
Rm. 204A - Lounge Bathroom	Sink	Secured - SCSD Staff Only	LM-061	LM-S148	< 1.0	None	--	--
Rm. 204B - Lounge Bathroom	Sink	Secured - SCSD Staff Only	LM-060	LM-S147	1.4	None	--	--
Rm. 206 - Classroom	Sink	Public Access	LM-053	LM-S140	1.8	None	--	--
Rm. 206 - Classroom	Sink	Public Access	LM-054	LM-S141	3.2	None	--	--
Rm. 212A - Girl's Bathroom/Corridor	Sink	Public Access	LM-049	LM-S136	1.1	None	--	--
Rm. 212A - Girl's Bathroom/Corridor	Sink	Public Access	LM-050	LM-S137	3.0	None	--	--
Rm. 212B - Boy's Bathroom Sink/Corridor	Sink	Public Access	LM-051	LM-S138	15.0	*See Note 6	--	--
Rm. 212B - Boy's Bathroom Sink/Corridor	Sink	Public Access	LM-052 / LM-001	LM-S139 / LM-S139B	16.0	*See Note 7	<1.0	None
Rm. 212D - Staff Bathroom	Sink	Secured - SCSD Staff Only	LM-055	LM-S142	1.1	None	--	--
Rm. 219A - Library Office	Sink	Secured - SCSD Staff Only	LM-048	LM-S135	< 1.0	None	--	--
Rm. 222 - Hallway/Vestibule	Sink	Public Access	LM-056	LM-S143	< 1.0	None	--	--

SYRACUSE CITY SCHOOL DISTRICT
LEMOYNE ELEMENTARY SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/17/2016 SAMPLE RESULTS (ppb)	09/17/2016 ORIGINAL ACTIONS	03/14/2017 RESAMPLE RESULTS (ppb)	03/14/2017 RESAMPLE ACTIONS
Rm. 222 - Hallway/Vestibule	Sink	Public Access	LM-057	LM-S144	3.7	None	--	--
Rm. 222 - Hallway/Vestibule	Fountain	Public Access	LM-013	LM-F113	< 1.0	None	--	--
Rm. 222 - Hallway/Vestibule	Sink	Public Access	LM-058	LM-S145	8.3	None	--	--

Original Sampling Notes (September 17, 2017 Event):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-004
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1615976
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. SCSD to replace fixture
7. SCSD to replace fixture

Resampling Notes (March 14, 2017 Event):

1. Water samples collected By: SCSD Facilities Personnel
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1703694
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
5. Resample ID Numbers are indicated with a "B"