

**SYRACUSE CITY SCHOOL DISTRICT  
DR. KING ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/25/2016 SAMPLE RESULTS (ppb)	09/25/2016 ORIGINAL ACTIONS	03/22/2017 RESAMPLE RESULTS (ppb)	03/22/2017 RESAMPLE ACTIONS
Rm. A002 - Mechanical/Meter Room	Hose Bib at Meter	Secured - SCSO Staff Only	DKES-175	DK-M100	30.0	*See Note 6	--	--
Rm. A102 - Hallway/Corridor	Fountain	Public Access	DKES-151	DK-F301	< 1.0	None	--	--
Rm. A102 - Hallway/Corridor	Fountain	Public Access	DKES-152	DK-F302	< 1.0	None	--	--
Rm. A113 - Kitchenette	Sink	Secured - SCSO Staff Only	DKES-106	DK-S325	< 1.0	None	--	--
Rm. A116 - Classroom	Sink	Public Access	DKES-094	DK-S313	< 1.0	None	--	--
Rm. A116 - Classroom	Fountain	Public Access	DKES-157	DK-F307	< 1.0	None	--	--
Rm. A116A - Classroom Bathroom	Sink	Public Access	DKES-095	DK-S314	< 1.0	None	--	--
Rm. A117 - Classroom	Sink	Public Access	DKES-092	DK-S311	< 1.0	None	--	--
Rm. A117 - Classroom	Fountain	Public Access	DKES-156	DK-F306	< 1.0	None	--	--
Rm. A117A - Classroom Bathroom	Sink	Public Access	DKES-093	DK-S312	< 1.0	None	--	--
Rm. A118 - Classroom	Sink	Public Access	DKES-090 / DKS-001	DK-S309 / DK-S309B	45.0	*See Note 7	< 1.0	None
Rm. A118 - Classroom	Fountain	Public Access	DKES-155	DK-F305	< 1.0	None	--	--
Rm. A118A - Classroom Bathroom	Sink	Public Access	DKES-091	DK-S310	< 1.0	None	--	--
Rm. A119 - Classroom	Sink	Public Access	DKES-088	DK-S307	< 1.0	None	--	--
Rm. A119 - Classroom	Fountain	Public Access	DKES-154	DK-F304	< 1.0	None	--	--
Rm. A119A - Classroom Bathroom	Sink	Public Access	DKES-089	DK-S308	< 1.0	None	--	--
Rm. A120 - Classroom	Sink	Public Access	DKES-086	DK-S305	< 1.0	None	--	--
Rm. A120 - Classroom	Fountain	Public Access	DKES-153	DK-F303	< 1.0	None	--	--
Rm. A120A - Classroom Bathroom	Sink	Public Access	DKES-087	DK-S306	< 1.0	None	--	--
Rm. A122 - Men's Staff Bathroom	Sink	Secured - SCSO Staff Only	DKES-083	DK-S302	< 1.0	None	--	--
Rm. A123 - Women's Staff Bathroom	Sink	Secured - SCSO Staff Only	DKES-085	DK-S304	< 1.0	None	--	--
Rm. A124 - Girl's Bathroom	Sink	Public Access	DKES-084	DK-S303	< 1.0	None	--	--
Rm. A125 - Boy's Bathroom	Sink	Public Access	DKES-082	DK-S301	< 1.0	None	--	--
Rm. A129 - Classroom	Sink	Public Access	DKES-104	DK-S323	< 1.0	None	--	--
Rm. A129 - Classroom	Fountain	Public Access	--	DK-F311	--	*See Note 8	--	--
Rm. A129A - Classroom Bathroom	Sink	Public Access	DKES-105	DK-S324	< 1.0	None	--	--
Rm. A130 - Classroom	Sink	Public Access	DKES-102	DK-S321	< 1.0	None	--	--
Rm. A130 - Classroom	Fountain	Public Access	DKES-160	DK-F310	< 1.0	None	--	--
Rm. A130A - Classroom Bathroom	Sink	Public Access	DKES-103	DK-S322	< 1.0	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT  
DR. KING ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/25/2016 SAMPLE RESULTS (ppb)	09/25/2016 ORIGINAL ACTIONS	03/22/2017 RESAMPLE RESULTS (ppb)	03/22/2017 RESAMPLE ACTIONS
Rm. A131 - Classroom	Sink	Public Access	DKES-100	DK-S319	< 1.0	None	--	--
Rm. A131 - Classroom	Fountain	Public Access	DKES-159	DK-F309	< 1.0	None	--	--
Rm. A131A - Classroom Bathroom	Sink	Public Access	DKES-101	DK-S320	< 1.0	None	--	--
Rm. A132 - Classroom	Sink	Public Access	DKES-098	DK-S317	< 1.0	None	--	--
Rm. A132A - Classroom Bathroom	Sink	Public Access	DKES-099	DK-S318	< 1.0	None	--	--
Rm. A133 - Classroom	Sink	Public Access	DKES-096	DK-S315	< 1.0	None	--	--
Rm. A133 - Classroom	Fountain	Public Access	DKES-158	DK-F308	< 1.0	None	--	--
Rm. A133A - Classroom Bathroom	Sink	Public Access	DKES-097	DK-S316	< 1.0	None	--	--
Rm. B102 - Hallway/Corridor	Fountain	Public Access	DKES-161	DK-F312	< 1.0	None	--	--
Rm. B102 - Hallway/Corridor	Fountain	Public Access	DKES-162	DK-F313	< 1.0	None	--	--
Rm. B112 - Classroom	Sink	Public Access	DKES-107	DK-S326	2.0	None	--	--
Rm. B112 - Classroom	Sink	Public Access	DKES-108	DK-S327	1.1	None	--	--
Rm. B112 - Classroom	Sink	Public Access	DKES-109	DK-S328	1.5	None	--	--
Rm. B112 - Classroom	Sink	Public Access	DKES-110 / DKS-002	DK-S329 / DK-S329B	24.0	*See Note 9	1.1	None
Rm. B115 - Resource & Staff Development	Sink	Secured - SCSD Staff Only	DKES-027	DK-S125	< 1.0	None	--	--
Rm. B116 - Science Office	Sink	Public Access	DKES-111	DK-S330	< 1.0	None	--	--
Rm. B118A - Boy's/Girl's Bathroom	Sink	Public Access	DKES-029	DK-S127	< 1.0	None	--	--
Rm. B118B - Staff's Bathroom	Sink	Secured - SCSD Staff Only	DKES-028	DK-S126	< 1.0	None	--	--
Rm. B122 - Media Work Room	Sink	Public Access	DKES-030	DK-S128	2.7	None	--	--
Rm. B125 - Staff's Bathroom	Sink	Secured - SCSD Staff Only	DKES-026	DK-S124	< 1.0	None	--	--
Rm. B126 - Boy's Bathroom	Sink	Public Access	DKES-025	DK-S123	< 1.0	None	--	--
Rm. B127 - Girl's Bathroom	Sink	Public Access	DKES-024	DK-S122	< 1.0	None	--	--
Rm. B128 - Staff Lounge	Sink	Secured - SCSD Staff Only	DKES-023	DK-S121	< 1.0	None	--	--
Rm. B128A - Staff Bathroom	Sink	Secured - SCSD Staff Only	DKES-022	DK-S120	< 1.0	None	--	--
Rm. B129 - Classroom	Sink	Public Access	DKES-067	DK-S224	< 1.0	None	--	--
Rm. B129 - Classroom	Fountain	Public Access	DKES-147	DK-F203	2.2	None	--	--
Rm. B130 - Classroom	Sink	Public Access	DKES-066	DK-S223	< 1.0	None	--	--
Rm. B133 - Music Room	Sink	Public Access	DKES-065	DK-S222	< 1.0	None	--	--
Rm. B134 - Classroom	Sink	Public Access	DKES-021	DK-S119	< 1.0	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT  
DR. KING ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/25/2016 SAMPLE RESULTS (ppb)	09/25/2016 ORIGINAL ACTIONS	03/22/2017 RESAMPLE RESULTS (ppb)	03/22/2017 RESAMPLE ACTIONS
Rm. B134 - Classroom	Fountain	Public Access	-	DK-F107	-	*See Note 10	-	--
Rm. B134A - Classroom Bathroom	Sink	Public Access	DKES-020	DK-S118	< 1.0	None	--	--
Rm. B136 - Classroom	Sink	Public Access	DKES-018	DK-S117A	< 1.0	None	--	--
Rm. B136 - Classroom	Sink	Public Access	DKES-019	DK-S117B	1.4	None	--	--
Rm. B136A - Classroom Bathroom	Sink	Public Access	DKES-017	DK-S116	< 1.0	None	--	--
Rm. C106 - Hallway/Corridor	Fountain	Public Access	DKES-135	DK-F100	< 1.0	None	--	--
Rm. C106 - Hallway/Corridor	Fountain	Public Access	DKES-136	DK-F101	< 1.0	None	--	--
Rm. C108 - Hallway/Corridor	Sink	Public Access	DKES-057	DK-S214	< 1.0	None	--	--
Rm. C108 - Hallway/Corridor	Sink	Public Access	DKES-059	DK-S216	< 1.0	None	--	--
Rm. C111 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DKES-015	DK-S114	< 1.0	None	--	--
Rm. C112 - Café	Fountain	Public Access	DKES-145	DK-F201	< 1.0	None	--	--
Rm. C112 - Café	Fountain	Public Access	DKES-146	DK-F202	< 1.0	None	--	--
Rm. C113 - Girl's Bathroom	Sink	Public Access	DKES-046	DK-S203	< 1.0	None	--	--
Rm. C113 - Girl's Bathroom	Sink	Public Access	DKES-047	DK-S204	< 1.0	None	--	--
Rm. C115 - Boy's Bathroom	Sink	Public Access	DKES-044	DK-S201	< 1.0	None	--	--
Rm. C115 - Boy's Bathroom	Sink	Public Access	DKES-045	DK-S202	< 1.0	None	--	--
Rm. C117 - Kitchen	Sink	Secured - SCSD Staff Only	DKES-048	DK-S205	< 1.0	None	--	--
Rm. C117 - Kitchen	Sink	Secured - SCSD Staff Only	DKES-049	DK-S206	< 1.0	None	--	--
Rm. C117 - Kitchen	Sink	Secured - SCSD Staff Only	DKES-050	DK-S207	< 1.0	None	--	--
Rm. C117 - Kitchen	Sink	Secured - SCSD Staff Only	DKES-051	DK-S208	< 1.0	None	--	--
Rm.s C123 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	DKES-053	DK-S210	< 1.0	None	--	--
Rm. C126 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	DKES-054	DK-S211	< 1.0	None	--	--
Rm. C129 - Custodian Shop	Sink	Secured - SCSD Staff Only	DKES-052	DK-S209	< 1.0	None	--	--
Rm. C132 - Nurse's Bathroom	Sink	Public Access	DKES-064	DK-S221	10.0	None	--	--
Rm. C133 - Nurse's Room	Sink	Public Access	DKES-062	DK-S219	< 1.0	None	--	--
Rm. C136 - Clean Room	Sink	Secured - SCSD Staff Only	DKES-060	DK-S217	1.4	None	--	--
Rm. C137 - Staff's Bathroom	Sink	Secured - SCSD Staff Only	DKES-058	DK-S215	< 1.0	None	--	--
Rm. C138 - Sick Room	Sink	Public Access	DKES-063	DK-S220	< 1.0	None	--	--
Rm. C140 - Exam Room	Sink	Public Access	DKES-061	DK-S218	<1.0	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT  
DR. KING ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/25/2016 SAMPLE RESULTS (ppb)	09/25/2016 ORIGINAL ACTIONS	03/22/2017 RESAMPLE RESULTS (ppb)	03/22/2017 RESAMPLE ACTIONS
Rm.s C141 - Exam Room	Sink	Public Access	DKES-056	DK-S213	< 1.0	None	--	--
Rm. C142 - Dental Room	Sink	Public Access	DKES-055	DK-S212	< 1.0	None	--	--
Rm. C146A - Staff Bathroom	Sink	Secured - SCSD Staff Only	DKES-016	DK-S115	1.2	None	--	--
Rm. C147 - Mail Room	Sink	Secured - SCSD Staff Only	DKES-001	DK-S100	< 1.0	None	--	--
Rm. C148 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DKES-002	DK-S101	3.2	None	--	--
Rm. D101 - Hallway/Corridor	Fountain	Public Access	DKES-137	DK-F102	< 1.0	None	--	--
Rm. D101 - Hallway/Corridor	Fountain	Public Access	DKES-138	DK-F103	< 1.0	None	--	--
Rm. D108A - Hallway/Corridor	Fountain	Public Access	DKES-139	DK-F104	< 1.0	None	--	--
Rm. D108A - Hallway/Corridor	Fountain	Public Access	DKES-140	DK-F105	< 1.0	None	--	--
Rm. D113 - Kitchen	Sink	Secured - SCSD Staff Only	DKES-003	DK-S102	< 1.0	None	--	--
Rm. D114 - Staff's Bathroom	Sink	Secured - SCSD Staff Only	DKES-004	DK-S103	< 1.0	None	--	--
Rm. D115 - Staff's Bathroom	Sink	Secured - SCSD Staff Only	DKES-006	DK-S105	< 1.0	None	--	--
Rm. D121A - PE Bathroom	Sink	Secured - SCSD Staff Only	DKES-005	DK-S104	< 1.0	None	--	--
Rm. D127 - Classroom	Sink	Public Access	DKES-014	DK-S113	< 1.0	None	--	--
Rm. D127A - Classroom Bathroom	Sink	Public Access	DKES-013	DK-S112	< 1.0	None	--	--
Rm. D128 - Classroom	Sink	Public Access	DKES-012	DK-S111	< 1.0	None	--	--
Rm. D128A - Classroom Bathroom	Sink	Public Access	DKES-011	DK-S110	< 1.0	None	--	--
Rm. D130 - Boy's Locker Room	Sink	Public Access	DKES-007	DK-S106	< 1.0	None	--	--
Rm. D130 - Boy's Locker Room	Sink	Public Access	DKES-008	DK-S107	< 1.0	None	--	--
Rm. D131 - Girl's Locker Room	Sink	Public Access	DKES-009	DK-S108	< 1.0	None	--	--
Rm. D131 - Girl's Locker Room	Sink	Public Access	DKES-010	DK-S109	< 1.0	None	--	--
Rm. A202 - Hallway/Corridor	Fountain	Public Access	DKES-163	DK-F314	< 1.0	None	--	--
Rm. A202 - Hallway/Corridor	Fountain	Public Access	DKES-164	DK-F315	< 1.0	None	--	--
Rm. A213 - Kitchenette	Sink	Public Access	DKES-134	DK-S353	< 1.0	None	--	--
Rm. A217 - Classroom	Sink	Public Access	DKES-123	DK-S342	< 1.0	None	--	--
Rm. A217 - Classroom	Fountain	Public Access	DKES-169	DK-F320	< 1.0	None	--	--
Rm. A217A - Classroom Bathroom	Sink	Public Access	DKES-124	DK-S343	< 1.0	None	--	--
Rm. A218 - Classroom	Sink	Public Access	DKES-121	DK-S340	< 1.0	None	--	--
Rm. A218 - Classroom	Fountain	Public Access	DKES-168	DK-F319	< 1.0	None	--	--



**SYRACUSE CITY SCHOOL DISTRICT  
DR. KING ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/25/2016 SAMPLE RESULTS (ppb)	09/25/2016 ORIGINAL ACTIONS	03/22/2017 RESAMPLE RESULTS (ppb)	03/22/2017 RESAMPLE ACTIONS
Rm. A218A - Classroom Bathroom	Sink	Public Access	DKES-122	DK-S341	< 1.0	None	--	--
Rm. A219 - Classroom	Sink	Public Access	DKES-119	DK-S338	< 1.0	None	--	--
Rm. A219 - Classroom	Fountain	Public Access	DKES-167	DK-F318	< 1.0	None	--	--
Rm. A219A - Classroom Bathroom	Sink	Public Access	DKES-120	DK-S339	< 1.0	None	--	--
Rm. A220 - Classroom	Sink	Public Access	DKES-118	DK-S337	< 1.0	None	--	--
Rm. A220 - Classroom	Fountain	Public Access	DKES-166	DK-F317	< 1.0	None	--	--
Rm. A221 - Classroom	Sink	Public Access	DKES-116	DK-S335	< 1.0	None	--	--
Rm. A221 - Classroom	Fountain	Public Access	DKES-165	DK-F316	< 1.0	None	--	--
Rm. A221A - Classroom Bathroom	Sink	Public Access	DKES-117	DK-S336	1.3	None	--	--
Rm. A222 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DKES-115	DK-S334	< 1.0	None	--	--
Rm. A223 - Staff Bathroom	Sink	Secured - SCSD Staff Only	DKES-114	DK-S333	< 1.0	None	--	--
Rm. A224 - Girl's Bathroom	Sink	Public Access	DKES-113	DK-S332	< 1.0	None	--	--
Rm. A225 - Boy's Bathroom	Sink	Public Access	DKES-112	DK-S331	< 1.0	None	--	--
Rm. A233 - Classroom	Sink	Public Access	DKES-132	DK-S351	< 1.0	None	--	--
Rm. A233 - Classroom	Fountain	Public Access	DKES-174	DK-F325	< 1.0	None	--	--
Rm. A233A - Classroom Bathroom	Sink	Public Access	DKES-133	DK-S352	< 1.0	None	--	--
Rm. A234 - Classroom	Sink	Public Access	DKES-131	DK-S350	< 1.0	None	--	--
Rm. A234 - Classroom	Fountain	Public Access	DKES-173	DK-F324	< 1.0	None	--	--
Rm. A235 - Classroom	Sink	Public Access	DKES-129	DK-S348	< 1.0	None	--	--
Rm. A235 - Classroom	Fountain	Public Access	DKES-172	DK-F323	< 1.0	None	--	--
Rm. A235A - Classroom Bathroom	Sink	Public Access	DKES-130	DK-S349	< 1.0	None	--	--
Rm. A236 - Classroom	Sink	Public Access	DKES-127	DK-S346	< 1.0	None	--	--
Rm. A236 - Classroom	Fountain	Public Access	DKES-171	DK-F222	< 1.0	None	--	--
Rm. A236A - Classroom Bathroom	Sink	Public Access	DKES-128	DK-S347	< 1.0	None	--	--
Rm. A237 - Classroom	Sink	Public Access	DKES-125	DK-S344	< 1.0	None	--	--
Rm. A237 - Classroom	Fountain	Public Access	DKES-170	DK-F321	< 1.0	None	--	--
Rm. A237A - Classroom Bathroom	Sink	Public Access	DKES-126	DK-S345	< 1.0	None	--	--
Rm. B202 - Hallway/Corridor	Fountain	Public Access	DKES-149	DK-F205	< 1.0	None	--	--
Rm. B202 - Hallway/Corridor	Fountain	Public Access	DKES-150	DK-F206	< 1.0	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT  
DR. KING ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/25/2016 SAMPLE RESULTS (ppb)	09/25/2016 ORIGINAL ACTIONS	03/22/2017 RESAMPLE RESULTS (ppb)	03/22/2017 RESAMPLE ACTIONS
Rm. B211 - Classroom	Sink	Public Access	DKES-080	DK-S238	< 1.0	None	--	--
Rm. B211 - Classroom	Sink	Public Access	DKES-081	DK-S239	< 1.0	None	--	--
Rm. B214 - Boy's Bathroom	Sink	Public Access	DKES-078	DK-S236	< 1.0	None	--	--
Rm. B214 - Boy's Bathroom	Sink	Public Access	DKES-079	DK-S237	1.2	None	--	--
Rm. B216 - Girl's Bathroom	Sink	Public Access	DKES-076	DK-S234	< 1.0	None	--	--
Rm. B216 - Girl's Bathroom	Sink	Public Access	DKES-077	DK-S235	< 1.0	None	--	--
Rm. B217 - Classroom	Sink	Public Access	DKES-075	DK-S233	1.1	None	--	--
Rm. B217 - Classroom	Fountain	Public Access	DKES-148	DK-F204	< 1.0	None	--	--
Rm. B217A - Classroom Bathroom	Sink	Public Access	DKES-074	DK-S232	< 1.0	None	--	--
Rm. B218 - Classroom	Sink	Public Access	DKES-072	DK-S230	< 1.0	None	--	--
Rm. B222 - Commons Kitchenette	Sink	Secured - SCSD Staff Only	DKES-073	DK-S231	< 1.0	None	--	--
Rm. B223 - Classroom	Sink	Public Access	DKES-070	DK-S228	< 1.0	None	--	--
Rm. B224 - Classroom	Sink	Public Access	DKES-071	DK-S229	< 1.0	None	--	--
Rm. B225 - Classroom	Sink	Public Access	DKES-069	DK-S227	< 1.0	None	--	--
Rm. C202 - Hallway/Corridor	Fountain	Public Access	DKES-141	DK-F108	< 1.0	None	--	--
Rm. C202 - Hallway/Corridor	Fountain	Public Access	DKES-142	DK-F109	< 1.0	None	--	--
Rm. C213 - Staff's Bathroom	Sink	Secured - SCSD Staff Only	DKES-068	DK-S226	< 1.0	None	--	--
Rm. C216 - Kitchenette	Sink	Secured - SCSD Staff Only	DKES-032	DK-S130	< 1.0	None	--	--
Rm. C218 - Classroom	Sink	Public Access	DKES-031	DK-S129	< 1.0	None	--	--
Rm. C219 - Classroom	Sink	Public Access	DKES-033	DK-S131	< 1.0	None	--	--
Rm. C220 - Classroom	Sink	Public Access	DKES-034	DK-S132	< 1.0	None	--	--
Rm. C221 - Classroom	Sink	Public Access	DKES-035	DK-S133	< 1.0	None	--	--
Rm. C221 - Classroom	Fountain	Public Access	DKES-143	DK-F110	< 1.0	None	--	--
Rm. C221A - Classroom Bathroom	Sink	Public Access	DKES-036	DK-S134	< 1.0	None	--	--
Rm. C225 - Classroom	Sink	Public Access	DKES-038	DK-S136	< 1.0	None	--	--
Rm. C225 - Classroom	Fountain	Public Access	DKES-144	DK-F111	< 1.0	None	--	--
Rm. C225A - Classroom Bathroom	Sink	Public Access	DKES-037	DK-S135	< 1.0	None	--	--
Rm. C226 - Classroom	Sink	Public Access	DKES-039	DK-S137	< 1.0	None	--	--
Rm. C227 - Classroom	Sink	Public Access	DKES-040	DK-S138	< 1.0	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT**  
**DR. KING ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/25/2016 SAMPLE RESULTS (ppb)	09/25/2016 ORIGINAL ACTIONS	03/22/2017 RESAMPLE RESULTS (ppb)	03/22/2017 RESAMPLE ACTIONS
Rm. C228 - Classroom	Sink	Public Access	DKES-041	DK-S139	< 1.0	None	--	--
Rm. C229 - Girl's Bathroom	Sink	Public Access	DKES-042	DK-S140	5.9	None	--	--
Rm. C230 - Boy's Bathroom	Sink	Public Access	DKES-043	DK-S141	< 1.0	None	--	--

Original Sampling Notes (September 25, 2016 Event):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-018
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1619533
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. SCS D to post warning sign
7. SCS D is to replace fixture
8. Fixture not operating
9. SCS D is to replace fixture
10. Fixture not operating

Resampling Notes (March 22, 2017 Event):

1. Water samples collected By: SCS D Facilities Personnel
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1703987
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
5. Resample ID Numbers are indicated with a "B".