

SYRACUSE CITY SCHOOL DISTRICT
ED SMITH PK - Grade 8 SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/22/2016 SAMPLE RESULTS (ppb)	09/22/2016 ORIGINAL ACTIONS	04/13/2017 RESAMPLE RESULTS (ppb)	04/13/2017 RESAMPLE ACTIONS
Rm. 1 - Classroom	Sink	Public Access	EDS-005	EDS-S103	1.9	None	--	--
Rm. 1A - Classroom Bathroom	Sink	Public Access	N/A	EDS-S104	N/A	*See Note 6	--	--
Rm. 2 - Classroom	Sink	Public Access	EDS-007	EDS-S106	2.0	None	--	--
Rm. 2A - Classroom Bathroom	Sink	Public Access	EDS-006 / 005A	EDS-S105 / EDS-S105B	25.0	*See Note 7	1.7	None
Rm. 4A - Classroom Bathroom	Sink	Public Access	EDS-009	EDS-S108	3.3	None	--	--
Rm. 4B - Classroom	Sink	Public Access	EDS-008	EDS-S107	2.9	None	--	--
Rm. 5 - Classroom	Sink	Public Access	EDS-010	EDS-S109	2.1	None	--	--
Rm. 5A - Classroom Bathroom	Sink	Public Access	EDS-011	EDS-S110	8.9	None	--	--
Rm. 6 - Classroom	Sink	Public Access	EDS-012	EDS-S111	2.5	None	--	--
Rm. 8C - Classroom Bathroom	Sink	Public Access	EDS-015	EDS-S114	5.9	None	--	--
Rm. 8F - Custodian's Bathroom	Sink	Secured - SCSD Staff Only	EDS-016	EDS-S115	1.4	None	--	--
Rm. 12 - Classroom	Sink	Public Access	EDS-038	EDS-S137	3.5	None	--	--
Rm. 13 - Classroom	Sink	Public Access	EDS-036	EDS-S135	3.9	None	--	--
Rm. 14 - Classroom	Sink	Public Access	EDS-037	EDS-S136	5.7	None	--	--
Rm. 107 - Classroom	Sink	Public Access	EDS-049	EDS-S148	4.6	None	--	--
Rm. 110A - Storage Room	Sink	Secured - SCSD Staff Only	EDS-051	EDS-S150	1.4	None	--	--
Rm. 111 - Workroom Bathroom	Sink	Secured - SCSD Staff Only	EDS-050	EDS-S149	< 1.0	None	--	--
Rm. 112 - Boy's Bathroom	Sink	Public Access	EDS-047	EDS-S146	< 1.0	None	--	--
Rm. 112 - Boy's Bathroom	Sink	Public Access	EDS-048	EDS-S147	< 1.0	None	--	--
Rm. 113E - Principal's Bathroom	Sink	Secured - SCSD Staff Only	EDS-002	EDS-S100	3.1	None	--	--
Rm. 114 - Nurse's Office	Sink	Public Access	EDS-003	EDS-S101	1.1	None	--	--
Rm. 114T - Nurse's Office Bathroom	Sink	Public Access	EDS-004	EDS-S102	3.1	None	--	--
Rm. 118 - Girl's Bathroom	Sink	Public Access	EDS-044	EDS-S143	10.0	None	--	--
Rm. 118 - Girl's Bathroom	Sink	Public Access	EDS-045	EDS-S144	1.3	None	--	--
Rm. 118 - Girl's Bathroom	Sink	Public Access	EDS-046	EDS-S145	2.2	None	--	--
Rm. 126B - Hallway/Corridor	Fountain	Public Access	N/A	EDS-F105	N/A	*See Note 6	--	--
Rm. 126B - Hallway/Corridor	Fountain	Public Access	EDS-071	EDS-F106	< 1.0	None	--	--
Rm. 126D - Hallway/Corridor	Fountain	Public Access	EDS-067	EDS-F100	1.1	None	--	--
Rm. 126F - Hallway/Corridor	Fountain	Public Access	EDS-068	EDS-F101	< 1.0	None	--	--

SYRACUSE CITY SCHOOL DISTRICT
ED SMITH PK - Grade 8 SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/22/2016 SAMPLE RESULTS (ppb)	09/22/2016 ORIGINAL ACTIONS	04/13/2017 RESAMPLE RESULTS (ppb)	04/13/2017 RESAMPLE ACTIONS
Rm. 126K - Hallway/Vestibule	Sink	Public Access	EDS-030	EDS-S129	4.6	None	--	--
Rm. 126K - Hallway/Vestibule	Sink	Public Access	EDS-031	EDS-S130	11.0	None	--	--
Rm. 126K - Hallway/Vestibule	Sink	Public Access	EDS-032	EDS-S131	3.7	None	--	--
Rm. 126K - Hallway/Vestibule	Fountain	Public Access	EDS-070	EDS-F103	1.6	None	--	--
Rm. 127 - Girl's Bathroom	Sink	Public Access	EDS-013	EDS-S112	2.4	None	--	--
Rm. 127 - Girl's Bathroom	Sink	Public Access	EDS-014	EDS-S113	2.7	None	--	--
Rm. 129 - Copy Room	Sink	Secured - SCSD Staff Only	EDS-039	EDS-S138	11.0	None	--	--
Rm. 135 - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	EDS-023	EDS-122	8.3	None	--	--
Rm. 135 - Kitchen	Sink	Secured - SCSD Staff Only	EDS-024	EDS-S123	1.2	None	--	--
Rm. 135 - Kitchen	Sink	Secured - SCSD Staff Only	EDS-025	EDS-S124	< 1.0	None	--	--
Rm. 135 - Kitchen	Sink	Secured - SCSD Staff Only	EDS-026	EDS-S125	2.6	None	--	--
Rm. 135 - Kitchen	Sink	Secured - SCSD Staff Only	EDS-027	EDS-S126	3.6	None	--	--
Rm. 135 - Kitchen	Sink	Secured - SCSD Staff Only	EDS-028	EDS-S127	< 1.0	None	--	--
Rm. 135 - Kitchen	Sink	Secured - SCSD Staff Only	EDS-029	EDS-S128	1.9	None	--	--
Rm. 140 - Boy's Locker-room	Fountain	Public Access	N/A	EDS-F104	N/A	*See Note 6	--	--
Rm. 140 - Boy's Locker-room	Sink	Public Access	EDS-034 / 006A	EDS-S133 / EDS-S133B	48.0	*See Note 7	4.2	None
Rm. 141A - Boy's Coach Bathroom	Sink	Secured - SCSD Staff Only	EDS-033	EDS-S132	5.3	None	--	None
Rm. 154A - Storage Bathroom	Sink	Secured - SCSD Staff Only	EDS-035	EDS-S134	6.6	None	--	--
Rm. 156 - Boy's Bathroom	Sink	Public Access	EDS-022	EDS-121	9.2	None	--	--
Rm. 156A - Girl's Bathroom	Sink	Public Access	EDS-020 / 003A	EDS-S119 / EDS-S119B	25.0	*See Note 7	3.9	None
Rm. 156A - Girl's Bathroom	Sink	Public Access	EDS-021 / 004A	EDS-S120 / EDS-S120B	16.0	*See Note 7	6.4	None
Rm. 164 - Library Lounge	Sink	Secured - SCSD Staff Only	EDS-040 / 007A	EDS-S139 / EDS-S139B	32.0	*See Note 7	1.0	None
Rm. 169 - Girl's Bathroom	Sink	Public Access	EDS-018 / 001A	EDS-S117 / EDS-S117B	29.0	*See Note 7	180.0	See Note 6
Rm. 169 - Girl's Bathroom	Sink	Public Access	EDS-019 / 002A	EDS-S118 / EDS-S118B	27.0	*See Note 7	1.8	None
Rm. 171 - Boy's Bathroom	Sink	Public Access	EDS-017	EDS-S116	1.1	None	--	--
Rm. 176 - Meter/Boiler Room	Sink Adjacent to Meter	Secured - SCSD Staff Only	EDS-001	EDS-M100	5.1	None	--	--
Rm. 179 - Cafeteria	Fountain	Public Access	EDS-069	EDS-F102	1.1	None	--	--
Rm. B1 - Classroom	Sink	Public Access	EDS-041	EDS-S140	2.4	None	--	--
Rm. B5 - Classroom	Sink	Public Access	EDS-042	EDS-S141	6.0	None	--	--

SYRACUSE CITY SCHOOL DISTRICT
ED SMITH PK - Grade 8 SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/22/2016 SAMPLE RESULTS (ppb)	09/22/2016 ORIGINAL ACTIONS	04/13/2017 RESAMPLE RESULTS (ppb)	04/13/2017 RESAMPLE ACTIONS
Rm. B5 - Classroom	Sink	Public Access	EDS-043	EDS-S142	1.7	None	--	--
Rm. L-2 - Stairwell/Corridor Bathroom	Sink	Secured - SCSD Staff Only	EDS-061	EDS-S160	3.1	None	--	--
Rm. 206 - Girl's Bathroom	Sink	Public Access	EDS-057	EDS-S156	< 1.0	None	--	--
Rm. 206 - Girl's Bathroom	Sink	Public Access	EDS-058	EDS-S157	< 1.0	None	--	--
Rm. 209 - Classroom	Sink	Public Access	EDS-055	EDS-S154	9.4	None	--	--
Rm. 210 - Art Room	Sink	Public Access	EDS-052	EDS-S151	32.0	*See Note 8	--	--
Rm. 210 - Art Room	Sink	Public Access	EDS-053	EDS-S152	6.0	*See Note 8	--	--
Rm. 210 - Art Room	Sink	Public Access	EDS-054	EDS-S153	21.0	*See Note 8	--	--
Rm. 210A - Storage Room	Sink	Secured - SCSD Staff Only	EDS-056	EDS-S155	89.0	*See Note 8	--	--
Rm. 216 - Hallway/Corridor	Fountain	Public Access	EDS-072	EDS-F107	< 1.0	None	--	--
Rm. 216 - Hallway/Corridor	Fountain	Public Access	EDS-073	EDS-F108	< 1.0	None	--	--
Rm. 217 - Boy's Bathroom	Sink	Public Access	EDS-059	EDS-S158	5.7	None	--	--
Rm. 217 - Boy's Bathroom	Sink	Public Access	EDS-060	EDS-S159	1.1	None	--	--
Rm. 230A - Hallway/Vestibule	Sink	Public Access	EDS-062	EDS-S161	1.8	None	--	--
Rm. 230A - Hallway/Vestibule	Fountain	Public Access	EDS-074	EDS-F109	< 1.0	None	--	--
Rm. 230A - Hallway/Vestibule	Sink	Public Access	EDS-063	EDS-S162	1.9	None	--	--
Rm. 230A - Hallway/Vestibule	Sink	Public Access	EDS-064	EDS-S163	4.1	None	--	--
Rm. 231 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	EDS-065	EDS-S164	1.2	None	--	--
Rm. 232 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	EDS-066	EDS-S165	4.3	None	--	--

Original Sampling Notes (September 22, 2016 Event):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-011
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1616196
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture out of service
7. SCSD to replace fixture
8. SCSD to attach warning sign at fixture

Resampling Notes (April 13, 2017 Event):

1. Water samples collected By: SCSD Facilities Personnel
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1705145
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
5. Resample ID Numbers are indicated with a "B"
6. Fixture out of service.