

**SYRACUSE CITY SCHOOL DISTRICT
HUNTINGTON PK- GRADE 8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/25/2016 SAMPLE RESULTS (ppb)	09/25/2016 ORIGINAL ACTIONS	04/27/2017 RESAMPLE RESULTS (ppb)	04/27/2017 RESAMPLE ACTIONS
Rm. A103 - Hallway/Vestibule	Fountain	Public Access	SCSD-HN-073	HN-F200	< 1.0	None	--	--
Rm. A104 - Girl's Bathroom	Sink	Public Access	SCSD-HN-007	HN-S207	2.9	None	--	--
Rm. A104 - Girl's Bathroom	Sink	Public Access	SCSD-HN-008	HN-S208	2.1	None	--	--
Rm. A104 - Girl's Locker Room Bathroom	Sink	Public Access	SCSD-HN-018	HN-S218	2.2	None	--	--
Rm. A105 - Boy's Bathroom	Sink	Public Access	SCSD-HN-009	HN-S209	2.0	None	--	--
Rm. A105 - Boy's Bathroom	Sink	Public Access	SCSD-HN-010	HN-S210	5.5	None	--	--
Rm. A112 - Kitchen	Sink	Secured - SCSD Staff Only	SCSD-HN-001	HN-S201	< 1.0	None	--	--
Rm. A112 - Kitchen	Sink	Secured - SCSD Staff Only	SCSD-HN-002	HN-S202	< 1.0	None	--	--
Rm. A112 - Kitchen	Sink	Secured - SCSD Staff Only	SCSD-HN-003	HN-S203	1.4	None	--	--
Rm. A112 - Kitchen	Sink	Secured - SCSD Staff Only	SCSD-HN-004	HN-S204	1.2	None	--	--
Rm. A112 - Kitchen	Sink	Secured - SCSD Staff Only	SCSD-HN-005	HN-S205	2.1	None	--	--
Rm. A117A - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	SCSD-HN-006	HN-S206	1.9	None	--	--
Rm. A132A - Boy's Coach Bathroom	Sink	Secured - SCSD Staff Only	SCSD-HN-015 / HN-001	HN-S215 / HN-S215B	49.0	*See Note 6	6.1	None
Rm. A135 - Boy's Locker Room Bathroom	Sink	Public Access	SCSD-HN-014	HN-S214	1.4	None	--	--
Rm. A137 - Teacher's Resource Room	Sink	Secured - SCSD Staff Only	SCSD-HN-011	HN-S211	< 1.0	None	--	--
Rm. A137A - Teacher's Resource Bathroom	Sink	Secured - SCSD Staff Only	SCSD-HN-012	HN-S212	2.2	None	--	--
Rm. A137A - Teacher's Resource Bathroom	Sink	Secured - SCSD Staff Only	SCSD-HN-013	HN-S213	< 1.0	None	--	--
Rm. A139 - Gym	Fountain	Public Access	SCSD-HN-074	HN-F201	< 1.0	None	--	--
Rm. A139 - Gym	Fountain	Public Access	SCSD-HN-075	HN-F202	< 1.0	None	--	--
Rm. A146 - Girl's Coach Bathroom	Sink	Secured - SCSD Staff Only	SCSD-HN-016	HN-S216	4.0	None	--	--
Rm. A149 - Girl's Locker Room Bathroom	Sink	Public Access	SCSD-HN-017	HN-S217	< 1.0	None	--	--
Rm. A158 - Boy's Locker Room Bathroom	Sink	Public Access	SCSD-HN-019	HN-S219	< 1.0	None	--	--
Rm. A162A - Office Bathroom	Sink	Secured - SCSD Staff Only	SCSD-HN-020	HN-S220	1.3	None	--	--
Rm. A201 - Hallway/Corridor	Fountain	Public Access	SCSD-HN-078	HN-F206	< 1.0	None	--	--
Rm. A211 - Hallway/Vestibule	Sink	Public Access	SCSD-HN-024	HN-S224	1.1	None	--	--
Rm. A211 - Hallway/Vestibule	Sink	Public Access	SCSD-HN-025	HN-S225	1.1	None	--	--
Rm. A211 - Hallway/Vestibule	Sink	Public Access	SCSD-HN-026	HN-S226	1.1	None	--	--
Rm. A211 - Hallway/Vestibule	Sink	Public Access	SCSD-HN-027 / HN-002	HN-S227 / HN-S227B	70.0	*See Note 7	1.9	None
Rm. A240 - Classroom	Sink	Public Access	SCSD-HN-023	HN-S223	< 1.0	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT
HUNTINGTON PK- GRADE 8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/25/2016 SAMPLE RESULTS (ppb)	09/25/2016 ORIGINAL ACTIONS	04/27/2017 RESAMPLE RESULTS (ppb)	04/27/2017 RESAMPLE ACTIONS
Rm. B01 - Technology Room	Sink	Public Access	SCSD-HN-033	HN-S100	3.4	None	--	--
Rm. B01 - Technology Room	Sink	Public Access	SCSD-HN-034	HN-S101	4.0	None	--	--
Rm. B06 - Music Room	Sink	Public Access	SCSD-HN-040	HN-S107	3.3	None	--	--
Rm. B08A - Water Service Room	Hose Bib at Meter	Secured - SCSD Staff Only	SCSD-HN-032	HN-M100	45.0	*See Note 8	--	--
Rm. B20 - Hallway/Corridor	Fountain	Public Access	SCSD-HN-080	HN-F100	1.4	None	--	--
Rm. B20A - Boy's Bathroom	Sink	Public Access	SCSD-HN-035	HN-S102A	8.6	None	--	--
Rm. B20A - Boy's Bathroom	Sink	Public Access	SCSD-HN-036	HN-S102B	6.2	None	--	--
Rm. B20G - Girl's Bathroom	Sink	Public Access	SCSD-HN-037	HN-S104	6.5	None	--	--
Rm. B20G - Girl's Bathroom	Sink	Public Access	SCSD-HN-038	HN-S105	6.0	None	--	--
Rm. B20G - Girl's Bathroom	Sink	Public Access	SCSD-HN-039	HN-S106	3.2	None	--	--
Rm. B104 - Classroom	Sink	Public Access	SCSD-HN-051	HN-S119	< 1.0	None	--	--
Rm. B104A - Classroom Bathroom	Sink	Public Access	--	HN-S118	--	*See Note 9	--	--
Rm. B106 - Classroom	Sink	Public Access	SCSD-HN-053	HN-S121	< 1.0	None	--	--
Rm. B106A - Classroom Bathroom	Sink	Public Access	SCSD-HN-052	HN-S120	2.0	None	--	--
Rm. B108 - Classroom	Sink	Public Access	SCSD-HN-059	HN-S127	1.7	None	--	--
Rm. B115 - Classroom	Sink	Public Access	SCSD-HN-041	HN-S108	2.9	None	--	--
Rm. B119A - Hallway/Corridor	Fountain	Public Access	SCSD-HN-081	HN-F101	1.3	None	--	--
Rm. B119A - Hallway/Corridor	Fountain	Public Access	SCSD-HN-082	HN-F102	2.6	None	--	--
Rm. B119L - Hallway/Corridor	Fountain	Public Access	--	HN-F204	--	*See Note 10	--	--
Rm. B119L - Hallway/Corridor	Fountain	Public Access	SCSD-HN-077	HN-F205	4.0	None	--	--
Rm. B122 - Boy's Bathroom	Sink	Public Access	SCSD-HN-057	HN-S125	< 1.0	None	--	--
Rm. B122 - Boy's Bathroom	Sink	Public Access	SCSD-HN-058	HN-S126	< 1.0	None	--	--
Rm. B124 - Girl's Bathroom	Sink	Public Access	SCSD-HN-054 / HN-003	HN-S122 / HN-S122B	21.0	*See Note 11	<1.0	None
Rm. B124 - Girl's Bathroom	Sink	Public Access	SCSD-HN-055	HN-S123	6.1	None	--	--
Rm. B124 - Girl's Bathroom	Sink	Public Access	SCSD-HN-056	HN-S124	< 1.0	None	--	--
Rm. B129 - Staff Bathroom	Sink	Secured - SCSD Staff Only	SCSD-HN-021	HN-S221	4.2	None	--	--
Rm. B136 - Girl's Bathroom	Sink	Public Access	SCSD-HN-046	HN-S113	1.5	None	--	--
Rm. B136 - Girl's Bathroom	Sink	Public Access	SCSD-HN-047	HN-S114	< 1.0	None	--	--
Rm. B137 - Boy's Bathroom	Sink	Public Access	SCSD-HN-044	HN-S111	< 1.0	None	--	--

SYRACUSE CITY SCHOOL DISTRICT
HUNTINGTON PK- GRADE 8 SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/25/2016 SAMPLE RESULTS (ppb)	09/25/2016 ORIGINAL ACTIONS	04/27/2017 RESAMPLE RESULTS (ppb)	04/27/2017 RESAMPLE ACTIONS
Rm. B137 - Boy's Bathroom	Sink	Public Access	SCSD-HN-045	HN-S112	1.5	None	--	--
Rm. B140C - Office/Staff Bathroom	Sink	Secured - SCSD Staff Only	SCSD-HN-050	HN-S117	< 1.0	None	--	--
Rm. B140D - Office/Staff Bathroom	Sink	Secured - SCSD Staff Only	SCSD-HN-049	HN-S116	1.0	None	--	--
Rm. B140E - Mail Room	Sink	Secured - SCSD Staff Only	SCSD-HN-048	HN-S115	< 1.0	None	--	--
Rm. B142 - Nurse's Room	Sink	Public Access	SCSD-HN-043	HN-S110	1.3	None	--	--
Rm. B142C - Nurse's Bathroom	Sink	Public Access	SCSD-HN-042	HN-S109	1.6	None	--	--
Rm. B206 - Home & Careers Room	Sink	Public Access	SCSD-HN-060	HN-S128	1.6	None	--	--
Rm. B206 - Home & Careers Room	Sink	Public Access	SCSD-HN-061	HN-S129A	< 1.0	None	--	--
Rm. B207 - Classroom	Sink	Public Access	SCSD-HN-062	HN-S129B	< 1.0	None	--	--
Rm. B216 - Laboratory Room	Sink	Public Access	SCSD-HN-069	HN-S136	36.0	*See Note 12	--	--
Rm. B216 - Laboratory Room	Sink	Public Access	--	HN-S137	--	*See Note 13	--	--
Rm. B216 - Laboratory Room	Sink	Public Access	SCSD-HN-070	HN-S138	2.5	None	--	--
Rm. B216 - Laboratory Room	Sink	Public Access	--	HN-S139	--	*See Note 13	--	--
Rm. B218 - Boy's Bathroom	Sink	Public Access	SCSD-HN-063	HN-S130	< 1.0	None	--	--
Rm. B218 - Boy's Bathroom	Sink	Public Access	SCSD-HN-064	HN-S131	< 1.0	None	--	--
Rm. B218 - Art Room	Sink	Public Access	SCSD-HN-071	HN-S140	2.5	None	--	--
Rm. B218 - Art Room	Sink	Public Access	SCSD-HN-072	HN-S141	1.2	None	--	--
Rm. B221 - Girl's Bathroom	Sink	Public Access	SCSD-HN-065	HN-S132	14.0	None	--	--
Rm. B221 - Girl's Bathroom	Sink	Public Access	SCSD-HN-066	HN-S133	9.3	None	--	--
Rm. B221 - Girl's Bathroom	Sink	Public Access	SCSD-HN-067	HN-S134	3.0	None	--	--
Rm. B223 - Staff Bathroom	Sink	Secured - SCSD Staff Only	SCSD-HN-022	HN-S222	< 1.0	None	--	--
Rm. B226 - Girl's Bathroom	Sink	Public Access	SCSD-HN-028	HN-S228	< 1.0	None	--	--
Rm. B226 - Girl's Bathroom	Sink	Public Access	SCSD-HN-029	HN-S229	1.1	None	--	--
Rm. B227 - Boy's Bathroom	Sink	Public Access	SCSD-HN-030	HN-S230	2.3	None	--	--
Rm. B227 - Boy's Bathroom	Sink	Public Access	SCSD-HN-031	HN-S231	2.3	None	--	--
Rm. B229D - Library Office Room	Sink	Secured - SCSD Staff Only	SCSD-HN-068	HN-S135	1.9	None	--	--
Rm. B236 - Hallway/Corridor	Fountain	Public Access	SCSD-HN-079	HN-F207	< 1.0	None	--	--
Rm. B236 - Hallway/Corridor	Fountain	Public Access	SCSD-HN-083	HN-F103	< 1.0	None	--	--
Rm. N104 - Pool	Fountain	Public Access	SCSD-HN-076	HN-F203	3.1	None	--	--

SYRACUSE CITY SCHOOL DISTRICT HUNTINGTON PK- GRADE 8 SCHOOL

Original Sampling Notes (September 25, 2016 Event):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-008
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1618445
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. SCSD replaced fixture
7. SCSD replaced fixture
8. SCSD affixed warning sign at fixture
9. Fixture out-of-service
10. Fixture out-of-service
11. SCSD replaced fixture
12. SCSD removed fixture from service
13. Fixture out-of-service

Resampling Notes (April 27, 2017 Event):

1. Water samples collected By: SCSD Facilities Personnel
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1705889
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
5. Resample ID Numbers are indicated with a "B".