

SYRACUSE CITY SCHOOL DISTRICT
EXPEDITIONARY LEARNING CENTER MIDDLE SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/14/2016 SAMPLE RESULTS (ppb)	10/14/2016 ORIGINAL ACTIONS	05/05/2017 RESAMPLE RESULTS (ppb)	05/05/2017 RESAMPLE ACTIONS
Rm. 106 - Nurse's Office	Sink	Public Access	ELMS-017	ELMS-S316	6.0	None	--	--
Rm. 106A - Nurse's Office Bathroom	Sink	Public Access	ELMS-018	ELMS-S317	2.7	None	--	--
Rm. 110 - Hallway/Corridor	Fountain	Public Access	ELMS-012	ELMS-F311	< 1.0	None	--	--
Rm. 116A - Locker Room Bathroom	Sink	Public Access	ELMS-032	ELMS-S331	4.4	None	--	--
Rm. 119A - Classroom Bathroom	Sink	Public Access	ELMS-035	ELMS-S334	1.5	None	--	--
Rm. 120A - Classroom Bathroom	Sink	Public Access	ELMS-037	ELMS-S336	2.3	None	--	--
Rm. 123 - Hallway/Corridor	Fountain	Public Access	ELMS-033	ELMS-F332	< 1.0	None	--	--
Rm. 124 - Staff Bathroom	Sink	Secured - SCSD Staff Only	ELMS-038	ELMS-S337	1.7	None	--	--
Rm. 125A - Classroom Bathroom	Sink	Public Access	ELMS-036	ELMS-S335	2.0	None	--	--
Rm. 127A - Classroom Bathroom	Sink	Public Access	ELMS-034	ELMS-S333	< 1.0	None	--	--
Rm. 130A - Library Bathroom	Sink	Public Access	ELMS-031	ELMS-S330	9.1	None	--	--
Rm. 135 - Hallway/Corridor	Fountain	Public Access	ELMS-025	ELMS-F324	< 1.0	None	--	--
Rm. 137 - Girl's Locker Room Bathroom	Sink	Public Access	ELMS-026	ELMS-S325	5.4	None	--	--
Rm. 137 - Girl's Locker Room Bathroom	Sink	Public Access	ELMS-027	ELMS-S326	4.0	None	--	--
Rm. 143 - Gym Office	Sink	Secured - SCSD Staff Only	ELMS-030	ELMS-S329	6.9	None	--	--
Rm. 145 - Kitchen	Sink	Secured - SCSD Staff Only	ELMS-021	ELMS-S320	1.2	None	--	--
Rm. 145 - Kitchen	Sink	Secured - SCSD Staff Only	ELMS-022	ELMS-S321	1.9	None	--	--
Rm. 145 - Kitchen	Sink	Secured - SCSD Staff Only	ELMS-023 / ELMS-001	ELMS-S322 / ELMS-S322B	21.0	*See Note 6	<1.0	None
Rm. 145 - Kitchen	Sink	Secured - SCSD Staff Only	ELMS-024	ELMS-S323	3.5	None	--	--
Rm. 147 - Boy's Locker Room Bathroom	Sink	Public Access	ELMS-028	ELMS-S327	5.6	None	--	--
Rm. 147 - Boy's Locker Room Bathroom	Sink	Public Access	ELMS-029	ELMS-S328	8.3	None	--	--
Rm. 150 - Staff's Bathroom	Sink	Secured - SCSD Staff Only	ELMS-020	ELMS-S319	1.4	None	--	--
Rm. 154 - Kitchenette	Sink	Secured - SCSD Staff Only	ELMS-019 / ELMS-002	ELMS-S318 / ELMS-S318B	1500.0	*See Note 6	2.7	None
Rm. 165 - Break Room	Sink	Secured - SCSD Staff Only	ELMS-016	ELMS-S315	< 1.0	None	--	--
Rm. 165A - Break Room Bathroom	Sink	Secured - SCSD Staff Only	ELMS-014	ELMS-S313	6.1	None	--	--
Rm. 165B - Break Room Bathroom	Sink	Secured - SCSD Staff Only	ELMS-015 / ELMS-003	ELMS-S314 / ELMS-S314B	16.0	*See Note 6	7.5	None
Rm. 167 - Principal's Bathroom	Sink	Secured - SCSD Staff Only	ELMS-013	ELMS-S312	2.3	None	--	--
Rm. 168 - Hallway/Vestibule	Sink	Public Access	ELMS-010	ELMS-S309	7.6	None	--	--
Rm. 168 - Hallway/Vestibule	Sink	Public Access	ELMS-011	ELMS-S310	6.2	None	--	--

SYRACUSE CITY SCHOOL DISTRICT
EXPEDITIONARY LEARNING CENTER MIDDLE SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/14/2016 SAMPLE RESULTS (ppb)	10/14/2016 ORIGINAL ACTIONS	05/05/2017 RESAMPLE RESULTS (ppb)	05/05/2017 RESAMPLE ACTIONS
Rm. 172A - Classroom Bathroom	Sink	Public Access	ELMS-009	ELMS-S308	< 1.0	None	--	--
Rm. 176A - Classroom Bathroom	Sink	Public Access	ELMS-008	ELMS-S307	< 1.0	None	--	--
Rm. 178 - Classroom	Sink	Public Access	ELMS-005	ELMS-S304	1.3	None	--	--
Rm. 178 - Classroom	Sink	Public Access	ELMS-006	ELMS-S305	2.7	None	--	--
Rm. 178A - Classroom Bathroom	Sink	Public Access	ELMS-007	ELMS-S306	1.2	None	--	--
Rm. 182 - Hallway/Corridor	Fountain	Public Access	ELMS-004	ELMS-F303	< 1.0	None	--	--
Rm. 188 - Sprinkler/Meter Room	Hose Bib at Meter	Secured - SCSD Staff Only	ELMS-001	ELMS-M300	55.0	*See Note 7	--	--
Rm. 189 - Art Room	Sink	Public Access	ELMS-003	ELMS-S302	< 1.0	None	--	--
Rm. 190 - Kitchen	Sink	Secured - SCSD Staff Only	ELMS-002	ELMS-S301	2.1	None	--	--

Original Sampling Notes (October 14, 2016 Event):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-032
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620740
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. SCSD is to replace fixture
7. SCSD to post warning sign

Resampling Notes (May 5, 2017 Event):

1. Water samples collected By: SCSD Facilities Personnel
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1706475
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
5. Resample ID Numbers are indicated with a "B".