

SYRACUSE CITY SCHOOL DISTRICT  
CLARY MIDDLE SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/14/16 SAMPLE RESULTS (ppb)	10/14/16 ORIGINAL ACTIONS	05/05/17 SAMPLE RESULTS (ppb)	05/05/17 RESAMPLE ACTIONS	11/10/17 SAMPLE RESULTS (ppb)	11/10/17 RESAMPLE ACTIONS
Rm. 001 - Classroom	Sink	Public Access	--	CY-S114	--	*See Note 6	--	--	--	--
Rm. 001 - Classroom	Sink	Public Access	--	CY-S115	--	*See Note 6	--	--	--	--
Rm. 001D - Classroom	Fountain	Public Access	CY-069	CY-F105	1.3	None	--	--	--	--
Rm. 001E - Classroom	Sink	Public Access	CY-014	CY-S113	1.4	None	--	--	--	--
Rm. 002B - Main Office	Sink	Secured - SCSD Staff Only	CY-064	CY-S165	2.9	None	--	--	--	--
Rm. 004B - Nurse's Office Bathroom	Sink	Public Access	CY-059	CY-S160	7.0	None	--	--	--	--
Rm. 004D - Clinic Room	Sink	Public Access	CY-061	CY-S162	1.9	None	--	--	--	--
Rm. 005A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	CY-058	CY-S159	2.3	None	--	--	--	--
Rm. 005B - Staff Bathroom	Sink	Secured - SCSD Staff Only	CY-057	CY-S158	4.9	None	--	--	--	--
Rm. 008 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	CY-054	CY-S155	1.1	None	--	--	--	--
Rm. 008 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	CY-055	CY-S156	< 1.0	None	--	--	--	--
Rm. 022 - Boy's Bathroom	Sink	Public Access	CY-049	CY-S150	2.9	None	--	--	--	--
Rm. 022 - Boy's Bathroom	Sink	Public Access	CY-050	CY-S151	2.7	None	--	--	--	--
Rm. 022 - Boy's Bathroom	Sink	Public Access	CY-051	CY-S152	4.6	None	--	--	--	--
Rm. 022 - Boy's Bathroom	Sink	Public Access	CY-052	CY-S153	6.7	None	--	--	--	--
Rm. 022 - Boy's Bathroom	Sink	Public Access	CY-053	CY-S154	1.6	None	--	--	--	--
Rm. 023 - Girl's Bathroom	Sink	Public Access	CY-046	CY-S147	7.6	None	--	--	--	--
Rm. 023 - Girl's Bathroom	Sink	Public Access	CY-047	CY-S148	8.2	None	--	--	--	--
Rm. 023 - Girl's Bathroom	Sink	Public Access	CY-048	CY-S149	11.0	None	--	--	--	--
Rm. 029 - Boy's Bathroom	Sink	Public Access	CY-036	CY-S137	12.0	None	--	--	--	--
Rm. 029 - Boy's Bathroom	Sink	Public Access	CY-037/CY-001	CY-S138/CY S138B	17.0	*See Note 7	3.4	None	--	--
Rm. 029 - Boy's Bathroom	Sink	Public Access	CY-038	CY-S139	4.1	None	--	--	--	--
Rm. 029 - Boy's Bathroom	Sink	Public Access	CY-039	CY-S140	13.0	None	--	--	--	--
Rm. 029 - Boy's Bathroom	Sink	Public Access	CY-040/CY-002	CY-S141/CY S141B	18.0	*See Note 7	3.9	None	--	--
Rm. 030 - Girl's Bathroom	Sink	Public Access	CY-041	CY-S142	5.9	None	--	--	--	--
Rm. 030 - Girl's Bathroom	Sink	Public Access	CY-042	CY-S143	7.5	None	--	--	--	--
Rm. 030 - Girl's Bathroom	Sink	Public Access	CY-043	CY-S144	4.9	None	--	--	--	--
Rm. 030 - Girl's Bathroom	Sink	Public Access	CY-044	CY-S145	8.3	None	--	--	--	--
Rm. 030 - Girl's Bathroom	Sink	Public Access	CY-045	CY-S146	5.8	None	--	--	--	--

**SYRACUSE CITY SCHOOL DISTRICT**  
**CLARY MIDDLE SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/14/16 SAMPLE RESULTS (ppb)	10/14/16 ORIGINAL ACTIONS	05/05/17 SAMPLE RESULTS (ppb)	05/05/17 RESAMPLE ACTIONS	11/10/17 SAMPLE RESULTS (ppb)	11/10/17 RESAMPLE ACTIONS
Rm. 039 - Home & Careers Room	Sink	Public Access	CY-029	CY-S130	10.0	None	--	--	--	--
Rm. 039 - Home & Careers Room	Sink	Public Access	CY-030	CY-S131	13.0	None	--	--	--	--
Rm. 039 - Home & Careers Room	Sink	Public Access	CY-031	CY-S132	1.4	None	--	--	--	--
Rm. 042 - Home & Careers Room	Sink	Public Access	CY-032	CY-S133	1.3	None	--	--	--	--
Rm. 042 - Home & Careers Room	Sink	Public Access	CY-033	CY-S134	11.0	None	--	--	--	--
Rm. 042 - Home & Careers Room	Sink	Public Access	CY-034	CY-S135	8.5	None	--	--	--	--
Rm. 055 - Staff Locker Room Bathroom	Sink	Secured - SCSD Staff Only	CY-016	CY-S117	4.6	None	--	--	--	--
Rm. 056 - Staff Locker Room Bathroom	Sink	Secured - SCSD Staff Only	CY-015	CY-S116	8.1	None	--	--	--	--
Rm. 060 - Girl's Locker Room	Fountain	Public Access	CY-066	CY-F101	2.3	None	--	--	--	--
Rm. 068 - Boy's Locker Room	Fountain	Public Access	--	CY-F102	--	*See Note 6	--	--	--	--
Rm. 071 - Group Instruction Room	Sink	Public Access	CY-008	CY-S107	2.5	None	--	--	--	--
Rm. 076A - Classroom	Sink	Public Access	CY-013	CY-S112	1.5	None	--	--	--	--
Rm. 152 - Hallway/Corridor	Fountain	Public Access	CY-071	CY-F107	< 1.0	None	--	--	--	--
Rm. 153 - Hallway/Corridor	Fountain	Public Access	CY-072	CY-F108	2.1	None	--	--	--	--
Rm. 163 - Hallway/Corridor	Fountain	Public Access	CY-068	CY-F104	< 1.0	None	--	--	--	--
Rm. 202 - Hallway/Corridor	Fountain	Public Access	CY-065	CY-F100	1.4	None	--	--	--	--
Rm. 203 - Hallway/Corridor	Fountain	Public Access	CY-067	CY-F103	2.4	None	--	--	--	--
Rm. 208 - Men's Bathroom	Sink	Public Access	CY-009	CY-S108	3.0	None	--	--	--	--
Rm. 208 - Men's Bathroom	Sink	Public Access	CY-010	CY-S109	2.6	None	--	--	--	--
Rm. 210 - Women's Bathroom	Sink	Public Access	CY-011	CY-S110	2.8	None	--	--	--	--
Rm. 210 - Women's Bathroom	Sink	Public Access	CY-012	CY-S111	5.3	None	--	--	--	--
Rm. 217 - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	CY-007	CY-S106	7.9	None	--	--	--	--
Rm. 223 - Boy's Locker Room Bathroom	Sink	Public Access	CY-005	CY-S104	6.7	None	--	--	--	--
Rm. 223 - Boy's Locker Room Bathroom	Sink	Public Access	CY-006	CY-S105	5.4	None	--	--	--	--
Rm. 238 - Girl's Locker Room Bathroom	Sink	Public Access	CY-003	CY-S102	9.4	None	--	--	--	--
Rm. 238 - Girl's Locker Room Bathroom	Sink	Public Access	CY-004	CY-S103	6.6	None	--	--	--	--
Rm. 244 - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	CY-002	CY-S100	5.1	None	--	--	--	--
Rm. 245 - Boiler/Meter Room	Hose Bib at Meter	Secured - SCSD Staff Only	CY-001	CY-M100	2.2	None	--	--	--	--
Rm. 309A - Main Office Bathroom	Sink	Secured - SCSD Staff Only	CY-063	CY-S164	5.4	None	--	None	--	--
Rm. 309B - Main Office Bathroom	Sink	Secured - SCSD Staff Only	CY-062	CY-S163	12.0	None	--	None	--	--

SYRACUSE CITY SCHOOL DISTRICT  
CLARY MIDDLE SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/14/16 SAMPLE RESULTS (ppb)	10/14/16 ORIGINAL ACTIONS	05/05/17 SAMPLE RESULTS (ppb)	05/05/17 RESAMPLE ACTIONS	11/10/17 SAMPLE RESULTS (ppb)	11/10/17 RESAMPLE ACTIONS
Rm. 326 - Nurse's Office	Sink	Public Access	CY-060	CY-S161	1.2	None	--	None	--	--
Rm. 331 - Kitchen	Sink	Secured - SCSD Staff Only	CY-017	CY-S118	1.7	None	--	None	--	--
Rm. 331 - Kitchen	Sink	Secured - SCSD Staff Only	CY-018	CY-S119	1.2	None	--	None	--	--
Rm. 331 - Kitchen	Sink	Secured - SCSD Staff Only	CY-019	CY-S120	1.1	None	--	None	--	--
Rm. 331 - Kitchen	Sink	Secured - SCSD Staff Only	CY-020	CY-S121	2.9	None	--	None	--	--
Rm. 331 - Kitchen	Sink	Secured - SCSD Staff Only	CY-021	CY-S122	2.8	None	--	None	--	--
Rm. 331 - Kitchen	Sink	Secured - SCSD Staff Only	CY-022	CY-S123	< 1.0	None	--	None	--	--
Rm. 331 - Kitchen	Sink	Secured - SCSD Staff Only	CY-023	CY-S124	1.6	None	--	None	--	--
Rm. 331 - Kitchen	Kettle	Secured - SCSD Staff Only	CY-024	CY-S125	2.8	None	--	None	--	--
Rm. 331 - Kitchen	Kettle	Secured - SCSD Staff Only	CY-025	CY-S126	11.0	None	--	None	--	--
Rm. 331 - Kitchen	Steamer	Secured - SCSD Staff Only	CY-026	CY-S127	4.0	None	--	None	--	--
Rm. 331 - Kitchen	Steamer	Secured - SCSD Staff Only	CY-027	CY-S128	< 1.0	None	--	None	--	--
Rm. 339 - Kitchen	Sink	Secured - SCSD Staff Only	CY-028	CY-S129	2.7	None	--	None	--	--
Rm. 329 - Cafeteria	Fountain	Public Access	CY-070	CY-F106	< 1.0	None	--	None	--	--
Rm. 414 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	CY-056	CY-S157	3.0	None	--	None	--	--
Rm. 450 - Work Room	Sink	Secured - SCSD Staff Only	CY-035/CY-003	CY-S136/CY-S136B	58.0	*See Note 7	22.0	Re-Sample	<1.0	None

Original Sampling Notes (October 14, 2016):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-031
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620741
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture not operating
7. SCSD to replace fixture

Resampling Notes (May 5, 2017):

1. Water samples collected By: SCSD Facilities Personnel
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1706474; May 16, 2017
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
5. Resample ID Numbers are indicated with a "B".

Resampling Notes (November 10, 2017 Event):

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-042
2. Water samples analyzed by: Life Science Laboratories, Inc. - LSL Project ID No. 1718691; November 20, 2017
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.