

**SYRACUSE CITY SCHOOL DISTRICT  
ELMWOOD ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/27/16 SAMPLE RESULTS (ppb)	10/27/16 ORIGINAL ACTIONS	02/24/17 RESAMPLE RESULTS (ppb)	02/24/17 RESAMPLE ACTIONS	11/10/17 RESAMPLE RESULTS (ppb)	11/10/17 RESAMPLE ACTIONS
Rm. 04 - Kitchen	Sink	Secured - SCSD Staff Only	--	ELM-S201	--	*See Note 7	--	--	--	--
Rm. 04 - Kitchen	Sink	Secured - SCSD Staff Only	ELM-026 / ELM-001	ELM-S202 / ELM-S202B	23.0	*See Note 8	16.0	TBD	2.3	None
Rm. 04 - Kitchen	Sink	Secured - SCSD Staff Only	ELM-027 / ELM-002	ELM-S203 / ELM-S203B	70.0	*See Note 8	74.0	TBD	<1.0	None
Rm. 04 - Kitchen	Sink	Secured - SCSD Staff Only	--	ELM-S204	--	*See Note 7	--	--	--	--
Rm. 04 - Kitchen	Sink	Secured - SCSD Staff Only	ELM-028 / ELM-003	ELM-S205 / ELM-S205B	23.0	*See Note 8	24.0	TBD	2.8	None
Rm. 08 - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	ELM-025	ELM-M(S)200	5.3	None	--	--	--	--
Rm. 31A - Custodian's Bathroom	Sink	Secured - SCSD Staff Only	ELM-032	ELM-S211	1.9	None	--	--	--	--
Rm. 40 - Hallway/Vestibule	Fountain	Public Access	ELM-058	ELM-F201	1.1	None	--	--	--	--
Rm. 40 - Hallway/Vestibule	Sink	Public Access	--	ELM-S206	--	*See Note 7	--	--	--	--
Rm. 40 - Hallway/Vestibule	Sink	Public Access	ELM-029 / ELM-004	ELM-S207 / ELM-S207B	20.0	*See Note 8	69.0	TBD	<1.0	None
Rm. 40 - Hallway/Vestibule	Sink	Public Access	ELM-030	ELM-S208	5.1	None	--	--	--	--
Rm. 42 - Boy's Bathroom	Sink	Public Access	--	ELM-S210	--	*See Note 7	--	--	--	--
Rm. 44 - Girl's Bathroom	Sink	Public Access	ELM-031 / ELM-005	ELM-S209 / ELM-S209B	32.0	*See Note 8	5600.0	Removed	--	--
Rm. 47 - Staff Bathroom	Sink	Secured - SCSD Staff Only	ELM-008 / ELM-006	ELM-S109 / ELM-S109B	44.0	*See Note 8	30.0	TBD	<1.0	None
Rm. 55 - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	ELM-005 / ELM-007	ELM-S106 / ELM-S106B	19.0	*See Note 8	26.0	TBD	<1.0	None
Rm. 59 - Classroom	Sink	Public Access	ELM-001	ELM-S100	1.1	None	--	--	--	--
Rm. 59 - Classroom	Sink	Public Access	ELM-002	ELM-S101	12.0	None	--	--	--	--
Rm. 61 - Classroom	Sink	Public Access	ELM-003	ELM-S102	5.6	None	--	--	--	--
Rm. 61 - Classroom	Sink	Public Access	ELM-004	ELM-S103	3.7	None	--	--	--	--
Rm. 63 - Classroom	Sink	Public Access	ELM-006 / ELM-008	ELM-S107 / ELM-S107B	17.0	*See Note 8	88.0	TBD	<1.0	None
Rm. 63 - Classroom	Sink	Public Access	ELM-007 / ELM-009	ELM-S108 / ELM-S108B	18.0	*See Note 8	43.0	TBD	<1.0	None
Rm. 68 - Storage Room	Sink	Secured - SCSD Staff Only	--	ELM-S105	--	*See Note 7	--	--	--	--
Rm. 69 - PT Office	Sink	Secured - SCSD Staff Only	--	ELM-S104	--	*See Note 7	--	--	--	--
Rm. 105 - Resource Room	Sink	Public Access	ELM-021 / ELM-013	ELM-S125 / ELM-S125B	43.0	*See Note 8	38.0	TBD	<1.0	None
Rm. 106 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	ELM-019	ELM-S122	1.9	None	--	--	--	--
Rm. 107 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	ELM-020	ELM-S124	9.2	None	--	--	--	--
Rm. 109 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	--	ELM-S123	--	*See Note 7	--	--	--	--
Rm. 121A - Parent Room	Sink	Secured - SCSD Staff Only	ELM-016	ELM-S119	2.4	None	--	--	--	--
Rm. 124 - Hallway/Vestibule	Fountain	Public Access	ELM-022	ELM-F101	< 1.0	None	--	--	--	--

**SYRACUSE CITY SCHOOL DISTRICT  
ELMWOOD ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/27/16 SAMPLE RESULTS (ppb)	10/27/16 ORIGINAL ACTIONS	02/24/17 RESAMPLE RESULTS (ppb)	02/24/17 RESAMPLE ACTIONS	11/10/17 RESAMPLE RESULTS (ppb)	11/10/17 RESAMPLE ACTIONS
Rm. 124 - Hallway/Vestibule	Sink	Public Access	ELM-013	ELM-S115	11.0	None	--	--	--	--
Rm. 124 - Hallway/Vestibule	Sink	Public Access	ELM-014 / ELM-011	ELM-S116 / ELM-S116B	15.0	*See Note 8	34.0	TBD	<1.0	None
Rm. 124 - Hallway/Vestibule	Sink	Public Access	ELM-015	ELM-S117	2.6	None	--	--	--	--
Rm. 125 - Boy's Bathroom	Sink	Public Access	--	ELM-S118	--	*See Note 7	--	--	--	--
Rm. 126 - Girl's Bathroom	Sink	Public Access	--	ELM-S114	--	*See Note 7	--	--	--	--
Rm. 133 - Staff Bathroom	Sink	Public Access	ELM-037	ELM-S216	4.2	None	--	--	--	--
Rm. 134 - Classroom	Sink	Public Access	ELM-033	ELM-S212	9.7	None	--	--	--	--
Rm. 135 - Classroom Bathroom	Sink	Public Access	ELM-034	ELM-S213	1.8	None	--	--	--	--
Rm. 136 - Classroom	Sink	Public Access	ELM-035	ELM-S214	13.0	None	--	--	--	--
Rm. 137 - Classroom	Sink	Public Access	ELM-036 / ELM-012	ELM-S215 / ELM-S215B	34.0	*See Note 8	20.0	TBD	<1.0	None
Rm. 138 - Classroom	Sink	Public Access	ELM-038	ELM-S217	8.8	None	--	--	--	--
Rm. 139 - Hallway/Corridor	Fountain	Public Access	ELM-023	ELM-F102	< 1.0	None	--	--	--	--
Rm. 139 - Hallway/Corridor	Fountain	Public Access	ELM-024	ELM-F103	< 1.0	None	--	--	--	--
Rm. 142A - Classroom	Sink	Public Access	ELM-012	ELM-S113	3.8	None	--	--	--	--
Rm. 142A - Classroom	Fountain	Public Access	--	ELM-F100	--	*See Note 7	--	--	--	--
Rm. 142B - Resource Room	Sink	Public Access	ELM-009 / ELM-010	ELM-S110 / ELM-S110B	31.0	*See Note 8	41.0	TBD	<1.0	None
Rm. 146 - Classroom	Sink	Public Access	ELM-010	ELM-S111	3.7	None	--	--	--	--
Rm. 146 - Classroom	Sink	Public Access	ELM-011	ELM-S112	5.7	None	--	--	--	--
Rm. 153 - Nurse's Office Bathroom	Sink	Public Access	ELM-018	ELM-S121	2.4	None	--	--	--	--
Rm. 156 - Main Office Bathroom	Sink	Secured - SCSD Staff Only	ELM-017	ELM-S120	6.8	None	--	--	--	--
Rm. 205 - Staff Bathroom	Sink	Secured - SCSD Staff Only	ELM-048	ELM-S228	4.4	None	--	--	--	--
Rm. 208 - Classroom	Sink	Public Access	ELM-052	ELM-S232	11.0	None	--	--	--	--
Rm. 212 - Work Room	Sink	Secured - SCSD Staff Only	ELM-057	ELM-S237	4.2	None	--	--	--	--
Rm. 215 - Hallway/Vestibule	Sink	Public Access	ELM-053 / ELM-014	ELM-S233 / ELM-S233B	15.0	*See Note 8	26.0	TBD	<1.0	None
Rm. 215 - Hallway/Vestibule	Sink	Public Access	ELM-054	ELM-S234	9.8	None	--	--	--	--
Rm. 215 - Hallway/Vestibule	Sink	Public Access	ELM-055	ELM-S235	7.7	None	--	--	--	--
Rm. 215 - Hallway/Vestibule	Sink	Public Access	ELM-056	ELM-S236	3.8	None	--	--	--	--
Rm. 215 - Hallway/Vestibule	Fountain	Public Access	ELM-060	ELM-F203	< 1.0	None	--	--	--	--
Rm. 221 - Classroom	Sink	Public Access	ELM-051	ELM-S231	9.3	None	--	--	--	--

**SYRACUSE CITY SCHOOL DISTRICT**  
**ELMWOOD ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/27/16 SAMPLE RESULTS (ppb)	10/27/16 ORIGINAL ACTIONS	02/24/17 RESAMPLE RESULTS (ppb)	02/24/17 RESAMPLE ACTIONS	11/10/17 RESAMPLE RESULTS (ppb)	11/10/17 RESAMPLE ACTIONS
Rm. 224 - Classroom	Sink	Public Access	ELM-044	ELM-S223	12.0	None	--	--	--	--
Rm. 225 - Classroom	Sink	Public Access	ELM-041 / ELM-015	ELM-S220 / ELM-S220B	65.0	*See Note 8	21.0	TBD	1.5	None
Rm. 226 - Classroom	Sink	Public Access	ELM-039	ELM-S218	14.0	None	--	--	--	--
Rm. 227 - Classroom	Sink	Public Access	ELM-040	ELM-S219	3.1	None	--	--	--	--
Rm. 228 - Classroom	Sink	Public Access	ELM-042	ELM-S221	6.0	None	--	--	--	--
Rm. 229 - Classroom	Sink	Public Access	ELM-043 / ELM-016	ELM-S222 / ELM-S222B	20.0	*See Note 8	34.0	TBD	<1.0	None
Rm. 230 - Hallway/Vestibule	Fountain	Public Access	ELM-059	ELM-F202	< 1.0	None	--	--	--	--
Rm. 230 - Hallway/Vestibule	Sink	Public Access	ELM-045 / ELM-017	ELM-S224 / ELM-S224B	27.0	*See Note 8	21.0	TBD	<1.0	None
Rm. 230 - Hallway/Vestibule	Sink	Public Access	ELM-046 / ELM-018	ELM-S225 / ELM-S225B	62.0	*See Note 8	20.0	TBD	<1.0	None
Rm. 230 - Hallway/Vestibule	Sink	Public Access	--	ELM-S226	--	*See Note 9	--	--	--	--
Rm. 230 - Hallway/Vestibule	Sink	Public Access	ELM-047	ELM-S227	68.0	*See Note 8	--	--	<1.0	None
Rm. 233 - Classroom	Sink	Public Access	ELM-049	ELM-S229	11.0	None	--	--	--	--
Rm. 235 - Classroom	Sink	Public Access	ELM-050	ELM-S230	9.0	None	--	--	--	--

Original Sampling Notes (October 27, 2016 Event):

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-042
2. Water samples analyzed by: Life Science Laboratories, Inc. - LSL Project ID No. 1621047; December 27 and 28, 2016
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. This school facility is currently vacant. Resampling of fixture locations where exceedances were discovered will be performed prior to re-occupancy.
7. Fixture not operating
8. SCSD is to replace fixture
9. Fixture out of service

Resampling Notes (February 24, 2017 Event):

1. Water samples collected by: SCSD Facilities Personnel
2. Water samples analyzed by: Life Science Laboratories, Inc. - LSL Project ID No. 1702681; March 1, 2017
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
5. Resample ID Numbers are indicated with a "B".

Resampling Notes (November 10, 2017 Event):

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-042
2. Water samples analyzed by: Life Science Laboratories, Inc. - LSL Project ID No. 1718686; November 16, 2017
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.