

SYRACUSE CITY SCHOOL DISTRICT  
HW SMITH PK - GRADE 8 SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/25/16 SAMPLE RESULTS (ppb)	09/25/16 ORIGINAL ACTIONS	04/27/17 SAMPLE RESULTS (ppb)	04/27/17 ORIGINAL ACTIONS	11/10/17 SAMPLE RESULTS (ppb)	11/10/17 ORIGINAL ACTIONS
Rm. A-A - Classroom	Sink	Public Access	HWS-045	HW-S308	2.8	None	--	--	--	--
Rm. A-A - Classroom	Sink	Public Access	HWS-046	HW-S309	2.4	None	--	--	--	--
Rm. A-01 - ESL Room	Sink	Public Access	HWS-043	HW-S306	< 1.0	None	--	--	--	--
Rm. A-01 - ESL Room	Sink	Public Access	HWS-044	HW-S307	< 1.0	None	--	--	--	--
Rm. A-02 - Classroom	Sink	Public Access	--	HW-S312	--	*See Note 6	--	--	--	--
Rm. A-02 - Classroom	Sink	Public Access	HWS-049	HW-S313	1.7	None	--	--	--	--
Rm. A-03 - Classroom	Sink	Public Access	HWS-051	HW-S315	1.2	None	--	--	--	--
Rm. A-03 - Classroom	Fountain	Public Access	HWS-122	HW-F302	1.7	None	--	--	--	--
Rm. A-03B - Classroom Bathroom	Sink	Public Access	HWS-050	HW-S314	1.0	None	--	--	--	--
Rm. A-04 - Classroom	Sink	Public Access	HWS-052	HW-S316	2.4	None	--	--	--	--
Rm. A-04 - Classroom	Fountain	Public Access	HWS-123	HW-F303	1.3	None	--	--	--	--
Rm. A-04B - Classroom Bathroom	Sink	Public Access	HWS-053	HW-S317	< 1.0	None	--	--	--	--
Rm. A-05 - Classroom	Sink	Public Access	HWS-055	HW-S319	1.4	None	--	--	--	--
Rm. A-05 - Classroom	Fountain	Public Access	HWS-125	HW-F305	1.9	None	--	--	--	--
Rm. A-05B - Classroom Bathroom	Sink	Public Access	HWS-054	HW-S318	1.0	None	--	--	--	--
Rm. A-06 - Classroom	Sink	Public Access	HWS-058	HW-S322	1.2	None	--	--	--	--
Rm. A-06 - Classroom	Fountain	Public Access	HWS-126	HW-F306	< 1.0	None	--	--	--	--
Rm. A-06B - Classroom Bathroom	Sink	Public Access	HWS-057	HW-S321	< 1.0	None	--	--	--	--
Rm. A-07 - Classroom	Sink	Public Access	HWS-060	HW-S324	1.4	None	--	--	--	--
Rm. A-07 - Classroom	Fountain	Public Access	HWS-127	HW-F307	< 1.0	None	--	--	--	--
Rm. A-07B - Classroom Bathroom	Sink	Public Access	HWS-059	HW-S323	1.1	None	--	--	--	--
Rm. A-12 - Teacher's Work Room	Sink	Secured - SCSD Staff Only	HWS-056	HW-S320	2.9	None	--	--	--	--
Rm. A-16 - Staff Bathroom	Sink	Secured - SCSD Staff Only	HWS-048 / HW-001	HW-S311 / HW-S311B	110.0	*See Note 7	1.1	None	--	--
Rm. A-17 - Staff Bathroom	Sink	Secured - SCSD Staff Only	HWS-047	HW-S310	2.3	None	--	--	--	--
Rm. A-22D - Storage Room	Sink	Secured - SCSD Staff Only	HWS-040	HW-S303	3.7	None	--	--	--	--
Rm. A-30A - Hallway/Corridor	Fountain	Public Access	HWS-124	HW-F304	< 1.0	None	--	--	--	--
Rm. A-30D - Hallway/Vestibule	Sink	Public Access	HWS-038	HW-S301	< 1.0	None	--	--	--	--
Rm. A-30D - Hallway/Vestibule	Sink	Public Access	HWS-039	HW-S302	2.0	None	--	--	--	--
Rm. A-30D - Hallway/Vestibule	Sink	Public Access	HWS-041	HW-S304	2.4	None	--	--	--	--

SYRACUSE CITY SCHOOL DISTRICT  
HW SMITH PK - GRADE 8 SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/25/16 SAMPLE RESULTS (ppb)	09/25/16 ORIGINAL ACTIONS	04/27/17 SAMPLE RESULTS (ppb)	04/27/17 ORIGINAL ACTIONS	11/10/17 SAMPLE RESULTS (ppb)	11/10/17 ORIGINAL ACTIONS
Rm. A-30D - Hallway/Vestibule	Sink	Public Access	HWS-042	HW-S305	< 1.0	None	--	--	--	--
Rm. A-30H - Hallway/Corridor	Fountain	Public Access	HWS-121	HW-F301	< 1.0	None	--	--	--	--
Rm. A-33 - Classroom	Sink	Public Access	HWS-005	HW-S104	< 1.0	None	--	--	--	--
Rm. A-33 - Classroom	Fountain	Public Access	HWS-113	HW-F101	< 1.0	None	--	--	--	--
Rm. A-33B - Classroom Bathroom	Sink	Public Access	HWS-004	HW-S103	< 1.0	None	--	--	--	--
Rm. A-34 - Staff Bathroom	Sink	Secured - SCSD Staff Only	HWS-006	HW-S105	1.2	None	--	--	--	--
Rm. A-35 - Classroom	Sink	Public Access	HWS-003	HW-S102	< 1.0	None	--	--	--	--
Rm. A-35 - Classroom	Fountain	Public Access	HWS-112 / HW-002	HW-F100 / HW-F100B	20.0	*See Note 8	<1.0	None	--	--
Rm. A-35B - Classroom Bathroom	Sink	Public Access	HWS-002	HW-S101	1.1	None	--	--	--	--
Rm. A100B - Girl's Bathroom	Sink	Public Access	HWS-007	HW-S106	< 1.0	None	--	--	--	--
Rm. A100C - Girl's Bathroom	Sink	Public Access	HWS-008	HW-S107	1.1	None	--	--	--	--
Rm. A100D - Boy's Bathroom	Sink	Public Access	HWS-009	HW-S108	6.5	None	--	--	--	--
Rm. A100E - Boy's Bathroom	Sink	Public Access	HWS-010	HW-S109	2.0	None	--	--	--	--
Rm. A100J - Hallway/Corridor	Fountain	Public Access	HWS-128	HW-F308	< 1.0	None	--	--	--	--
Rm. A100K - Hallway/Corridor	Fountain	Public Access	HWS-114	HW-F102	< 1.0	None	--	--	--	--
Rm. A100K - Hallway/Corridor	Fountain	Public Access	HWS-115	HW-F103	< 1.0	None	--	--	--	--
Rm. A104 - Office	Sink	Secured - SCSD Staff Only	HWS-011	HW-S110	< 1.0	None	--	--	--	--
Rm. A106 - Copy Room	Sink	Secured - SCSD Staff Only	HWS-013	HW-S112	2.9	None	--	--	--	--
Rm. A106A - Staff Bathroom	Sink	Secured - SCSD Staff Only	HWS-012	HW-S111	< 1.0	None	--	--	--	--
Rm. A106A - Staff Bathroom	Sink	Secured - SCSD Staff Only	HWS-076	HW-S341	1.4	None	--	--	--	--
Rm. A108 - Art Room	Sink	Public Access	HWS-014	HW-S113	3.7	None	--	--	--	--
Rm. A108 - Art Room	Sink	Public Access	HWS-015	HW-S114	6.0	None	--	--	--	--
Rm. A108 - Art Room	Sink	Public Access	HWS-016	HW-S115	4.1	None	--	--	--	--
Rm. A108C - Home & Careers Room	Sink	Public Access	HWS-072	HW-S337	< 1.0	None	--	--	--	--
Rm. A108C - Home & Careers Room	Sink	Public Access	HWS-073	HW-S338	1.4	None	--	--	--	--
Rm. A108C - Home & Careers Room	Sink	Public Access	HWS-074	HW-S339	1.5	None	--	--	--	--
Rm. A108C - Home & Careers Room	Sink	Public Access	HWS-075	HW-S340	3.5	None	--	--	--	--
Rm. A109 - Science Room	Sink	Public Access	HWS-068	HW-S333	9.4	None	--	--	--	--

**SYRACUSE CITY SCHOOL DISTRICT**  
**HW SMITH PK - GRADE 8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/25/16 SAMPLE RESULTS (ppb)	09/25/16 ORIGINAL ACTIONS	04/27/17 SAMPLE RESULTS (ppb)	04/27/17 ORIGINAL ACTIONS	11/10/17 SAMPLE RESULTS (ppb)	11/10/17 ORIGINAL ACTIONS
Rm. A109 - Science Room	Sink	Public Access	HWS-069	HW-S334	3.4	None	--	--	--	--
Rm. A109 - Science Room	Sink	Public Access	HWS-070	HW-S335	1.3	None	--	--	--	--
Rm. A109B - Boy's Bathroom	Sink	Public Access	HWS-066	HW-S331	1.4	None	--	--	--	--
Rm. A110 - Technology Shop	Sink	Public Access	HWS-071	HW-S336	< 1.0	None	--	--	--	--
Rm. A112 - Classroom	Sink	Public Access	HWS-077	HW-S342	1.4	None	--	--	--	--
Rm. A112B - Girl's Bathroom	Sink	Public Access	HWS-064	HW-S329	< 1.0	None	--	--	--	--
Rm. A113 - Science Room	Sink	Public Access	HWS-061	HW-S326	< 1.0	None	--	--	--	--
Rm. A113 - Science Room	Sink	Public Access	HWS-062	HW-S327	1.0	None	--	--	--	--
Rm. A113 - Science Room	Sink	Public Access	HWS-063	HW-S328	5.7	None	--	--	--	--
Rm. A113B - Boy's Bathroom	Sink	Public Access	HWS-067	HW-S332	1.1	None	--	--	--	--
Rm. A120A - Girl's Bathroom	Sink	Public Access	HWS-065	HW-S330	1.0	None	--	--	--	--
Rm. A122 - Classroom	Sink	Public Access	HWS-078	HW-S343	1.9	None	--	--	--	--
Rm. A123 - Classroom	Sink	Public Access	HWS-079	HW-S344	1.7	None	--	--	--	--
Rm. A125 - Classroom	Sink	Public Access	HWS-080	HW-S345	2.9	None	--	--	--	--
Rm. A200 - Girl's Bathroom	Sink	Public Access	HWS-103	HW-S369	< 1.0	None	--	--	--	--
Rm. A200B - Hallway/Corridor	Fountain	Public Access	HWS-131	HW-F311	< 1.0	None	--	--	--	--
Rm. A200B - Hallway/Corridor	Fountain	Public Access	HWS-132	HW-F312	< 1.0	None	--	--	--	--
Rm. A200C - Girl's Bathroom	Sink	Public Access	HWS-102	HW-S368	< 1.0	None	--	--	--	--
Rm. A200D - Boy's Bathroom	Sink	Public Access	HWS-101	HW-S367	< 1.0	None	--	--	--	--
Rm. A200E - Boy's Bathroom	Sink	Public Access	HWS-099	HW-S365	1.0	None	--	--	--	--
Rm. A202B - Classroom	Sink	Public Access	HWS-100	HW-S366	3.3	None	--	--	--	--
Rm. A205A - Hallway/Corridor	Fountain	Public Access	HWS-130	HW-F310	< 1.0	None	--	--	--	--
Rm. A206B - Staff's Bathroom	Sink	Secured - SCSD Staff Only	HWS-098	HW-S364	1.7	None	--	--	--	--
Rm. A208A - Copy Room	Sink	Secured - SCSD Staff Only	HWS-097	HW-S363	1.9	None	--	--	--	--
Rm. A209B - Boy's Bathroom	Sink	Public Access	HWS-096	HW-S362	1.0	None	--	--	--	--
Rm. A214A - Girl's Bathroom	Sink	Public Access	HWS-094	HW-S360	1.0	None	--	--	--	--
Rm. A215B - Boy's Bathroom	Sink	Public Access	HWS-095	HW-S361	< 1.0	None	--	--	--	--
Rm. A216B - Girl's Bathroom	Sink	Public Access	HWS-093	HW-S359	1.2	None	--	--	--	--
Rm. B-03 - Staff Bathroom	Sink	Secured - SCSD Staff Only	HWS-001	HW-S100	5.6	None	--	--	--	--

**SYRACUSE CITY SCHOOL DISTRICT**  
**HW SMITH PK - GRADE 8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/25/16 SAMPLE RESULTS (ppb)	09/25/16 ORIGINAL ACTIONS	04/27/17 SAMPLE RESULTS (ppb)	04/27/17 ORIGINAL ACTIONS	11/10/17 SAMPLE RESULTS (ppb)	11/10/17 ORIGINAL ACTIONS
Rm. B104 - Hallway/Corridor	Fountain	Public Access	HWS-129	HW-F309	< 1.0	None	--	--	--	--
Rm. B106 - Staff Bathroom	Sink	Secured - SCSD Staff Only	HWS-026	HW-S126	< 1.0	None	--	--	--	--
Rm. B106 - Staff Bathroom	Sink	Secured - SCSD Staff Only	HWS-027	HW-S127	1.1	None	--	--	--	--
Rm. B109 - Boy's Locker Room	Fountain	Public Access	HWS-117	HW-F105	< 1.0	None	--	--	--	--
Rm. B112 - Boy's Bathroom	Sink	Public Access	HWS-017 / HW-003	HW-S116 / HW-S116B	31.0	*See Note 9	27.0	TBD	<1.0	None
Rm. B116A - Boy's Coach Bathroom	Sink	Secured - SCSD Staff Only	HWS-018	HW-S117	2.7	None	--	--	--	--
Rm. B119A - Girl's Coach Bathroom	Sink	Secured - SCSD Staff Only	HWS-019	HW-S118	< 1.0	None	--	--	--	--
Rm. B123 - Girl's Bathroom	Sink	Public Access	--	HW-S119	--	Fixture not operating	--	--	--	--
Rm. B126 - Girl's Locker Room	Fountain	Public Access	HWS-118	HW-F106	< 1.0	None	--	--	--	--
Rm. B128 - OT/PT Room	Sink	Public Access	HWS-021	HW-S121	< 1.0	None	--	--	--	--
Rm. B128A - OT/PT Room Bathroom	Sink	Public Access	HWS-020	HW-S120	< 1.0	None	--	--	--	--
Rm. B131 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	HWS-082	HW-S347	2.4	None	--	--	--	--
Rm. B132 - Dental Room	Sink	Public Access	HWS-081	HW-S346	< 1.0	None	--	--	--	--
Rm. B133 - Health Center Bathroom	Sink	Public Access	HWS-084	HW-S349	2.1	None	--	--	--	--
Rm. B134 - Hallway/Corridor	Fountain	Public Access	HWS-116	HW-F104	< 1.0	None	--	--	--	--
Rm. B135B - Exam Room	Sink	Public Access	HWS-087	HW-S353	2.1	None	--	--	--	--
Rm. B136 - Health Center	Sink	Public Access	HWS-083	HW-S348	1.1	None	--	--	--	--
Rm. B138 - Nurse's Room	Sink	Public Access	HWS-086	HW-S352	1.4	None	--	--	--	--
Rm. B138A - Nurse's Bathroom	Sink	Public Access	HWS-085	HW-S351	8.0	None	--	--	--	--
Rm. B147 - Staff Office Bathroom	Sink	Secured - SCSD Staff Only	HWS-090	HW-S356	2.5	None	--	--	--	--
Rm. B149 - Main Office	Sink	Secured - SCSD Staff Only	HWS-091	HW-S357	8.2	None	--	--	--	--
Rm. B164 - Library Bathroom	Sink	Public Access	HWS-092	HW-S358	< 1.0	None	--	--	--	--
Rm. B168 - Conference Room	Sink	Secured - SCSD Staff Only	HWS-089	HW-S355	1.7	None	--	--	--	--
Rm. B171 - Staff Bathroom	Sink	Secured - SCSD Staff Only	HWS-088	HW-S354	< 1.0	None	--	--	--	--
Rm. B172 - Work Room	Sink	Secured - SCSD Staff Only	HWS-025	HW-S125	< 1.0	None	--	--	--	--
Rm. B173 - Work Room Bathroom	Sink	Secured - SCSD Staff Only	HWS-024	HW-S124	< 1.0	None	--	--	--	--
Rm. B174 - Staff Bathroom	Sink	Secured - SCSD Staff Only	HWS-023	HW-S123	< 1.0	None	--	--	--	--
Rm. B176 - Classroom Bathroom	Sink	Public Access	HWS-022	HW-S122	1.4	None	--	--	--	--
Rm. B204 - Hallway/Corridor	Fountain	Public Access	HWS-120	HW-F108	< 1.0	None	--	--	--	--



**SYRACUSE CITY SCHOOL DISTRICT**  
**HW SMITH PK - GRADE 8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/25/16 SAMPLE RESULTS (ppb)	09/25/16 ORIGINAL ACTIONS	04/27/17 SAMPLE RESULTS (ppb)	04/27/17 ORIGINAL ACTIONS	11/10/17 SAMPLE RESULTS (ppb)	11/10/17 ORIGINAL ACTIONS
Rm. B209 - Hallway/Corridor	Fountain	Public Access	HWS-119	HW-F107	< 1.0	None	--	--	--	--
Rm. B210 - Girl's Bathroom	Sink	Public Access	HWS-032	HW-S132	1.6	None	--	--	--	--
Rm. B210 - Girl's Bathroom	Sink	Public Access	HWS-033	HW-S133	1.3	None	--	--	--	--
Rm. B210 - Girl's Bathroom	Sink	Public Access	HWS-034	HW-S134	1.8	None	--	--	--	--
Rm. B211 - Boy's Bathroom	Sink	Public Access	HWS-035	HW-S135	1.2	None	--	--	--	--
Rm. B211 - Boy's Bathroom	Sink	Public Access	HWS-036	HW-S136	2.0	None	--	--	--	--
Rm. B220 - Band Room	Sink	Public Access	HWS-037	HW-S137	2.4	None	--	--	--	--
Rm. B222 - Kitchen	Sink	Secured - SCSD Staff Only	HWS-104	HW-S370	< 1.0	None	--	--	--	--
Rm. B222 - Kitchen	Sink	Secured - SCSD Staff Only	HWS-105	HW-S371	4.3	None	--	--	--	--
Rm. B222 - Kitchen	Sink	Secured - SCSD Staff Only	HWS-106	HW-S372	2.5	None	--	--	--	--
Rm. B222 - Kitchen	Sink	Secured - SCSD Staff Only	HWS-107	HW-S373	1.5	None	--	--	--	--
Rm. B222 - Kitchen	Sink	Secured - SCSD Staff Only	HWS-108	HW-S374	< 1.0	None	--	--	--	--
Rm. B222 - Kitchen	Sink	Secured - SCSD Staff Only	HWS-109	HW-S375	< 1.0	None	--	--	--	--
Rm. B222B - Kitchen Serving Area	Sink	Secured - SCSD Staff Only	HWS-111	HW-S377	< 1.0	None	--	--	--	--
Rm. B224 - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	HWS-110	HW-S376	2.3	None	--	--	--	--
Rm. B231A - Classroom Bathroom	Sink	Public Access	HWS-031	HW-S131	< 1.0	None	--	--	--	--
Rm. B232A - Classroom Bathroom	Sink	Public Access	HWS-030	HW-S130	< 1.0	None	--	--	--	--
Rm. B233A - Classroom Bathroom	Sink	Public Access	HWS-029	HW-S129	< 1.0	None	--	--	--	--

Original Sampling Notes (September 25, 2016 Event):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-019
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620560
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture not operating
7. SCSD is to replace fixture
8. This is a new fixture. SCSD has removed fixture, will flush and resample for confirmation.
9. SCSD is to replace fixture

Resampling Notes (April 27, 2017 Event):

1. Water samples collected By: SCSD Facilities Personnel
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1705888
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
5. Resample ID Numbers are indicated with a "B".

Resampling Notes (November 10, 2017 Event):

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-042
2. Water samples analyzed by: Life Science Laboratories, Inc. - LSL Project ID No. 1718692; November 20, 2017
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.