

SYRACUSE CITY SCHOOL DISTRICT
FRAZER PK-GRADE 8 SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/24/16 RESAMPLE RESULTS (ppb)	09/24/16 RESAMPLE ACTIONS	11/22/17 RESAMPLE RESULTS (ppb)	11/22/17 RESAMPLE ACTIONS
Rm. 000 - Hallway/Vestibule	Fountain	Public Access	--	FR-F104	--	See Note 6	<1.0	None
Rm. 000 - Hallway/Vestibule	Fountain	Public Access	FR-022	FR-F105	< 1.0	None	--	--
Rm. 000A - Hallway Corridor	Fountain	Public Access	FR-002	FR-F100	1.1	None	--	--
Rm. 000A - Hallway Corridor	Fountain	Public Access	FR-003	FR-F101	< 1.0	None	--	--
Rm. 0T1A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	FR-005	FR-S101	8.3	None	--	--
Rm. 0T1B - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	FR-004	FR-S100	3.2	None	--	--
Rm. 002B - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	FR-024	FR-S118	4.2	None	--	--
Rm. 002C - Girl's Locker Room	Sink	Public Access	FR-025	FR-S119	2.2	None	--	--
Rm. 002C - Girl's Locker Room	Sink	Public Access	FR-026	FR-S120	5.0	None	--	--
Rm. 002C - Girl's Locker Room	Sink	Public Access	FR-027	FR-S121	4.3	None	--	--
Rm. 003B - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	FR-023	FR-S117	5.4	None	--	--
Rm. 003C - Boy's Locker Room	Sink	Public Access	FR-019	FR-S114	2.7	None	--	--
Rm. 003C - Boy's Locker Room	Sink	Public Access	FR-020	FR-S115	2.1	None	--	--
Rm. 003C - Boy's Locker Room	Sink	Public Access	FR-021	FR-S116	14.0	None	--	--
Rm. 05B - Technology Room	Sink	Public Access	FR-015	FR-S110	5.8	None	--	--
Rm. 007 - Lounge	Sink	Secured - SCSD Staff Only	FR-016	FR-S111	< 1.0	None	--	--
Rm. 007A - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	FR-017	FR-S112	2.4	None	--	--
Rm. 007B - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	FR-018	FR-S113	< 1.0	None	--	--
Rm. 008A - Cafeteria	Fountain	Public Access	FR-006	FR-F102	3.9	None	--	--
Rm. 008A - Cafeteria	Fountain	Public Access	-	FR-F103	-	See Note 6	<1.0	None
Rm. 008E - Kitchen	Sink	Secured - SCSD Staff Only	FR-007	FR-S102	< 1.0	None	--	--
Rm. 008E - Kitchen	Sink	Secured - SCSD Staff Only	FR-008	FR-S103	< 1.0	None	--	--
Rm. 008E - Kitchen	Sink	Secured - SCSD Staff Only	FR-009	FR-S104	1.7	None	--	--
Rm. 008E - Kitchen	Sink	Secured - SCSD Staff Only	FR-010	FR-S105	2.4	None	--	--
Rm. 008E - Kitchen	Sink	Secured - SCSD Staff Only	FR-011	FR-S106	1.8	None	--	--
Rm. 008J - Kitchen Staff Bathroom	Sink	Secured - SCSD Staff Only	FR-012	FR-S107	1.2	None	--	--
Rm. 008K - Custodian's Bathroom	Sink	Secured - SCSD Staff Only	FR-013	FR-S108	2.6	None	--	--
Rm. 009 - Technology Room	Sink	Public Access	FR-014	FR-S109	3.3	None	--	--
Rm. 014 - Mechanical/Meter Room	Hose Bib at Meter	Secured - SCSD Staff Only	FR-001	FR-M100	35.0	* See Note 9	<1.0	See Note 5

SYRACUSE CITY SCHOOL DISTRICT
FRAZER PK-GRADE 8 SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/24/16 RESAMPLE RESULTS (ppb)	09/24/16 RESAMPLE ACTIONS	11/22/17 RESAMPLE RESULTS (ppb)	11/22/17 RESAMPLE ACTIONS
Rm. 1T1 - Hallway/Vestibule	Sink	Public Access	FR-056	FR-S141	< 1.0	None	--	--
Rm. 1T1 - Hallway/Vestibule	Sink	Public Access	FR-057	FR-S142	< 1.0	None	--	--
Rm. 1T1 - Hallway/Vestibule	Sink	Public Access	FR-058	FR-S143	5.9	None	--	--
Rm. 1T2 - Hallway/Vestibule	Sink	Public Access	FR-044	FR-S134	2.3	None	--	--
Rm. 1T2 - Hallway/Vestibule	Sink	Public Access	FR-045	FR-S135	11.0	None	--	--
Rm. 1T2 - Hallway/Vestibule	Sink	Public Access	FR-046	FR-S136	< 1.0	None	--	--
Rm. 100B - Hallway/Corridor	Fountain	Public Access	FR-053	FR-F113	< 1.0	None	--	--
Rm. 100B - Hallway/Corridor	Fountain	Public Access	FR-054	FR-F114	< 1.0	None	--	--
Rm. 100B - Hallway/Corridor	Fountain	Public Access	FR-055	FR-F115	< 1.0	None	--	--
Rm. 100H - Hallway/Corridor	Fountain	Public Access	FR-047	FR-F111	< 1.0	None	--	--
Rm. 101 - Classroom	Sink	Public Access	FR-038	FR-S130	< 1.0	None	--	--
Rm. 101 - Classroom	Fountain	Public Access	FR-039	FR-F109	3.1	None	--	--
Rm. 101A - Classroom	Sink	Public Access	FR-037	FR-S129	59.0	* See Note 8	<1.0	None
Rm. 101J - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	FR-040	FR-S131	2.5	None	--	--
Rm. 101K - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	FR-041	FR-S132	< 1.0	None	--	--
Rm. 102A - Nurse's Bathroom	Sink	Public Access	FR-035	FR-S127	3.1	None	--	--
Rm. 102B - Exam Room	Sink	Public Access	FR-036	FR-S128	5.8	None	--	--
Rm. 105 - Special Education Room	Sink	Public Access	FR-034	FR-S126	< 1.0	None	--	--
Rm. 106 - Classroom	Sink	Public Access	FR-032	FR-S125	< 1.0	None	--	--
Rm. 106 - Classroom	Fountain	Public Access	FR-033	FR-F108	2.0	None	--	--
Rm. 106A - Classroom Bathroom	Sink	Public Access	FR-031	FR-S124	13.0	None	--	--
Rm. 107 - Classroom	Sink	Public Access	FR-029	FR-S123	23.0	* See Note 8	<1.0	None
Rm. 107 - Classroom	Fountain	Public Access	FR-030	FR-F107	3.5	None	--	--
Rm. 107A - Classroom Bathroom	Sink	Public Access	FR-028	FR-S122	6.0	None	--	--
Rm. 116 - Resource Room	Sink	Public Access	FR-062	FR-S147	< 1.0	None	--	--
Rm. 117C - Work Room	Sink	Secured - SCSD Staff Only	FR-061	FR-S146	< 1.0	None	--	--
Rm. 118 - Work Room	Sink	Secured - SCSD Staff Only	FR-060	FR-S145	< 1.0	None	--	--
Rm. 118A - Work Room Bathroom	Sink	Secured - SCSD Staff Only	FR-059	FR-S144	2.8	None	--	--
Rm. 130 - Classroom	Sink	Public Access	FR-051	FR-S139	1.6	None	--	--

SYRACUSE CITY SCHOOL DISTRICT
FRAZER PK-GRADE 8 SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/24/16 RESAMPLE RESULTS (ppb)	09/24/16 RESAMPLE ACTIONS	11/22/17 RESAMPLE RESULTS (ppb)	11/22/17 RESAMPLE ACTIONS
Rm. 131A - Class Bathroom	Sink	Public Access	FR-052	FR-S140	3.8	None	--	--
Rm. 131A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	FR-049	FR-S138	3.0	None	--	--
Rm. 131B - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	FR-048	FR-S137	3.2	None	--	--
Rm. 134B - Classroom Bathroom	Sink	Public Access	FR-042	FR-S133	4.2	None	--	--
Rm. 142 - Classroom	Fountain	Public Access	FR-043	FR-F110	< 1.0	None	--	--
Rm. L-10 - Hallway/Corridor	Fountain	Public Access	FR-050	FR-F112	< 1.0	None	--	--
Rm. 200 - Computer Lab	Sink	Public Access	FR-073	FR-S158	< 1.0	None	--	--
Rm. 200A - Hallway/Corridor	Fountain	Public Access	FR-084	FR-F120	< 1.0	None	<1.0	None
Rm. 200A - Hallway/Corridor	Fountain	Public Access	FR-085	FR-F121	< 1.0	None	<1.0	None
Rm. 200A - Dark Room	Sink	Public Access	FR-072	FR-S157	830.0	* See Note 7	--	See Note 6
Rm. 200A - Hallway/Corridor	Fountain	Public Access	--	FR-F119	--	See Note 6	<1.0	None
Rm. 200D - Hallway/Corridor	Fountain	Public Access	--	FR-F118	--	See Note 6	<1.0	None
Rm. 200H - Hallway/Corridor	Fountain	Public Access	--	FR-F116	--	See Note 6	<1.0	None
Rm. 200H - Hallway/Corridor	Fountain	Public Access	FR-077	FR-F117	< 1.0	None	--	--
Rm. 203A - Work Room Bathroom	Sink	Secured - SCSD Staff Only	FR-070	FR-S155	1.6	None	--	--
Rm. 211 - Work Room	Sink	Secured - SCSD Staff Only	FR-069	FR-S154	4.6	None	--	--
Rm. 214 - Laboratory Room	Sink	Public Access	FR-065	FR-S150	2.4	None	--	--
Rm. 214 - Laboratory Room	Sink	Public Access	FR-066	FR-S151	3.0	None	--	--
Rm. 214 - Laboratory Room	Sink	Public Access	FR-067	FR-S152	< 1.0	None	--	--
Rm. 214 - Laboratory Room	Sink	Public Access	FR-068	FR-S153	1.2	None	--	--
Rm. 217 - Home & Careers Room	Sink	Public Access	FR-063	FR-S148	< 1.0	None	--	--
Rm. 217 - Home & Careers Room	Sink	Public Access	FR-064	FR-S149	< 1.0	None	--	--
Rm. 230 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	FR-079	FR-S163	4.3	None	--	--
Rm. 231 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	FR-078	FR-S162	3.9	None	--	--
Rm. 231 - Classroom Bathroom	Sink	Public Access	FR-080	FR-S164	2.6	None	--	--
Rm. 249 - Art Room	Sink	Public Access	FR-071	FR-S156	1.1	None	--	--
Rm. 2T1 - Hallway/Vestibule	Sink	Public Access	FR-081	FR-S165	4.3	None	--	--
Rm. 2T1 - Hallway/Vestibule	Sink	Public Access	FR-082	FR-S166	< 1.0	None	--	--
Rm. 2T1 - Hallway/Vestibule	Sink	Public Access	FR-083	FR-S167	23.0	* See Note 8	<1.0	None

SYRACUSE CITY SCHOOL DISTRICT
FRAZER PK-GRADE 8 SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	09/24/16 RESAMPLE RESULTS (ppb)	09/24/16 RESAMPLE ACTIONS	11/22/17 RESAMPLE RESULTS (ppb)	11/22/17 RESAMPLE ACTIONS
Rm. 2T2 - Hallway/Vestibule	Sink	Public Access	FR-074	FR-S159	3.9	None	--	--
Rm. 2T2 - Hallway/Vestibule	Sink	Public Access	FR-075	FR-S160	< 1.0	None	--	--
Rm. 2T2 - Hallway/Vestibule	Sink	Public Access	FR-076	FR-S161	4.7	None	--	--

Original Sampling Notes (September 24, 2016):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-013
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1619253
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture not operating.
7. SCSD is to remove fixture from service.
8. SCSD is to replace fixture.
9. SCSD is to post warning sign.

Resampling Notes (November 22, 2017 Event):

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-042
2. Water samples analyzed by: Life Science Laboratories, Inc. - LSL Project ID No. 1719313; November 28, 2017
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
5. Water sample was collected from sink faucet in meter room.
6. Fixture and service lines disconnected.