

SYRACUSE CITY SCHOOL DISTRICT
LEVY K-8 SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/27/16 SAMPLE RESULTS (ppb)	10/27/16 ORIGINAL ACTIONS	03/03/17 RESAMPLE RESULTS (ppb)	03/03/17 RESAMPLE ACTIONS	11/10/17 RESAMPLE RESULTS (ppb)	11/10/17 RESAMPLE ACTIONS
Rm. B05 - Boiler/Meter Room	Hose Bib at Meter	Secured - SCSD Staff Only	LY-031	LY-M200	2.4	None	--	--	--	--
Rm. 108 - Classroom	Sink	Public Access	LY-049	LY-S218	7.4	None	--	--	--	--
Rm. 109A - Classroom	Sink	Public Access	LY-048	LY-S217	7.4	None	--	--	--	--
Rm. 111A - Hallway/Corridor	Fountain	Public Access	LY-067	LY-F205	6.0	None	--	--	--	--
Rm. 114 - Girl's Bathroom	Sink	Public Access	LY-045	LY-S214	7.6	None	--	--	--	--
Rm. 114 - Girl's Bathroom	Sink	Public Access	LY-046	LY-S215	2.8	None	--	--	--	--
Rm. 114 - Girl's Bathroom	Sink	Public Access	LY-047	LY-S216	7.5	None	--	--	--	--
Rm. 117 - Boy's Bathroom	Sink	Public Access	LY-042	LY-S211	6.3	None	--	--	--	--
Rm. 117 - Boy's Bathroom	Sink	Public Access	LY-043	LY-S212	2.8	None	--	--	--	--
Rm. 117 - Boy's Bathroom	Sink	Public Access	LY-044	LY-S213	4.2	None	--	--	--	--
Rm. 119 - Hallway/Corridor	Fountain	Public Access	LY-066	LY-F204	3.3	None	--	--	--	--
Rm. 120 - Hallway/Corridor	Fountain	Public Access	LY-064	LY-F202	1.2	None	--	--	--	--
Rm. 121A - Classroom	Fountain	Public Access	LY-065	LY-F203	< 1.0	None	--	--	--	--
Rm. 121A - Classroom	Sink	Public Access	LY-039	LY-S208	8.3	None	--	--	--	--
Rm. 125A - Staff Bathroom	Sink	Secured - SCSD Staff Only	LY-035	LY-S204	5.3	None	--	--	--	--
Rm. 125D - Work Room	Sink	Secured - SCSD Staff Only	LY-034	LY-S203	10.0	None	--	--	--	--
Rm. 126 - Guidance Office	Sink	Public Access	LY-033	LY-S202	3.8	None	--	--	--	--
Rm. 129C-1 - Work Room	Sink	Secured - SCSD Staff Only	LY-038	LY-S207	6.8	None	--	--	--	--
Rm. 129E - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	LY-037	LY-S206	7.3	None	--	--	--	--
Rm. 129F - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	LY-036	LY-S205	2.0	None	--	--	--	--
Rm. 132A - Clinic Office	Sink	Public Access	LY-040	LY-S209	1.1	None	--	--	--	--
Rm. 132B - Clinic Bathroom	Sink	Public Access	LY-041 / LY-001	LY-S210 / LY-S210B	49.0	*See Note 6	5.9	None	--	--
Rm. 134 - Adult Bathroom	Sink	Public Access	LY-032 / LY-002	LY-S201 / LY-S201B	16.0	*See Note 6	19.0	Re-Sample	<1.0	None
Rm. 135A - Hallway/Corridor	Fountain	Public Access	-	LY-F201	-	Fixture not operating	--	--	--	--
Rm. 136 - Boy's Bathroom	Sink	Public Access	LY-001	LY-S100	< 1.0	None	--	--	--	--
Rm. 141 - Girl's Locker Room	Sink	Public Access	LY-002	LY-S101	3.9	None	--	--	--	--
Rm. 141 - Girl's Locker Room	Sink	Public Access	LY-003	LY-S102	9.5	None	--	--	--	--
Rm. 141B - Girl's Coach Bathroom	Sink	Secured - SCSD Staff Only	LY-004 / LY-003	LY-S103 / LY-S103B	15.0	*See Note 6	15.0	None	--	--
Rm. 142 - Hallway/Corridor	Fountain	Public Access	LY-028	LY-F100	< 1.0	None	--	--	--	--

SYRACUSE CITY SCHOOL DISTRICT
LEVY K-8 SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/27/16 SAMPLE RESULTS (ppb)	10/27/16 ORIGINAL ACTIONS	03/03/17 RESAMPLE RESULTS (ppb)	03/03/17 RESAMPLE ACTIONS	11/10/17 RESAMPLE RESULTS (ppb)	11/10/17 RESAMPLE ACTIONS
Rm. 145 - Boy's Locker Room	Fountain	Public Access	LY-029 / LY-004	LY-F101 / LY-F101B	60.0	*See Note 6	2.6	None	--	--
Rm. 145 - Boy's Locker Room	Sink	Public Access	LY-007 / LY-005	LY-S106 / LY-S106B	25.0	*See Note 6	25.0	Re-Sample	<1.0	None
Rm. 145 - Boy's Locker Room	Sink	Public Access	LY-010 / LY-006	LY-S109 / LY-S109B	71.0	*See Note 6	33.0	Removed	--	--
Rm. 145A-1 - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	LY-005 / LY-007	LY-S104 / LY-S104B	20.0	*See Note 6	3.9	None	--	--
Rm. 145B-1 - Boy's Coach Bathroom	Sink	Secured - SCSD Staff Only	LY-006	LY-S105	4.4	None	--	--	--	--
Rm. 145D - Boy's Locker Room Bathroom	Sink	Public Access	LY-009 / LY-008	LY-S108 / LY-S108B	18.0	*See Note 6	6.6	None	--	--
Rm. 145F - Boy's Shower	Sink	Public Access	LY-008	LY-S107	6.8	None	--	--	--	--
Rm. 151 - Kitchen	Sink	Secured - SCSD Staff Only	LY-016	LY-S115	5.3	None	--	--	--	--
Rm. 151 - Kitchen	Sink	Secured - SCSD Staff Only	LY-017	LY-S116	4.0	None	--	--	--	--
Rm. 151 - Kitchen	Sink	Secured - SCSD Staff Only	LY-018	LY-S117	11.0	None	--	--	--	--
Rm. 151 - Kitchen	Sink	Secured - SCSD Staff Only	LY-019	LY-S118	13.0	None	--	--	--	--
Rm. 151 - Kitchen	Steamer	Secured - SCSD Staff Only	LY-021	LY-S120	1.4	None	--	--	--	--
Rm. 151B - Staff Lockers	Sink	Secured - SCSD Staff Only	LY-015	LY-S114	3.6	None	--	--	--	--
Rm. 152 - Receiving Room	Sink	Secured - SCSD Staff Only	LY-020	LY-S119	12.0	None	--	--	--	--
Rm. 154 - Cafeteria	Fountain	Public Access	--	LY-F102	--	Fixture not operating	--	--	--	--
Rm. 154C - Boy's Bathroom	Sink	Public Access	LY-013	LY-S112	12.0	None	--	--	--	--
Rm. 154C - Boy's Bathroom	Sink	Public Access	LY-014	LY-S113	2.2	None	--	--	--	--
Rm. 154D - Girl's Bathroom	Sink	Public Access	LY-011	LY-S110	3.4	None	--	--	--	--
Rm. 154D - Girl's Bathroom	Sink	Public Access	LY-012	LY-S111	1.8	None	--	--	--	--
Rm. 211A - Hallway/Corridor	Fountain	Public Access	LY-068	LY-F206	5.3	None	--	--	--	--
Rm. 213 - Girl's Bathroom	Sink	Public Access	LY-053 / LY-009	LY-S222 / LY-S222B	26.0	*See Note 6	12.0	None	--	--
Rm. 213 - Girl's Bathroom	Sink	Public Access	LY-054 / LY-010	LY-S223 / LY-S223B	46.0	*See Note 6	37.0	Re-Sample	<1.0	None
Rm. 213 - Girl's Bathroom	Sink	Public Access	LY-055	LY-S224	13.0	None	--	--	--	--
Rm. 215 - Boy's Bathroom	Sink	Public Access	LY-050	LY-S219	6.3	None	--	--	--	--
Rm. 215 - Boy's Bathroom	Sink	Public Access	LY-051	LY-S220	6.3	None	--	--	--	--
Rm. 215 - Boy's Bathroom	Sink	Public Access	LY-052	LY-S221	6.9	None	--	--	--	--
Rm. 221 - Classroom	Sink	Public Access	LY-023	LY-S122	13.0	None	--	--	--	--
Rm. 221 - Classroom	Sink (hot water only)	Public Access	LY-024	LY-S123	210.0	*See Note 6	--	Re-Sample	<1.0	None
Rm. 230 - Hallway/Corridor	Fountain	Public Access	LY-030	LY-F103	7.8	None	--	--	--	--

SYRACUSE CITY SCHOOL DISTRICT
LEVY K-8 SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/27/16 SAMPLE RESULTS (ppb)	10/27/16 ORIGINAL ACTIONS	03/03/17 RESAMPLE RESULTS (ppb)	03/03/17 RESAMPLE ACTIONS	11/10/17 RESAMPLE RESULTS (ppb)	11/10/17 RESAMPLE ACTIONS
Rm. 231 - Staff Bathroom	Sink	Secured - SCSD Staff Only	LY-022	LY-S121	3.0	None	--	--	--	--
Rm. 311 - Hallway/Corridor	Fountain	Public Access	LY-069	LY-F207	4.8	None	--	--	--	--
Rm. 311B - Hallway/Corridor	Fountain	Public Access	LY-070	LY-F208	1.8	None	--	--	--	--
Rm. 313 - Girl's Bathroom	Sink	Public Access	LY-061 / LY-011	LY-S230 / LY-S230B	23.0	*See Note 6	6.9	None	--	--
Rm. 313 - Girl's Bathroom	Sink	Public Access	LY-062	LY-S231	6.5	None	--	--	--	--
Rm. 313 - Girl's Bathroom	Sink	Public Access	LY-063 / LY-012	LY-S232 / LY-S232B	28.0	*See Note 6	5.3	None	--	--
Rm. 315A - Teacher's Resource Bathroom	Sink	Secured - SCSD Staff Only	LY-060 / LY-013	LY-S229 / LY-S229B	16.0	*See Note 6	7.5	None	--	--
Rm. 317 - Boy's Bathroom	Sink	Public Access	LY-056 / LY-014	LY-S225 / LY-S225B	140.0	*See Note 6	4.5	None	--	--
Rm. 317 - Boy's Bathroom	Sink	Public Access	LY-057	LY-S226	3.2	None	--	--	--	--
Rm. 317 - Boy's Bathroom	Sink	Public Access	LY-058	LY-S227	8.7	None	--	--	--	--
Rm. 319 - Art Room	Sink	Public Access	LY-059	LY-S228	5.8	None	--	--	--	--
Rm. 321 - Staff Bathroom	Sink	Secured - SCSD Staff Only	LY-027 / LY-015	LY-S126 / LY-S126B	5.4	None	13.0	None	--	--
Rm. 322 - Staff Bathroom	Sink	Secured - SCSD Staff Only	LY-026	LY-S125	25.0	*See Note 6	--	Re-Sample	--	See Note 5
Rm. 323 - Teacher's Resource	Sink	Public Access	LY-025 / LY-016	LY-S124 / LY-S124B	16.0	*See Note 6	11.0	None	--	--

Original Sampling Notes (October 27, 2016 Event):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-041
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620931
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Building vacant, SCSD to re-sample prior to re-occupancy.

Resampling Notes (March 3, 2017 Event):

1. Water samples collected By: SCSD Facilities Personnel
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1703006
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
5. Resample ID Numbers are indicated with a "B"

Resampling Notes (November 10, 2017 Event):

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-042
2. Water samples analyzed by: Life Science Laboratories, Inc. - LSL Project ID No. 1718689; November 20, 2017
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
5. This staff bathroom is removed from service.