

**SYRACUSE CITY SCHOOL DISTRICT
HENNINGER HIGH SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/09/16 SAMPLE RESULTS (ppb)	10/09/16 ORIGINAL ACTIONS	01/13/18 SAMPLE RESULTS (ppb)	01/13/18 ORIGINAL ACTIONS
Rm. 001 - Classroom	Sink	Public Access	HR-093	HR-S513	2.4	None	--	--
Rm. 002 - Technology Shop	Sink	Public Access	HR-092	HR-S512	7.6	None	--	--
Rm. 003 - Technology Room	Sink	Public Access	HR-094	HR-S514	3.7	None	--	--
Rm. 003 - Technology Room	Sink	Public Access	HR-095	HR-S515	500.0	*See Note 6	1.7	None
Rm. 004 - Technology Shop	Sink	Public Access	HR-096	HR-S516	< 1.0	None	--	--
Rm. 004 - Technology Shop	Sink	Public Access	HR-097	HR-S517	1.0	None	--	--
Rm. 007 - Classroom	Sink	Public Access	HR-090	HR-S510	3.3	None	--	--
Rm. 008 - Classroom	Sink	Public Access	HR-089	HR-S509	1.1	None	--	--
Rm. 009 - Staff Women's Locker Bathroom	Sink	Secured - SCSD Staff Only	HR-098	HR-S518	4.2	None	--	--
Rm. 009 - Staff Women's Locker Bathroom	Sink	Secured - SCSD Staff Only	HR-099	HR-S519	4.4	None	--	--
Rm. 017 - Storage Room	Sink	Secured - SCSD Staff Only	HR-091	HR-S511	1.1	None	--	--
Rm. 020 - Staff Men's Locker Bathroom	Sink	Secured - SCSD Staff Only	HR-100	HR-S520	16.0	*See Note 6	<1.0	None
Rm. 020 - Staff Men's Locker Bathroom	Sink	Secured - SCSD Staff Only	HR-101	HR-S521	2.7	None	--	--
Rm. 030 - Mechanical/Meter Room	Hose Bib at Meter	Secured - SCSD Staff Only	HR-059	HR-M200	11.0	None	--	--
Rm. 044 - Hallway/Corridor	Fountain	Public Access	HR-127	HR-F504	< 1.0	None	--	--
Rm. 044 - Hallway/Corridor	Fountain	Public Access	HR-128	HR-F505	2.0	None	--	--
Rm. Rm. 047A - Hallway/Vestibule	Fountain	Public Access	HR-126	HR-F503	1.1	None	--	--
Rm. 047B - Hallway/Vestibule	Fountain	Public Access	HR-124	HR-F501	1.1	None	--	--
Rm. 049 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-085	HR-S500	1.8	None	--	--
Rm. 049 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-086	HR-S506	1.2	None	--	--
Rm. 050 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-087	HR-S507	< 1.0	None	--	--
Rm. 050 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-088	HR-S508	1.9	None	--	--
Rm. 051 - Hallway/Corridor	Fountain	Public Access	HR-125	HR-F502	1.4	None	--	--
Rm. 064A - Storage Room Bathroom	Sink	Secured - SCSD Staff Only	HR-030	HR-S129	< 1.0	None	--	--
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	HR-031	HR-S130	3.7	None	--	--
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	HR-032	HR-S131	2.7	None	--	--
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	HR-033	HR-S132	1.6	None	--	--
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	HR-034	HR-S133	2.6	None	--	--
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	HR-035	HR-S134	2.5	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT
HENNINGER HIGH SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/09/16 SAMPLE RESULTS (ppb)	10/09/16 ORIGINAL ACTIONS	10/09/16 SAMPLE RESULTS (ppb)	10/09/16 ORIGINAL ACTIONS
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	HR-036	HR-S135	4.2	None	--	--
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	HR-037	HR-S136	3.0	None	--	--
Rm. 068 - Kitchen	Sink	Secured - SCSD Staff Only	HR-038	HR-S137	1.4	None	--	--
Rm. 068 - Kitchen	Steamer	Secured - SCSD Staff Only	HR-039	HR-S138	1.1	None	--	--
Rm. 068 - Kitchen	Steamer	Secured - SCSD Staff Only	HR-040	HR-S139	2.8	None	--	--
Rm. 069 - Cafeteria 'B'	Fountain	Public Access	HR-115	HR-F106	< 1.0	None	--	--
Rm. 069 - Cafeteria 'B'	Fountain	Public Access	HR-116	HR-F107	< 1.0	None	--	--
Rm. 071A - Hallway/Corridor	Fountain	Public Access	HR-117	HR-F108	5.3	None	--	--
Rm. 072 - Boy's Locker Room	Sink	Public Access	HR-052	HR-S151	9.8	None	--	--
Rm. 077 - Boy's Bathroom	Sink	Public Access	HR-050	HR-S149	3.0	None	--	--
Rm. 078 - Girl's Locker Room	Sink	Public Access	HR-053	HR-S152	18.0	*See Note 7	--	--
Rm. 079 - Girl's Bathroom	Sink	Public Access	HR-045	HR-S144	5.7	None	--	--
Rm. 086 - Music/Vocal Room	Sink	Public Access	HR-051	HR-S150	5.1	None	--	--
Rm. 100A - Office Bathroom	Sink	Secured - SCSD Staff Only	HR-025	HR-S124	4.2	None	--	--
Rm. 103 - Classroom	Sink	Public Access	HR-046	HR-S145	4.9	None	--	--
Rm. 103 - Classroom	Sink	Public Access	HR-047	HR-S146	4.2	None	--	--
Rm. 103 - Classroom	Sink	Public Access	HR-048	HR-S147	11.0	None	--	--
Rm. 103 - Classroom	Sink	Public Access	HR-049	HR-S148	2.1	None	--	--
Rm. 103A - Work Area	Sink	Public Access	HR-044	HR-S143	4.4	None	--	--
Rm. 104 - Home & Careers Room	Sink	Public Access	HR-041	HR-S140	2.5	None	--	--
Rm. 104 - Home & Careers Room	Sink	Public Access	HR-042	HR-S141	1.8	None	--	--
Rm. 104 - Home & Careers Room	Sink	Public Access	HR-043	HR-S142	3.3	None	--	--
Rm. 123A - Career Center Room	Sink	Public Access	HR-028	HR-S127	1.5	None	--	--
Rm. 132 - Hallway/Corridor	Fountain	Public Access	HR-109	HR-F100	6.9	None	--	--
Rm. 132 - Hallway/Corridor	Fountain	Public Access	HR-110	HR-F101	1.3	None	--	--
Rm. 133 - Boy's Bathroom	Sink	Public Access	HR-008	HR-S107	5.8	None	--	--
Rm. 133 - Boy's Bathroom	Sink	Public Access	HR-009	HR-S108	3.0	None	--	--
Rm. 133 - Boy's Bathroom	Sink	Public Access	HR-010	HR-S109	3.3	None	--	--
Rm. 133 - Boy's Bathroom	Sink	Public Access	HR-011	HR-S110	2.6	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT
HENNINGER HIGH SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/09/16 SAMPLE RESULTS (ppb)	10/09/16 ORIGINAL ACTIONS	10/09/16 SAMPLE RESULTS (ppb)	10/09/16 ORIGINAL ACTIONS
Rm. 133 - Boy's Bathroom	Sink	Public Access	HR-012	HR-S111	2.9	None	--	--
Rm. 133 - Boy's Bathroom	Sink	Public Access	HR-013	HR-S112	1.9	None	--	--
Rm. 135 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-007	HR-S106	3.4	None	--	--
Rm. 136 - Girl's Bathroom	Sink	Public Access	HR-001	HR-S100	2.5	None	--	--
Rm. 136 - Girl's Bathroom	Sink	Public Access	HR-002	HE-S101	2.6	None	--	--
Rm. 136 - Girl's Bathroom	Sink	Public Access	HR-003	HR-S102	3.3	None	--	--
Rm. 136 - Girl's Bathroom	Sink	Public Access	HR-004	HR-S103	3.8	None	--	--
Rm. 136 - Girl's Bathroom	Sink	Public Access	HR-005	HR-S104	4.9	None	--	--
Rm. 136 - Girl's Bathroom	Sink	Public Access	HR-006	HR-S105	3.7	None	--	--
Rm. 146 - Clinic Bathroom	Sink	Public Access	HR-021	HR-S120	4.1	None	--	--
Rm. 149 - Health Service Room	Sink	Public Access	HR-022	HR-S121	3.4	None	--	--
Rm. 159 - Boy's Bathroom	Sink	Public Access	HR-029	HR-S128	1.7	None	--	--
Rm. 162 - Girl's Bathroom	Sink	Public Access	HR-026	HR-S125	3.0	None	--	--
Rm. 162 - Girl's Bathroom	Sink	Public Access	HR-027	HR-S126	3.5	None	--	--
Rm. 163 - Hallway/Corridor	Fountain	Public Access	HR-113	HR-F104	5.2	None	--	--
Rm. 163 - Hallway/Corridor	Fountain	Public Access	HR-114	HR-F105	4.8	None	--	--
Rm. 177 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-023	HR-S122	4.5	None	--	--
Rm. 179 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-024	HR-S123	5.6	None	--	--
Rm. 185 - Girl's Bathroom	Sink	Public Access	HR-018	HR-S117	4.1	None	--	--
Rm. 185 - Girl's Bathroom	Sink	Public Access	HR-019	HR-S118	3.7	None	--	--
Rm. 185 - Girl's Bathroom	Sink	Public Access	HR-020	HR-S119	1.9	None	--	--
Rm. 186 Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-017	HR-S116	1.6	None	--	--
Rm. 189 - Boy's Bathroom	Sink	Public Access	HR-014	HR-S113	6.5	None	--	--
Rm. 189 - Boy's Bathroom	Sink	Public Access	HR-015	HR-S114	3.4	None	--	--
Rm. 189 - Boy's Bathroom	Sink	Public Access	HR-016	HR-S115	5.3	None	--	--
Rm. 190 - Hallway/Corridor	Fountain	Public Access	HR-111	HR-F102	2.6	None	--	--
Rm. 190 - Hallway/Corridor	Fountain	Public Access	HR-112	HR-F103	7.4	None	--	--
Rm. 205 - Classroom	Sink	Public Access	HR-083	HR-S225	3.5	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT
HENNINGER HIGH SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/09/16 SAMPLE RESULTS (ppb)	10/09/16 ORIGINAL ACTIONS	10/09/16 SAMPLE RESULTS (ppb)	10/09/16 ORIGINAL ACTIONS
Rm. 207D - Library Storage Room	Sink	Secured - SCSD Staff Only	HR-082	HR-S224	9.0	None	--	--
Rm. 207F - Classroom	Sink	Public Access	HR-081	HR-S223	6.1	None	--	--
Rm. 211 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-102	HR-S522	6.3	None	--	--
Rm. 212 - Classroom	Sink	Public Access	HR-084	HR-S226	1.4	None	--	--
Rm. 213 - Classroom	Sink	Public Access	HR-080	HR-S222	10.0	None	--	--
Rm. 214 - Girl's Bathroom	Sink	Public Access	HR-103	HR-S524	5.5	None	--	--
Rm. 214 - Girl's Bathroom	Sink	Public Access	HR-104	HR-S525	6.1	None	--	--
Rm. 214 - Girl's Bathroom	Sink	Public Access	HR-105	HR-S526	5.6	None	--	--
Rm. 214 - Girl's Bathroom	Sink	Public Access	HR-106	HR-S527	6.8	None	--	--
Rm. 214 - Girl's Bathroom	Sink	Public Access	HR-107	HR-S528	6.4	None	--	--
Rm. 214 - Girl's Bathroom	Sink	Public Access	HR-108	HR-S529	6.3	None	--	--
Rm. 226C - Hallway/Corridor	Fountain	Public Access	HR-129	HR-F523	< 1.0	None	--	--
Rm. 228 - Classroom	Sink	Public Access	HR-073	HR-S215	3.9	None	--	--
Rm. 240 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	HR-067	HR-S209	2.0	None	--	--
Rm. 240 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	HR-068	HR-S210	92.0	*See Note 7	--	--
Rm. 242 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-069	HR-S211	1.2	None	--	--
Rm. 242 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-070	HR-S212	4.5	None	--	--
Rm. 243 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-071	HR-S213	6.4	None	--	--
Rm. 243 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	HR-072	HR-S214	2.4	None	--	--
Rm. 255 - Girl's Bathroom	Sink	Public Access	HR-077	HR-S219	5.9	None	--	--
Rm. 255 - Girl's Bathroom	Sink	Public Access	HR-078	HR-S220	3.9	None	--	--
Rm. 255 - Girl's Bathroom	Sink	Public Access	HR-079	HR-S221	3.7	None	--	--
Rm. 257 - Boy's Bathroom	Sink	Public Access	HR-074	HR-S216	6.1	None	--	--
Rm. 257 - Boy's Bathroom	Sink	Public Access	HR-075	HR-S217	2.9	None	--	--
Rm. 257 - Boy's Bathroom	Sink	Public Access	HR-076	HR-S218	2.8	None	--	--
Rm. 259 - Hallway/Corridor	Fountain	Public Access	HR-122	HR-F205	3.2	None	--	--
Rm. 259 - Hallway/Corridor	Fountain	Public Access	HR-123	HR-F206	5.9	None	--	--
Rm. N-5 - Office Bathroom	Sink	Secured - SCSD Staff Only	HR-063	HR-S204	4.1	None	--	--
Rm. N-8 - Girl's Locker Room Bathroom	Sink	Public Access	HR-060	HR-S201	3.4	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT
HENNINGER HIGH SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	10/09/16 SAMPLE RESULTS (ppb)	10/09/16 ORIGINAL ACTIONS	10/09/16 SAMPLE RESULTS (ppb)	10/09/16 ORIGINAL ACTIONS
Rm. N-8 - Girl's Locker Room Bathroom	Sink	Public Access	HR-061	HR-S202	3.3	None	--	--
Rm. N-10 - Girl's Locker Room	Fountain	Public Access	HR-119	HR-F201	8.5	None	--	--
Rm. N-15 - Boy's Locker Room	Fountain	Public Access	HR-120A	HR-F203	4.2	None	--	--
Rm. N-21 - Laundry Room	Ice Machine	Public Access	--	HR-S207	--	*See Note 8	--	--
Rm. N-23 - Team Room Bathroom	Sink	Public Access	HR-066	HR-S208	4.0	None	--	--
Rm. N-25 - Team Room	Fountain	Public Access	HR-121	HR-F204	< 1.0	None	--	--
Rm. N-32A - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	HR-064	HR-S205	1.5	None	--	--
Rm. N-35B - Boy's Locker Room Bathroom	Sink	Public Access	HR-065	HR-S206	2.4	None	--	--
Rm. N-40A - Supply Room	Ice Machine	Public Access	HR-062	HR-S203	< 1.0	None	--	--
Rm. N-42 - Pool	Fountain	Public Access	--	HR-F202	--	*See Note 8	--	--
FIELD HOUSE/CONCESSION STAND								
Field House - Boy's Bathroom	Sink	Public Access	HR-054	HR-S153	2.2	None	--	--
Field House - Boy's Bathroom	Sink	Public Access	HR-055	HR-S154	1.7	None	--	--
Field House - Girl's Bathroom	Sink	Public Access	HR-056	HR-S155	1.3	None	--	--
Field House - Girl's Bathroom	Sink	Public Access	HR-057	HR-S156	< 1.0	None	--	--
Field House - Concession Stand	Fountain	Public Access	HR-118	HR-F109	< 1.0	None	--	--
Field House - Concession Stand	Sink	Public Access	HR-058	HR-S157	< 1.0	None	--	--

Original Notes (October 9, 2016 Event):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-029
2. Water samples analyzed By: Life Science Laboratories, Inc. - LSL Project ID No. 1620823
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. SCSD to remove and replace fixture.
7. SCSD to permanently remove fixture from service.
8. Fixture not operating.

Resampling Notes (January 13, 2018 Event):

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-029
2. Water samples analyzed by: Life Science Laboratories, Inc. - LSL Project ID No. 1800759; January 27, 2018
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
5. Fixture not operating.