

**SYRACUSE CITY SCHOOL DISTRICT
LEMOYNE ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	06/16/23 RESULTS (ppb)	06/16/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	01/19/24 RE-SAMPLE RESULTS (ppb)	01/19/24 RE-SAMPLE ACTIONS
Rm. 005 - Classroom	Main Sink	Public Access	031	LE-S101	2.1	None	---	---	---
Rm. 005 - Classroom	Fountain	Public Access	030	LE-F101	<1.0	None	---	---	---
Rm. 005C - Classroom Bathroom	Sink	Public Access	032	LE-S102	1.0	None	---	---	---
Rm. 106B - Storage Room	Sink	Secured - SCSD Staff Only	---	LE-S103	---	See Note 6.	001	<1.0	None
Rm. 100F - Kitchen Serving Room	Sink	Secured - SCSD Staff Only	002	LE-S116	<1.0	None	---	---	---
Rm. 100F - Kitchen Serving Room	Sink	Secured - SCSD Staff Only	001	LE-S117	3.7	None	---	---	---
Rm. 100F - Kitchen Serving Room	Sink	Secured - SCSD Staff Only	003	LE-S118	2.6	None	---	---	---
Rm. 100F - Kitchen Serving Room	Sink	Secured - SCSD Staff Only	004	LE-S119	<1.0	None	---	---	---
Rm. 100F - Kitchen Serving Room	Nozzle	Secured - SCSD Staff Only	005	LE-C1000	<1.0	None	---	---	---
Rm. 101 - Classroom	Sink	Public Access	022	LE-S113	<1.0	None	---	---	---
Rm. 101 - Classroom	Fountain	Public Access	021	LE-F105	2.1	None	---	---	---
Rm. 101B - Hallway/Corridor	Fountain	Public Access	006	LE-F102	<1.0	None	---	---	---
Rm. 101B - Hallway/Corridor	Fountain	Public Access	007	LE-F102A	<1.0	None	---	---	---
Rm. 101J - Hallway/Corridor	Fountain	Public Access	025	LE-F106	<1.0	None	---	---	---
Rm. 101J - Hallway/Corridor	Fountain	Public Access	014	LE-F107	<1.0	None	---	---	---
Rm. 102A - Classroom Bathroom	Sink	Public Access	023	LE-S110	1.2	None	---	---	---
Rm. 103 - Classroom	Sink	Public Access	020	LE-S112	<1.0	None	---	---	---
Rm. 103 - Classroom	Fountain	Public Access	010	LE-F104	2.0	None	---	---	---
Rm. 104 - Classroom Bathroom	Sink	Public Access	024	LE-S109	<1.0	None	---	---	---
Rm. 105 - Classroom	Sink	Public Access	009	LE-S108	<1.0	None	---	---	---
Rm. 105 - Classroom	Fountain	Public Access	008	LE-F103	1.3	None	---	---	---
Rm. 110A - Clinic Room	Sink	Public Access	026	LE-S124	1.6	None	---	---	---
Rm. 113 - Classroom	Sink	Public Access	012	LE-S130	<1.0	None	---	---	---
Rm. 113 - Classroom	Fountain	Public Access	013	LE-F108	1.0	None	---	---	---
Rm. 115 - Classroom	Sink	Public Access	011	LE-S132	<1.0	None	---	---	---
Rm. 115 - Classroom	Fountain	Public Access	029	LE-F109	1.1	None	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
LEMOYNE ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	06/16/23 RESULTS (ppb)	06/16/23 ACTIONS	LAB SAMPLE I.D. No.	01/19/24 RE-SAMPLE RESULTS (ppb)	01/19/24 RE-SAMPLE ACTIONS
Rm. 118 - Classroom	Sink	Public Access	027	LE-S133	<1.0	None	---	---	---
Rm. 118 - Classroom	Fountain	Public Access	028	LE-F110	1.5	None	---	---	---
Rm. 201F - Hallway/Corridor	Fountain	Public Access	016	LE-F111	<1.0	None	---	---	---
Rm. 201F - Hallway/Corridor	Fountain	Public Access	015	LE-F112	<1.0	None	---	---	---
Rm. 222 - Hallway/Vestibule	Sink	Public Access	018	LE-S144	1.9	None	---	---	---
Rm. 222 - Hallway/Vestibule	Fountain	Public Access	019	LE-F113	1.2	None	---	---	---
Rm. 222 - Hallway/Vestibule	Sink	Public Access	017	LE-S145	1.1	None	---	---	---

Notes [June 16, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-005.
2. Water samples analyzed by: Pace Analytical Services, LLC - Project No. 70260178.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.

Notes [January 19, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-005.
2. Water samples analyzed by: Pace Analytical Services, LLC - Project No. 70284772.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.