

**SYRACUSE CITY SCHOOL DISTRICT  
JOHNSON VOCATIONAL CENTER SCHOOL**  
SAMPLE DATE: 10/25/23      ANALYSIS DATE: 10/30/23

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	10/25/23 RESULTS (ppb)	10/25/23 ACTIONS
Rm. 104 - Principal's Office	Sink	Secured - SCSD Staff Only	013	JN-S312	1.3	None
Rm. 105 - Main Office	Sink	Secured - SCSD Staff Only	012	JN-S311	2.6	None
Rm. 115 - Classroom	Sink	Public Access	008	JN-S315	<1.0	None
Rm. 115 - Classroom	Sink	Public Access	009	JN-S316	<1.0	None
Rm. 115E - Classroom Bathroom	Sink	Public Access	010	JN-S317	82.5	See Note 9.
Rm. 115E - Classroom Bathroom	Sink	Public Access	011	JN-S318	12.6	See Note 9.
Rm. 121/122 - Hallway/Vestibule	Sink	Public Access	006	JN-S320	2.1	None
Rm. 121/122 - Hallway/Vestibule	Sink	Public Access	007	JN-S321	2.2	None
Rm. 125 - Hallway/Corridor	Fountain	Public Access	003	JN-F323	<1.0	None
Rm. 125 - Hallway/Corridor	Fountain	Public Access	004	JN-F323A	<1.0	None
Rm. 128 - Technology Shop	Sink	Public Access	---	JN-S324	---	See Note 6.
Rm. 141 - Auto Shop	Fountain	Public Access	---	JN-F329	---	See Note 7.
Rm. 141 - Auto Shop	Sink	Public Access	005	JN-S328	8.6	See Note 9.
Rm. 142 - Welding Shop	Sink	Public Access	001	JN-S326	15.7	See Note 9.
Rm. 142 - Welding Shop	Sink	Public Access	002	JN-S327	18.1	See Note 9.
Rm. 207 - Hallway/Vestibule	Sink	Public Access	022	JN-S304	1.4	None
Rm. 207 - Hallway/Vestibule	Sink	Public Access	023	JN-S305	2.0	None
Rm. 213 - Laundry Room	Sink	Secured - SCSD Staff Only	025	JN-S303	34.6	See Note 9.
Rm. 214 - Nurse's Office	Sink	Public Access	024	JN-S301	4.3	None
Rm. 218A - Cosmetology Room	Sink	Public Access	017	JN-S308	19.7	See Note 9.
Rm. 218C - Classroom	Sink	Public Access	020	JN-S307	157	See Note 9.
Rm. 219 - Hallway/Corridor	Fountain	Public Access	021	JN-F306	<1.0	None
Rm. 222A - Lounge	Sink Spray Nozzle	Secured - SCSD Staff Only	---	JN-S310A	---	See Note 6.
Rm. 227 - Classroom	Sink	Public Access	016	JN-S309	111	See Note 9.

**SYRACUSE CITY SCHOOL DISTRICT  
JOHNSON VOCATIONAL CENTER SCHOOL**  
SAMPLE DATE: 10/25/23      ANALYSIS DATE: 10/30/23

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	10/25/23 RESULTS (ppb)	10/25/23 ACTIONS
Rm. 218A - Cosmetology Room	Sink	Public Access	---	JN-S2000	---	See Note 8.
Rm. 218A - Cosmetology Room	Sink	Public Access	018	JN-S2001	<1.0	None
Rm. 218A - Cosmetology Room	Sink Spray Nozzle	Public Access	019	JN-S2002	1.0	None
Rm. 227 - Classroom	Sink	Public Access	015	JN-S2003	827.0	See Note 9.

Notes [October 25, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-037
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70275341
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed from service by SCSD.
7. Fixture inoperative. SCSD to evaluate for repair or removal.
8. Fixture not sampled on 10/25/23. Sampling to be rescheduled.
9. Fixture removed and replaced by SCSD. Resampling pending.