

**SYRACUSE CITY SCHOOL DISTRICT
CORCORAN HIGH SCHOOL**

SAMPLE DATE: 02/09/24

ANALYSIS DATE: 02/16/24

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	02/09/24 RESULTS (ppb)	02/09/24 ACTIONS
BUILDING SECTION 'A'						
Rm. A100C - Conference Room	Sink	Public Access	018	CN-S425	1.8	None
Rm. A155 - Cafeteria	Fountain	Public Access	014	CN-F5001A	1.2	None
Rm. A155 - Cafeteria	Fountain	Public Access	012	CN-F5000	1.4	None
Rm. A109 - Clinic Office	Sink	Public Access	019	CN-S409	<1.0	None
Rm. A111 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	020	CN-S412	3.0	None
Rm. A155 - Kitchen	Combitherm	Public Access	002	CN-C5001	5.3	See Note 8
Rm. A157 - Kitchen	Ice Machine	Public Access	001	CN-S408	<1.0	None
Rm. A157 - Kitchen	Sink	Public Access	003	CN-S5001	11.8	See Note 8
Rm. A157 - Kitchen	Kettle	Secured - SCSD Staff Only	011	CN-S407	4.3	None
Rm. A157 - Kitchen	Sink	Secured - SCSD Staff Only	007	CN-S406	6.4	See Note 8
Rm. A157 - Kitchen	Sink	Secured - SCSD Staff Only	006	CN-S405	3.4	None
Rm. A157 - Kitchen	Sink	Secured - SCSD Staff Only	005	CN-S404	19.7	See Note 8
Rm. A116 - Classroom	Sink	Public Access	021	CN-S422	<1.0	None
Rm. A157 - Kitchen	Sink	Secured - SCSD Staff Only	009	CN-S403	13.9	See Note 8
Rm. A116B - Kitchen	Sink	Public Access	022	CN-S423	1.1	None
Rm. A117 - Classroom	Sink	Public Access	023	CN-S424	3.0	None
Rm. A157 - Kitchen	Sink	Public Access	010	CN-S401	16.8	See Note 8.
Rm. A157 - Kitchen	Sink	Secured - SCSD Staff Only	008	CN-S402	24.2	See Note 8.
Rm. A157 - Kitchen	iCombi Pro	Secured - SCSD Staff Only	004	CN-C5000	<1.0	None
Rm. A155 - Cafeteria	Fountain	Public Access	013	CN-F5001	1.5	None
Hallway/Corridor - A151	Fountain	Public Access	015	CN-F5002	2.2	None
Hallway/Corridor - A151	Fountain	Public Access	016	CN-F5003	6.5	See Note 8.
Hallway/Corridor - A151	Fountain	Public Access	017	CN-F5004	57.3	See Note 7.
Hallway/Corridor - A356	Fountain	Public Access	024	CN-F7000	<1.0	None
Hallway/Corridor - A356	Fountain	Public Access	025	CN-F7001	<1.0	None
Rm. A328B - Teacher Planning Room	Sink	Secured - SCSD Staff Only	026	CN-S446	13.7	See Note 8.
Rm. A216 - Librarian's Office	Sink	Secured - SCSD Staff Only	027	CN-S433	1.5	None
Hallway/Corridor - A252	Fountain	Public Access	028	CN-F6000	<1.0	None
Hallway/Corridor - A252	Fountain	Public Access	029	CN-F6001	<1.0	None

**SYRACUSE CITY SCHOOL DISTRICT
CORCORAN HIGH SCHOOL**

SAMPLE DATE: 02/09/24

ANALYSIS DATE: 02/16/24

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	02/09/24 RESULTS (ppb)	02/09/24 ACTIONS
BUILDING SECTION 'C'						
Hallway/Corridor - C108	Fountain	Public Access	030	CN-F100	15.4	See Note 8.
BUILDING SECTION 'B'						
Rm. B104 - Classroom	Sink	Public Access	033	CN-S503	2.5	None
Hallway/Corridor - B1	Fountain	Public Access	031	CN-F4004	<1.0	None
Hallway/Corridor - B1	Fountain	Public Access	032	CN-F4005	<1.0	None
Hallway/Corridor - B124	Fountain	Public Access	034	CN-F5005	<1.0	None
Hallway/Corridor - B124	Fountain	Public Access	035	CN-F5006	<1.0	None
Hallway/Corridor - B54	Fountain	Public Access	036	CN-F4003	<1.0	None
Rm. B005 - Gym Storage Room	Sink	Secured - SCSD Staff Only	037	CN-S115	8.4	See Note 8.
Rm. B05 - Tech Classroom	Sink	Secured - SCSD Staff Only	038	CN-S4006	1.9	None
Lobby - B001	Fountain	Public Access	039	CN-F4000	<1.0	None
Lobby - B001	Fountain	Public Access	040	CN-F4001	<1.0	None
Rm. B023 - Boy's Pool Lockerroom	Fountain	Public Access	041	CN-F109	1.4	None
Rm. B104 - Classroom	Sink	Secured - SCSD Staff Only	042	CN-S506	12.8	See Note 8.
Rm. B017 - Girl's Pool Lockers	Fountain	Public Access	---	CN-F110	---	See Note 6.
Hallway/Corridor - B55	Fountain	Public Access	---	CN-F107	---	See Note 6.
Rm. B61 - Pool	Fountain	Public Access	---	CN-F108	---	See Note 6.
Hallway/Corridor - B54	Fountain	Public Access	---	CN-F4002	---	See Note 6.
Rm. B04 - Ag. Shop	Fountain	Public Access	---	CN-F102	---	See Note 7.
Rm. B04 - Ag. Shop	Sink	Public Access	---	CN-S4000	---	See Note 7.
Rm. B04 - Ag. Shop	Sink	Public Access	---	CN-S4001	---	See Note 7.
Rm. B04 - Ag. Shop	Sink	Public Access	---	CN-S4001	---	See Note 7.
Rm. B04 - Ag. Shop	Sink	Public Access	---	CN-S4002	---	See Note 7.
Rm. B04 - Ag. Shop	Sink	Public Access	---	CN-S4003	---	See Note 7.
Rm. B04 - Ag. Shop	Sink	Public Access	---	CN-S4004	---	See Note 7.

SYRACUSE CITY SCHOOL DISTRICT
CORCORAN HIGH SCHOOL

SAMPLE DATE: 02/09/24

ANALYSIS DATE: 02/16/24

Notes [02/09/2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project Nos. 2016068-025
2. Water samples analyzed by: Pace Analytical Services, LLC. Pace Project No. 70286977.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture inoperative. SCSD to evaluate for repair or removal.
7. Fixture removed by SCSD.
8. Fixture repaired by SCSD. Resampling pending.