

**SYRACUSE CITY SCHOOL DISTRICT
DR. WEEKS ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	07/14/23 RESULTS (ppb)	07/14/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	03/27/24 RE-SAMPLE RESULTS (ppb)	03/27/24 RE-SAMPLE ACTIONS
Rm. 101 - Classroom	Fountain	Public Access	027	DW-F101	<1.0	None	---	---	---
Rm. 101 - Classroom	Sink	Public Access	026	DW-S105	<1.0	None	---	---	---
Rm. 101 - Classroom	Sink	Public Access	025	DW-S106	<1.0	None	---	---	---
Rm. 102 - Classroom	Sink	Public Access	049	DW-S103	6.6	See Note 7.	009	<1.0	None
Rm. 102 - Classroom	Sink	Public Access	050	DW-S104	1.9	None	---	---	---
Rm. 102 - Classroom	Fountain	Public Access	051	DW-F100	<1.0	None	---	---	---
Rm 103 - Corridor	Fountain	Public Access	---	DW-F102	---	See Note 6.	007	<1.0	None
Rm 103 - Corridor	Fountain	Public Access	---	DW-F103	---	See Note 6.	008	<1.0	None
Rm. 222 - Receiving	Sink	Public Access	038	DW-S309	1.2	None	---	---	---
Rm. 110 - Hallway/Corridor	Fountain	Public Access	057	DW-F205	<1.0	None	---	---	---
Rm. 110 - Hallway/Corridor	Fountain	Public Access	058	DW-F206	<1.0	None	---	---	---
Rm. 115 - Classroom	Fountain	Public Access	054	DW-F201	3.2	None	---	---	---
Rm. 210 - Dental	Sink	Public Access	101	DW-S317	1.6	None	---	---	---
Rm. 119 - Hallway/Corridor	Fountain	Public Access	052	DW-F202	<1.0	None	---	---	---
Rm. 119 - Hallway/Corridor	Fountain	Public Access	053	DW-F203	<1.0	None	---	---	---
Rm. 128 - Gym Office	Sink	Secured - SCSD Staff Only	055	DW-S207	3.9	None	---	---	---
Rm. 129 - Pool	Fountain	Public Access	056	DW-F204	11.6	See Note 7.	006	8.9	See Note 6.
Rm. 135 - Hallway/Corridor	Fountain	Public Access	067	DW-F210A	<1.0	None	---	---	---
Rm. 135 - Hallway/Corridor	Fountain	Public Access	068	DW-F210B	<1.0	None	---	---	---
Rm. 136 - Classroom	Sink	Public Access	061	DW-S211	1.7	None	---	---	---
Rm. 136 - Classroom	Fountain	Public Access	062	DW-F207	1.1	None	---	---	---
Rm. 138 - Hallway/Vestibule	Sink	Public Access	059	DW-S214	1.1	None	---	---	---
Rm. 139 - Hallway/Vestibule	Sink	Public Access	060	DW-S215	<1.0	None	---	---	---
Rm. 140 - Classroom	Sink	Public Access	063	DW-S213	1.9	None	---	---	---
Rm. 140 - Classroom	Fountain	Public Access	064	DW-F208	1.0	None	---	---	---
Rm. 141 - Classroom	Sink	Public Access	065	DW-S218	2.6	None	---	---	---
Rm. 141 - Classroom	Fountain	Public Access	066	DW-F209	<1.0	None	---	---	---
Rm. 146 - Teacher's Work Room	Sink	Secured - SCSD Staff Only	069	DW-S220	<1.0	None	---	---	---
Rm. 147 - Classroom	Sink	Public Access	100	DW-S219	1.7	None	---	---	---
Rm. 148 - Classroom	Sink	Public Access	070	DW-S222	1.9	None	---	---	---
Rm. 148 - Classroom	Fountain	Public Access	071	DW-F211A	2.0	None	---	---	---
Rm. 149 - Classroom	Sink	Public Access	072	DW-S224	3.3	None	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
DR. WEEKS ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	07/14/23 RESULTS (ppb)	07/14/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	03/27/24 RE-SAMPLE RESULTS (ppb)	03/27/24 RE-SAMPLE ACTIONS
Rm. 149 - Classroom	Fountain	Public Access	073	DW-F211B	1.0	None	---	---	---
Rm. 151 - Classroom	Sink	Public Access	078	DW-S225	4.8	None	---	---	---
Rm. 152 - Classroom	Sink	Public Access	075	DW-S227	3.2	None	---	---	---
Rm. 152 - Classroom	Fountain	Public Access	074	DW-F212	<1.0	None	---	---	---
Rm. 154 - Classroom	Sink	Public Access	077	DW-S126B	1.5	None	---	---	---
Rm. 154 - Classroom	Fountain	Public Access	076	DW-F111	<1.0	None	---	---	---
Rm. 156 - Classroom	Sink	Public Access	081	DW-S228	14.1	See Note 7.	010	5.0	None
Rm. 157 - Classroom	Sink	Public Access	079	DW-S125	1.1	None	---	---	---
Rm. 157 - Classroom	Fountain	Public Access	080	DW-F110	1.1	None	---	---	---
Rm. 160 - Classroom	Sink	Public Access	083	DW-S121	2.1	None	---	---	---
Rm. 160 - Classroom	Fountain	Public Access	082	DW-F109	1.5	None	---	---	---
Rm. 162 - Classroom	Fountain	Public Access	085	DW-F108	1.6	None	---	---	---
Rm. 162 - Classroom	Sink	Public Access	084	DW-S119	1.3	None	---	---	---
Rm. 165 - Classroom	Sink	Public Access	089	DW-S117	1.3	None	---	---	---
Rm. 165 - Classroom	Fountain	Public Access	088	DW-F107	<1.0	None	---	---	---
Rm. 166 - Classroom	Sink	Public Access	091	DW-S115	1.4	None	---	---	---
Rm. 166 - Classroom	Fountain	Public Access	090	DW-F106B	<1.0	None	---	---	---
Rm. 168 - Hallway/Vestibule	Sink	Public Access	086	DW-S128	<1.0	None	---	---	---
Rm. 168 - Hallway/Vestibule	Sink	Public Access	087	DW-S129	<1.0	None	---	---	---
Rm. 167 - Classroom	Sink	Public Access	099	DW-S131	1.2	None	---	---	---
Rm. 173A - Classroom Bathroom	Sink	Public Access	098	DW-S132	1.6	None	---	---	---
Rm. 174 - Classroom	Sink	Public Access	093	DW-S113	<1.0	None	---	---	---
Rm. 174 - Classroom	Fountain	Public Access	092	DW-F106A	<1.0	None	---	---	---
Rm. 176 - Classroom	Sink	Public Access	094	DW-S111	1.4	None	---	---	---
Rm. 176 - Classroom	Fountain	Public Access	095	DW-F105	<1.0	None	---	---	---
Rm. 177 - Classroom	Sink	Public Access	097	DW-S109	<1.0	None	---	---	---
Rm. 177 - Classroom	Fountain	Public Access	096	DW-F104	<1.0	None	---	---	---
Rm. 210 - Exam Room	Sink	Public Access	041	DW-S314	<1.0	None	---	---	---
Rm. 213 - Clinic Room	Sink	Public Access	042	DW-S313	1.2	None	---	---	---
Rm. 214 - Exam Room	Sink	Public Access	043	DW-S315	1.0	None	---	---	---
Rm. 216 - Treatment Room	Sink	Public Access	039	DW-S318	<1.0	None	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
DR. WEEKS ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	07/14/23 RESULTS (ppb)	07/14/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	03/27/24 RE-SAMPLE RESULTS (ppb)	03/27/24 RE-SAMPLE ACTIONS
Rm. 217 - Nurse's Room	Sink	Public Access	040	DW-S319	2.0	None	---	---	---
Rm. 221 - Kitchen	Sink	Secured - SCSD Staff Only	033	DW-S305	1.8	None	---	---	---
Rm. 221 - Kitchen	Sink	Secured - SCSD Staff Only	032	DW-S306	<1.0	None	---	---	---
Rm. 221 - Kitchen	Convotherm	Secured - SCSD Staff Only	034	DW-A	25.9	See Note 6.	001	4.1	None
Rm. 221 - Kitchen	i Combo Pro	Secured - SCSD Staff Only	035	DW-B	<1.0	None	---	---	---
Rm. 221B - Kitchen	Sink	Secured - SCSD Staff Only	036	DW-S308	<1.0	None	---	---	---
Rm. 222 - Receiving Room	Sink	Secured - SCSD Staff Only	---	DW-S310	---	See Note 8.			
Rm. 223 - Cafeteria	Fountain	Public Access	030	DW-F301	<1.0	None	---	---	---
Rm. 223 - Cafeteria	Fountain (Sensor)	Public Access	031	DW-F302	<1.0	None	---	---	---
Rm. 223 (225) - Hallway/Vestibule	Sink	Public Access	028	DW-S302	<1.0	None	---	---	---
Rm. 223 (224) - Hallway/Vestibule	Sink	Public Access	029	DW-S303	<1.0	None	---	---	---
Rm. 240 - Teacher's Room	Sink	Secured - SCSD Staff Only	024	DW-S244	<1.0	None	---	---	---
Rm. 244 - Corridor	Fountain	Public Access	---	DW-F213	---	See Note 6.	005	<1.0	None
Rm. 244 - Corridor	Fountain	Public Access	---	DW-F214	---	See Note 8.	004	<1.0	None
Rm. 244 (256) - Hallway/Vestibule	Sink	Public Access	013	DW-S229	<1.0	None	---	---	---
Rm. 244 (257) - Hallway/Vestibule	Sink	Public Access	012	DW-S230	<1.0	None	---	---	---
Rm. 244 (237) - Hallway/Vestibule	Sink	Public Access	021	DW-S239	<1.0	None	---	---	---
Rm. 244 (238) - Hallway/Vestibule	Sink	Public Access	020	DW-S238	1.1	None	---	---	---
Rm. 245 - Classroom	Sink	Public Access	023	DW-S242	1.5	None	---	---	---
Rm. 245 - Classroom	Fountain	Public Access	022	DW-F215	<1.0	None	---	---	---
Rm. 250 - Classroom	Sink	Public Access	019	DW-S237	2.9	None	---	---	---
Rm. 251 - Classroom	Sink	Public Access	018	DW-S236	2.7	None	---	---	---
Rm. 252 - Classroom	Sink	Public Access	016	DW-S235	1.5	None	---	---	---
Rm. 253 - Classroom	Sink	Public Access	015	DW-S234	2.7	None	---	---	---
Rm. 254 - Classroom	Sink	Secured - SCSD Staff Only	014	DW-S233	<1.0	None	---	---	---
Rm. 255B - Work Room	Sink	Secured - SCSD Staff Only	017	DW-S231	4.1	None	---	---	---
Rm. 258 - Classroom	Sink	Public Access	011	DW-S232	2.0	None	---	---	---
Rm. 261 - Classroom	Sink	Public Access	010	DW-S133	2.2	None	---	---	---
Rm. 262 - Classroom	Sink	Public Access	009	DW-S134	<1.0	None	---	---	---
Rm. 262 - Classroom	Fountain	Public Access	008	DW-F112	<1.0	None	---	---	---
Rm. 268 - Classroom	Sink	Public Access	007	DW-S136	<1.0	None	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
DR. WEEKS ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	07/14/23 RESULTS (ppb)	07/14/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	03/27/24 RE-SAMPLE RESULTS (ppb)	03/27/24 RE-SAMPLE ACTIONS
Rm. 270 - Hallway/Vestibule	Sink	Public Access	004	DW-S140	<1.0	None	---	---	---
Rm. 270 - Hallway/Vestibule	Sink	Public Access	003	DW-S141	<1.0	None	---	---	---
Rm. 270 - Hallway/Corridor	Fountain	Public Access	001	DW-F113	<1.0	None	---	---	---
Rm. 270 - Hallway/Corridor	Fountain	Public Access	002	DW-F114	<1.0	None	---	---	---
Rm. 273 - Classroom	Sink	Public Access	005	DW-S137	2.5	None	---	---	---
Rm. 274 - Classroom	Sink	Public Access	006	DW-S138	2.5	None	---	---	---
Rm. 275 - Classroom	Sink	Public Access	048	DW-S139	1.5	None	---	---	---
Rm. 277 - Classroom	Sink	Public Access	047	DW-S329	2.2	None	---	---	---
Rm. 278 - Classroom	Sink	Public Access	046	DW-S328	<1.0	None	---	---	---
Rm. 279 - Classroom	Sink	Public Access	044	DW-S326	1.4	None	---	---	---
Rm. 279 - Classroom	Fountain	Public Access	045	DW-F305	<1.0	None	---	---	---
Rm. 283 - Corridor	Fountain	Public Access	---	DW-F303	---	See Note 6.	002	<1.0	None
Rm. 283 - Corridor	Fountain	Public Access	---	DW-F304	---	See Note 6.	003	<1.0	None
Rm. 221B - Wash Room	Sink	Secured - SCSD Staff Only	037	DW-S3000	<1.0	None	---	---	---

Notes [July 14, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-020.
2. Water samples analyzed by: pace Analytical Services, LLC - Pace Project No. 70263580.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.
7. Fixture removed and replaced by SCSD.
8. Fixture signed by SCSD. No further action required.

Notes [March 27, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-020.
2. Water samples analyzed by: pace Analytical Services, LLC - Pace Project No. 70292020.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed by SCSD.