

**SYRACUSE CITY SCHOOL DISTRICT
DANFORTH MIDDLE SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	08/08/23 RESULTS (ppb)	08/08/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	05/07/24 RE-SAMPLE RESULTS (ppb)	05/07/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	05/30/24 RE-SAMPLE RESULTS (ppb)	05/30/24 RE-SAMPLE ACTIONS
Rm. 123 - Classroom	Sink	Public Access	026	DH-S321	4.1	None	---	---	---	---	---	---
Rm. 204 - Hallway/Corridor	Fountain	Public Access	005	DH-F2000	<1.0	None	---	---	---	---	---	---
Rm. 204 - Hallway/Corridor	Fountain	Public Access	004	DH-F2001	<1.0	None	---	---	---	---	---	---
Rm. 236 - Hallway/Corridor	Fountain	Public Access	006	DH-F2002	<1.0	None	---	---	---	---	---	---
Rm. 236 - Hallway/Corridor	Fountain	Public Access	007	DH-F2003	2.3	None	---	---	---	---	---	---
Rm. 218 - Classroom	Sink	Public Access	---	DH-S2000	---	See Note 11.	005	<1.0	None	---	---	---
Rm. 303 - Hallway/Corridor	Fountain	Public Access	001	DH-F3000	<1.0	None	---	---	---	---	---	---
Rm. 303 - Hallway/Corridor	Fountain	Public Access	002	DH-F3001	<1.0	None	---	---	---	---	---	---
Rm. 124 - Classroom	Sink	Public Access	015	DH-S319B	3.0	None	---	---	---	---	---	---
Rm. 156 - Hallway/Corridor	Fountain	Public Access	017	DH-F1000	<1.0	None	---	---	---	---	---	---
Rm. 156 - Hallway/Corridor	Fountain	Public Access	018	DH-F1001	<1.0	None	---	---	---	---	---	---
Rm. 113 - Special Ed.	Sink	Public Access	019	DH-S1000	2.5	None	---	---	---	---	---	---
Rm. 119A - Work Room	Sink	Public Access	020	DH-S1001	1.3	None	---	---	---	---	---	---
Rm. 122 - Nurse Office	Sink	Public Access	021	DH-S1002	1.2	None	---	---	---	---	---	---
Rm. 122A - Nurse Office	Sink	Public Access	022	DH-S1003	1.8	None	---	---	---	---	---	---
Rm. 106 - Hallway/Corridor	Fountain	Public Access	023	DH-F1002	<1.0	None	---	---	---	---	---	---
Rm. 106 - Hallway/Corridor	Fountain	Public Access	024	DH-F1003	<1.0	None	---	---	---	---	---	---
Rm. 106 - Hallway/Corridor	Fountain (Sensor)	Public Access	025	DH-F1003A	<1.0	None	---	---	---	---	---	---
Rm. 138 - Hallway/Corridor	Fountain	Public Access	027	DH-F1004	1.2	None	---	---	---	---	---	---
Rm. 138 - Hallway/Corridor	Fountain	Public Access	028	DH-F1005	<1.0	None	---	---	---	---	---	---
Rm. 130A - Family and Consumer Science	Sink	Public Access	011	DH-S1007	<1.0	None	---	---	---	---	---	---
Rm. 130A - Family and Consumer Science	Sink	Public Access	012	DH-S1006	1.1	None	---	---	---	---	---	---
Rm. 130A - Family and Consumer Science	Sink	Public Access	013	DH-S1005	3.1	None	---	---	---	---	---	---
Rm. 130A - Family and Consumer Science	Sink	Public Access	014	DH-S1004	3.3	None	---	---	---	---	---	---
Rm. 143 - Kitchen	iCombi Pro Oven Sprayer	Secured - SCSD Staff Only	034	DH-C1000	1.9	None	---	---	---	---	---	---
Rm. 143 - Kitchen	Sink	Secured - SCSD Staff Only	036	DH-S313	8.6	See Note 8.	001	1.5	None	---	---	---
Rm. 143 - Kitchen	Sink (Hose Sprayer)	Secured - SCSD Staff Only	031	DH-S314	13.0	See Note 9.	---	---	---	---	---	---
Rm. 143 - Kitchen	Sink	Secured - SCSD Staff Only	032	DH-S315A	2.8	None	---	---	---	---	---	---
Rm. 143 - Kitchen	Sink (Hose Sprayer)	Secured - SCSD Staff Only	033	DH-S317A	46.2	See Note 9.	---	---	---	---	---	---
Rm. 143 - Kitchen	Sink	Secured - SCSD Staff Only	030	DH-S318	3.6	None	---	---	---	---	---	---
Rm. 143 - Kitchen	Sink	Secured - SCSD Staff Only	029	DH-S319A	6.0	See Note 8.	002	7.1	See Note 7.	001	1.9	None
Rm. 159 - Classroom	Sink	Public Access	016	DH-S346	<1.0	None	---	---	---	---	---	---
Rm. 222 - Classroom	Sink	Public Access	010	DH-S368	2.1	None	---	---	---	---	---	---
Rm. 229 - Classroom	Sink	Public Access	009	DH-S371	5.4	See Note 8.	004	1.3	None	---	---	---
Rm. 231 - Fitness Room	Fountain	Public Access	008	DH-F372	<1.0	None	---	---	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
DANFORTH MIDDLE SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	08/08/23 RESULTS (ppb)	08/08/23 ORIGINAL ACTIONS	LAB RE-SAMPLE I.D. No.	05/07/24 RE-SAMPLE RESULTS (ppb)	05/07/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	05/30/24 RE-SAMPLE RESULTS (ppb)	05/30/24 RE-SAMPLE ACTIONS
Rm. 324 - Technology Room	Sink	Public Access	003	DH-S366	<1.0	None	---	---	---	---	---	---
Rm. 143 - Kitchen	Sink	Secured - SCSD Staff Only	035	DH-S1000A	158	See Note 9.	---	---	---	---	---	---
Rm. 327 - Hallway/Corridor	Fountain	Public Access	---	DH-F367	---	See Note 6.	---	---	See Note 6.	---	---	---
Rm. 159 - Classroom	Fountain	Public Access	---	DH-F348	---	See Note 6 and 10	003	<1.0	None	---	---	---
Rm. 128 - Storage	Sink	Secured - SCSD Staff Only	---	DH-S1009	---	See Note 7.	---	---	---	---	---	---

Notes [August 8, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-027.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project ID No. 70266182.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture inoperative. SCSD to evaluate for repair or removal.
7. Fixture signed by SCSD. No further action required.
8. Fixture removed and replaced by SCSD.
9. Fixture removed from service by SCSD.
10. Room number posted as 112A on classroom door.
11. Fixture inoperative. Repaired by SCSD and resampled.

Notes [May 7, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-027.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project ID No. 70296843.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture inoperative. SCSD to evaluate for repair or removal.
7. Fixture repaired by SCSD.

Notes [May 30, 2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-027.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project ID No. 70299646
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.