

SYRACUSE CITY SCHOOL DISTRICT WEBSTER ELEMENTARY SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	06/13/23 RESULTS (ppb)	06/13/23 ORIGINAL ACTIONS	LAB SAMPLE I.D. No.	05/10/24 RE-SAMPLE RESULTS (ppb)	05/10/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	05/30/24 RE-SAMPLE RESULTS (ppb)	05/30/24 RE-SAMPLE ACTIONS
Rm. 012A - Classroom (012) Bathroom	Sink	Public Access	027	WR-S137	<1.0	None	---	---	---	---	---	---
Rm. 021 - Hallway/Corridor	Fountain	Public Access	026	WR-F107	<1.0	None	---	---	---	---	---	---
Rm. 100D - Hallway/Corridor	Fountain	Public Access	001	WR-F101	2.1	None	---	---	---	---	---	---
Rm. 100D - Hallway/Corridor	Fountain	Public Access	002	WR-F102	<1.0	None	---	---	---	---	---	---
Rm. 100Q - Hallway/Corridor	Fountain	Public Access	009	WR-F100	1.3	None	---	---	---	---	---	---
Rm. 100T - Hallway/Corridor	Fountain	Public Access	013	WR-F104	<1.0	None	---	---	---	---	---	---
Rm. 100T - Hallway/Corridor	Fountain (Sensor)	Public Access	014	WR-F104A	<1.0	None	---	---	---	---	---	---
Rm. 110 - Hallway/Vestibule	Sink	Public Access	021	WR-S128	1.8	None	---	---	---	---	---	---
Rm. 110 - Hallway/Vestibule	Sink	Public Access	020	WR-S129	1.3	None	---	---	---	---	---	---
Rm. 110 - Hallway/Vestibule	Sink	Public Access	019	WR-S130	2.1	None	---	---	---	---	---	---
Rm. 110 - Hallway/Vestibule	Fountain	Public Access	018	WR-F105	2.4	None	---	---	---	---	---	---
Rm. 114 - Hallway/Vestibule	Sink	Public Access	031	WR-S138	2.1	None	---	---	---	---	---	---
Rm. 114 - Hallway/Vestibule	Sink	Public Access	030	WR-S139	3.8	None	---	---	---	---	---	---
Rm. 114 - Hallway/Vestibule	Sink	Public Access	029	WR-S140	3.5	None	---	---	---	---	---	---
Rm. 114 - Hallway/Vestibule	Fountain	Public Access	028	WR-F108	2.1	None	---	---	---	---	---	---
Rm 114AA- Nurse's Office Exam Room	Sink	Public Access	---	WR-S121	---	See Note 6.	004	1.1	None			
Rm. 114B - Nurse's Office Bathroom	Sink	Public Access	016	WR-S120	2.5	None	---	---	---	---	---	---
Rm. 118A - Library Office	Sink	Secured - SCSD Staff Only	015	WR-S119	3.6	None	---	---	---	---	---	---
Rm. 137 - Classroom Bathroom	Sink	Public Access	003	WR-S105	2.3	None	---	---	---	---	---	---
Rm. 144 - Classroom	Fountain	Public Access	010	WR-F103	3.3	None	---	---	---	---	---	---
Rm. 144B - Classroom (144) Bathroom	Sink	Public Access	011	WR-S116	1.7	None	---	---	---	---	---	---
Rm. 145 - Classroom	Sink	Public Access	012	WR-S115	3.6	None	---	---	---	---	---	---
Rm. 152A - Kitchen	Sink	Secured - SCSD Staff Only	004	WR-S100	6.7	See Note 7.	003	3.0	None			
Rm. 152A - Kitchen	Sink	Secured - SCSD Staff Only	005	WR-S101	<1.0	None	---	---	---	---	---	---
Rm. 152A - Kitchen	Sink Hose	Secured - SCSD Staff Only	006	WR-S101A	<1.0	None	---	---	---	---	---	---
Rm. 152A - Kitchen	Sink	Secured - SCSD Staff Only	007	WR-S102	2.5	None	---	---	---	---	---	---
Rm. 152A - Kitchen	Cooker Spray	Secured - SCSD Staff Only	008	WR-C100	53.6	See Note 6.	001	6.9	None	001	2.4	None
Rm. 152A - Kitchen	Cooker Spray	Secured - SCSD Staff Only	---	WR-C101	---	---	002	<1.0	None	---	---	---
Rm. 178 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	017	WR-S124	2.9	None	---	---	---	---	---	---
Rm. 211 - Hallway/Vestibule	Sink	Public Access	025	WR-S133	2.6	None	---	---	---	---	---	---
Rm. 211 - Hallway/Vestibule	Sink	Public Access	024	WR-S134	1.2	None	---	---	---	---	---	---

SYRACUSE CITY SCHOOL DISTRICT WEBSTER ELEMENTARY SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	06/13/23 RESULTS (ppb)	06/13/23 ORIGINAL ACTIONS	LAB SAMPLE I.D. No.	05/10/24 RE-SAMPLE RESULTS (ppb)	05/10/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	05/30/24 RE-SAMPLE RESULTS (ppb)	05/30/24 RE-SAMPLE ACTIONS
Rm. 211 - Hallway/Vestibule	Sink	Public Access	023	WR-S135	1.1	None	---	---	---	---	---	---
Rm. 211 - Hallway/Vestibule	Fountain	Public Access	022	WR-F106	1.4	None	---	---	---	---	---	---
Rm. 152A - Kitchen	Sampling Port	Secured - SCSD Staff Only	---	WR-C100A	---	---	---	---	---	002	9.2	See Note 6.

Notes [June 13, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-003.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70259562.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.
7. Fixture removed and replaced by SCSD.

Notes [May 10, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-003A.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70297479.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD / Upstream sampling port installed (C100A).

Notes [May 30, 2023 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-003A.
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70299649.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Upstream Sampling Port - Not a Drinking or Cooking Water Outlet.