

SYRACUSE CITY SCHOOL DISTRICT
INSTITUTE OF TECHNOLOGY AT SYRACUSE CENTRAL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	10/27/23 RESULTS (ppb)	10/27/23 ORIGINAL ACTIONS	LAB SAMPLE I.D. No.	01/18/24 RE-SAMPLE RESULTS (ppb)	01/18/24 RE-SAMPLE ACTIONS	LAB SAMPLE I.D. No.	04/04/24 RE-SAMPLE RESULTS (ppb)	04/04/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	05/30/24 RE-SAMPLE RESULTS (ppb)	05/30/24 RE-SAMPLE ACTIONS
Rm. 007 - Storage Room	Sink	Secured - SCSD Staff Only	010	IT-S100	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 100 - Hallway/Corridor	Fountain	Public Access	013	IT-F106	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 100 - Hallway/Corridor	Fountain	Public Access	014	IT-F107	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 102 - Concessions Room	Sink	Secured - SCSD Staff Only	011	IT-S139	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 102 - Concessions Room	Sink	Secured - SCSD Staff Only	012	IT-S140	1.2	None	---	---	---	---	---	---	---	---	---
Rm. 103 - Patient Room	Sink	Public Access	030	IT-S138	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 116 - Hallway/Corridor	Fountain	Public Access	015	IT-F108	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 133 - Nurse's Office	Sink	Public Access	027	IT-S106	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 135 - Exam Room	Sink	Public Access	026	IT-S104	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 140 - Library	Sink	Public Access	028	IT-S135	8.2	See Note 6.	001	6.7	See Note 6.	001	17.1	See Note 6.	---	---	---
Rm. 140 - Hallway/Corridor	Fountain	Public Access	016	IT-F100	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 147 - Main Office	Sink	Secured - SCSD Staff Only	029	IT-S137	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 157 - Tech Lab	Fountain	Public Access	046	IT-F105	3.7	None	---	---	---	---	---	---	---	---	---
Rm. 157 - Tech Lab	Sink	Public Access	047	IT-S132	1.7	None	---	---	---	---	---	---	---	---	---
Rm. 157 - Tech Lab	Sink	Public Access	048	IT-S133	4.1	None	---	---	---	---	---	---	---	---	---
Rm. 165 - Tech Lab	Fountain	Public Access	045	IT-F104	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 172 - Hallway/Corridor	Fountain	Public Access	031	IT-F103	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 174 - Teaching Kitchen	Sink	Public Access	036	IT-S121	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 174 - Teaching Kitchen	Sink	Public Access	037	IT-S122	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 174 - Teaching Kitchen	Sink	Public Access	038	IT-S123	2.8	None	---	---	---	---	---	---	---	---	---
Rm. 174 - Teaching Kitchen	Sink	Public Access	039	IT-S124	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 174 - Teaching Kitchen	Sink	Public Access	041	IT-S125	<1.0	None	---	---	---	005	<1.0	None	---	---	---
Rm. 174 - Teaching Kitchen	Sink	Public Access	043	IT-S126	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 174 - Teaching Kitchen	Sink	Public Access	042	IT-S127	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 174 - Teaching Kitchen	Hose Reel Spray	Public Access	040	IT-S128	170.0	See Note 8.	---	---	---	---	---	---	---	---	---
Rm. 174 - Teaching Kitchen	Sink	Public Access	034	IT-S129	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 177 - Home & Careers Room	Sink	Public Access	033	IT-S118	3.2	None	---	---	---	---	---	---	---	---	---
Rm. 177 - Home & Careers Room	Sink	Public Access	032	IT-S119	1.6	None	---	---	---	---	---	---	---	---	---
Rm. 190 - Cafeteria	Fountain	Public Access	017	IT-F101	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 190 - Cafeteria	Fountain	Public Access	018	IT-F102	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 192 - Warming Kitchen	Sink	Secured - SCSD Staff Only	019	IT-S107	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 192 - Warming Kitchen	Sink	Secured - SCSD Staff Only	020	IT-S108	6.7	See Note 6.	002	4.7	None	002	5.3	See Note 7.	001	5.0	None
Rm. 192 - Warming Kitchen	Sink	Secured - SCSD Staff Only	022	IT-S109	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 192 - Warming Kitchen	Sink	Secured - SCSD Staff Only	024	IT-S110	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 192 - Warming Kitchen	Sink	Secured - SCSD Staff Only	023	IT-S111	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 192 - Warming Kitchen	Sink	Secured - SCSD Staff Only	025	IT-S112	1.6	None	---	---	---	---	---	---	---	---	---
Rm. 192 - Warming Kitchen	iCombiPro Oven Sprayer	Secured - SCSD Staff Only	021	IT-S113	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 220 - Staff Kitchenette	Sink	Secured - SCSD Staff Only	001	IT-S502	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 244 - Music Room	Sink	Public Access	002	IT-S500	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 254 - Teacher's Work Room	Sink	Secured - SCSD Staff Only	009	IT-S508	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 255 - OT/PT Room	Sink	Secured - SCSD Staff Only	008	IT-S511	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 263 - Classroom	Sink	Public Access	003	IT-S519	2.4	None	---	---	---	---	---	---	---	---	---
Rm. 265 - Hallway/Corridor	Fountain	Public Access	004	IT-F500	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 266 - Storage Room	Sink	Secured - SCSD Staff Only	006	IT-S517	3.5	None	---	---	---	---	---	---	---	---	---
Rm. 266 - Storage Room	Sink	Secured - SCSD Staff Only	005	IT-S525	85.8	See Note 7.	003	31.7	See Note 8.	006	24.6	See Note 8.	---	---	---

SYRACUSE CITY SCHOOL DISTRICT
INSTITUTE OF TECHNOLOGY AT SYRACUSE CENTRAL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	10/27/23 RESULTS (ppb)	10/27/23 ORIGINAL ACTIONS	LAB SAMPLE I.D. No.	01/18/24 RE-SAMPLE RESULTS (ppb)	01/18/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	04/04/24 RE-SAMPLE RESULTS (ppb)	04/04/24 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	05/30/24 RE-SAMPLE RESULTS (ppb)	05/30/24 RE-SAMPLE ACTIONS
Rm. 267 - H & BS Team Room	Sink	Public Access	007	IT-S516	2.0	None	---	---	---	---	---	---	---	---	---
Rm. 177 - Home & Careers Room	Sink (Hot Water)	Public Access	035	IT-S1000	6.8	See Note 6.	---	---	See Note 7	003	4.1	None	---	---	---
Rm. 165 - Tech Lab	Sink	Public Access	044	IT-S1001	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. 174 - Teaching Kitchen	Ice Machine	Public Access	---	IT-S5000	---	---	---	---	---	004	<1.0	None	---	---	---

Notes [October 27, 2023 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-036
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70275761.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.
7. Fixture removed and replaced by SCSD.
8. Not a potable water fixture. No further action required.

Notes [January 18, 2024 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-036A.
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70284672.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed and replaced by SCSD.
7. Fixture repaired by SCSD.
8. Fixture signed by SCSD.

Notes [April 4, 2024 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-036A.
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70293138.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed by SCSD.
7. Fixture removed and replaced by SCSD.
8. Fixture signed by SCSD. No further action required.

Notes [May 30, 2024 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-036A.
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70299645.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.