

**SYRACUSE CITY SCHOOL DISTRICT
GRANT MIDDLE SCHOOL**

| ROOM No. & LOCATION | FIXTURE (Sink / Fountain) | ACCESSIBILITY | LAB SAMPLE I.D. No. | TDK SAMPLE I.D. No. | 12/22/23 RESULTS (ppb) | 12/22/23 ACTIONS | LAB SAMPLE I.D. No. | 05/17/24 RE-SAMPLE RESULTS (ppb) | 05/17/24 RE-SAMPLE ACTIONS | LAB SAMPLE I.D. No. | 06/21/24 RE-SAMPLE RESULTS (ppb) | 06/21/24 RE-SAMPLE ACTIONS |
|--------------------------------------------|------------------------------|---------------------------|---------------------------|---------------------------|------------------------------|---------------------|---------------------------|-------------------------------------------|----------------------------------|---------------------------|-------------------------------------------|----------------------------------|
| Rm. B-18 - Boy's Locker Room Bathroom | Fountain | Public Access | 047 | GT-F201 | 10.1 | See Note 6. | 001 | 6.5 | See Note 6. | --- | --- | --- |
| Rm. 108B - Exam Room | Sink | Public Access | 024 | GT-S217 | 2.7 | None | -- | -- | --- | --- | --- | --- |
| Rm. 109 - Nurse's Office | Sink | Public Access | 025 | GT-S218 | 2.5 | None | -- | -- | --- | --- | --- | --- |
| Rm. 110 - Classroom | Sink | Public Access | 023 | GT-S220 | 8.8 | See Note 7. | 011 | 7.7 | See Note 6. | -- | -- | -- |
| Rm. 115 - Music Room | Sink | Public Access | 068 | GT-S226 | 26.0 | See Note 6. | 009 | 27.9 | See Note 7. | -- | -- | -- |
| Rm. 123 - Work Room | Sink | Secured - SCSD Staff Only | 046 | GT-S221 | 1.2 | None | -- | -- | --- | 005 | 4.4 | None |
| Rm. 131 - Serving Room | Sink | Secured - SCSD Staff Only | 072 | GT-S212 | 1.4 | None | -- | -- | -- | -- | -- | -- |
| Rm. 132A - Medical Assistance Waiting Room | Sink | Public Access | 057 | GT-S109 | 1.4 | None | -- | -- | -- | -- | -- | -- |
| Rm. 132A - Medical Assistance Waiting Room | Sink | Public Access | 053 | GT-S112 | 1.2 | None | -- | -- | -- | -- | -- | -- |
| Rm. 132A - Medical Assistance Waiting Room | Sink | Public Access | 052 | GT-S113 | 1.7 | None | -- | -- | -- | -- | -- | -- |
| Rm. 132A - Medical Assistance Waiting Room | Sink | Public Access | 058 | GT-S114 | 3.8 | None | -- | -- | -- | -- | -- | -- |
| Rm. 132B - Dental Office | Sink | Public Access | 056 | GT-S115 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 132F - Examination Room | Sink | Public Access | 054 | GT-S111 | 3.2 | None | -- | -- | -- | -- | -- | -- |
| Rm. 133A - Kitchen | Sink | Secured - SCSD Staff Only | 077 | GT-S206 | 2.3 | None | -- | -- | -- | -- | -- | -- |
| Rm. 133A - Kitchen | Sink | Secured - SCSD Staff Only | 076 | GT-S207 | 9.8 | See Note 7. | 008 | 9.7 | See Note 8. | 003 | 5.4 | See Note 6. |
| Rm. 133A - Kitchen | Sink (spray nozzle) | Secured - SCSD Staff Only | 073 | GT-S208 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 133A - Kitchen | Sink | Secured - SCSD Staff Only | 074 | GT-S209 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 133A - Kitchen | Sink | Secured - SCSD Staff Only | 075 | GT-S210 | 1.5 | None | -- | -- | -- | -- | -- | -- |
| Rm. 140B - Swimming Pool Office | Sink | Secured - SCSD Staff Only | 049 | GT-S119 | 7.9 | See Note 6. | 014 | 11.9 | See Note 9. | -- | -- | -- |
| Rm. 151 - Hallway/Vestibule | Fountain | Public Access | 064 | GT-F100 | 1.1 | None | -- | -- | -- | -- | -- | -- |
| Rm. 151 - Hallway/Vestibule | Sink | Public Access | 066 | GT-S101 | 2.3 | None | -- | -- | -- | -- | -- | -- |
| Rm. 169 - Work Room | Sink | Secured - SCSD Staff Only | 027 | GT-S224 | 6.2 | See Note 7. | 010 | 11.0 | See Note 9. | -- | -- | -- |
| Rm. 170 - Audio/Video Storage | Sink | Secured - SCSD Staff Only | 026 | GT-S225 | 1.3 | None | -- | -- | -- | -- | -- | -- |
| Rm. 182 - Classroom | Sink | Public Access | 082 | GT-S103 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 182A - Nurse's Waiting Room | Sink | Public Access | 081 | GT-S106 | 1.2 | None | -- | -- | -- | -- | -- | -- |
| Rm. 182B - Classroom Office | Sink | Public Access | 062 | GT-S104 | 2.1 | None | -- | -- | -- | -- | -- | -- |
| Rm. 182D - Examination Room | Sink | Public Access | 059 | GT-S108 | 1.3 | None | -- | -- | -- | -- | -- | -- |
| Rm. 184 - Swimming Pool | Fountain | Public Access | 048 | GT-F101 | 14.4 | See Note 6. | 013 | 8.9 | See Note 6. | -- | -- | -- |

**SYRACUSE CITY SCHOOL DISTRICT
GRANT MIDDLE SCHOOL**

| ROOM No. & LOCATION | FIXTURE (Sink / Fountain) | ACCESSIBILITY | LAB SAMPLE I.D. No. | TDK SAMPLE I.D. No. | 12/22/23 RESULTS (ppb) | 12/22/23 ACTIONS | LAB SAMPLE I.D. No. | 05/17/24 RE-SAMPLE RESULTS (ppb) | 05/17/24 RE-SAMPLE ACTIONS | LAB SAMPLE I.D. No. | 06/21/24 RE-SAMPLE RESULTS (ppb) | 06/21/24 RE-SAMPLE ACTIONS |
|-----------------------------------|------------------------------|---------------------------|---------------------------|---------------------------|------------------------------|---------------------|---------------------------|-------------------------------------------|----------------------------------|---------------------------|-------------------------------------------|----------------------------------|
| Rm. 182G - Sick/Rest Waiting Room | Sink | Public Access | 061 | GT-S105 | 1.3 | None | -- | -- | -- | -- | -- | -- |
| Rm. 185C - Office | Sink | Secured - SCSD Staff Only | 067 | GT-S102 | 3.1 | None | -- | -- | -- | -- | -- | -- |
| Rm. 203 - Classroom | Sink | Public Access | 018 | GT-S124 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 212 - Girl's Coach Office | Sink | Secured - SCSD Staff Only | 015 | GT-S129 | 12.7 | See Note 6. | 005 | 2.8 | None | -- | -- | -- |
| Rm. 227 - Teacher's Lounge | Sink | Secured - SCSD Staff Only | 006 | GT-S142 | 1.2 | None | -- | -- | -- | -- | -- | -- |
| Rm. 270 - Hallway/Vestibule | Fountain | Public Access | 012 | GT-F102 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 294 - Home & Careers Room | Sink | Public Access | 020 | GT-S125 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 294 - Home & Careers Room | Sink | Public Access | 019 | GT-S126 | 5.7 | See Note 7. | 004 | 8.2 | See Note 6. | -- | -- | -- |
| Rm. 296 - Home & Careers Room | Sink | Public Access | 017 | GT-S120 | 10.7 | See Note 7. | 003 | 10.5 | See Note 6. | -- | -- | -- |
| Rm. 296 - Home & Careers Room | Sink | Public Access | --- | GT-S121 | --- | See Note 9. | -- | -- | See Note 6. | -- | -- | -- |
| Rm. 296 - Home & Careers Room | Sink | Public Access | 016 | GT-S122 | 1.6 | None | -- | -- | -- | -- | -- | -- |
| Rm. 131 - Serving Room | Ice Machine | Secured - SCSD Staff Only | 083 | GT-S1000 | <1.0 | None | 012 | <1.0 | None | -- | -- | -- |
| Rm. 152 - Vestibule | Fountain | Public Access | 071 | GT-F1000 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 152 - Vestibule | Sink | Public Access | 069 | GT-S1001 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 152 - Vestibule | Sink | Public Access | 070 | GT-S1002 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 120 - Hallway/ Corridor | Fountain | Public Access | 021 | GT-F1001 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 120 - Hallway/ Corridor | Fountain | Public Access | 022 | GT-F1002 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 139 - Hallway/ Corridor | Fountain | Public Access | 043 | GT-F1003 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 139 - Hallway/ Corridor | Fountain | Public Access | 044 | GT-F1003A | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 139 - Hallway/ Corridor | Fountain | Public Access | 045 | GT-F1004 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 151 - Vestibule | Sink | Public Access | 065 | GT-S1014 | 1.2 | None | -- | -- | -- | -- | -- | -- |
| Rm. 218 - Hallway/ Corridor | Fountain | Public Access | 001 | GT-F1005 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 218 - Hallway/ Corridor | Fountain | Public Access | --- | GT-F1006 | --- | See Note 8. | -- | -- | See Note 7. | 001 | <1.0 | None |
| Rm. 262 - Vestibule | Sink | Public Access | 039 | GT-S1016 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 262 - Vestibule | Sink | Public Access | 040 | GT-S1017 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 262 - Vestibule | Fountain | Public Access | 038 | GT-F1007 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 208 - Hallway/ Corridor | Fountain | Public Access | 004 | GT-F1008 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 208 - Hallway/ Corridor | Fountain | Public Access | 005 | GT-F1009 | <1.0 | None | -- | -- | -- | -- | -- | -- |

**SYRACUSE CITY SCHOOL DISTRICT
GRANT MIDDLE SCHOOL**

| ROOM No. & LOCATION | FIXTURE (Sink / Fountain) | ACCESSIBILITY | LAB SAMPLE I.D. No. | TDK SAMPLE I.D. No. | 12/22/23 RESULTS (ppb) | 12/22/23 ACTIONS | LAB SAMPLE I.D. No. | 05/17/24 RE-SAMPLE RESULTS (ppb) | 05/17/24 RE-SAMPLE ACTIONS | LAB SAMPLE I.D. No. | 06/21/24 RE-SAMPLE RESULTS (ppb) | 06/21/24 RE-SAMPLE ACTIONS |
|---------------------------------------|------------------------------|---------------------------|---------------------------|---------------------------|------------------------------|---------------------|---------------------------|-------------------------------------------|----------------------------------|---------------------------|-------------------------------------------|----------------------------------|
| Rm. 255 - Hallway/ Corridor | Fountain | Public Access | 002 | GT-F1010 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 255 - Hallway/ Corridor | Fountain | Public Access | 003 | GT-F1011 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 211 - Girl's Lockerroom | Sink | Public Access | 013 | GT-S1027 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 211 - Girl's Lockerroom | Sink | Public Access | 014 | GT-S1028 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 220 - Boy's Lockerroom | Sink | Public Access | 009 | GT-S1029 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 220 - Boy's Lockerroom | Sink | Public Access | 008 | GT-S1030 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 271 - Vestibule | Fountain | Public Access | 011 | GT-F1012 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 210 - Hallway/ Corridor | Fountain | Public Access | 007 | GT-F1013 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 315 - Hallway/ Corridor | Fountain | Public Access | 030 | GT-F1014 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 133A - Kitchen | Sink | Public Access | 078 | GT-S3000 | 5.5 | See Note 7. | 006 | 6.2 | See Note 8. | 002 | 3.7 | None |
| Rm. 315 - Hallway/ Corridor | Fountain | Public Access | 031 | GT-F1015 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 347 - Vestibule | Sink | Public Access | 033 | GT-S1034 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 347 - Vestibule | Sink | Public Access | 034 | GT-S1035 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 347 - Vestibule | Fountain | Public Access | 032 | GT-F1016 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 308 - Hallway/ Corridor | Fountain | Public Access | 035 | GT-F1018 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 308 - Hallway/ Corridor | Fountain | Public Access | --- | GT-F1017 | --- | See Note 8. | 002 | <1.0 | None | -- | -- | -- |
| Rm. 326 - Hallway/ Corridor | Fountain | Public Access | 036 | GT-F1019 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 326 - Hallway/ Corridor | Fountain | Public Access | 037 | GT-F1020 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 140E - Boy's Locker Room Bathroom | Sink | Public Access | 051 | GT-S1044 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 137 - Girls Locker Room Bathroom | Sink | Public Access | 042 | GT-S1045 | 1.6 | None | -- | -- | -- | -- | -- | -- |
| Rm. 184 - Swimming Pool | Fountain | Public Access | 050 | GT-F1021 | 1.5 | None | -- | -- | -- | -- | -- | -- |
| Rm. 372 - Art Room | Sink | Public Access | 028 | GT-S5000 | 1.5 | None | -- | -- | -- | -- | -- | -- |
| Rm. 372 - Art Room | Sink | Public Access | 029 | GT-S5001 | 3.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 133A - Kitchen | Convotherm (Oven) | Secured - SCSD Staff Only | 079 | GT-C1000 | 11.4 | See Note 7. | 007 | 7.2 | See Note 7. | 004 | 5.1 | See Note 6. |
| Rm. 133A - Kitchen | Convotherm (Oven) | Secured - SCSD Staff Only | 080 | GT-C1001 | 1.4 | None | -- | -- | -- | -- | -- | -- |
| Rm. 181 - Classroom | Sink | Public Access | 063 | GT-S3004 | 1.2 | None | -- | -- | -- | -- | -- | -- |
| Rm. 238 - Classroom | Sink | Public Access | 041 | GT-S136A | 3.9 | None | -- | -- | -- | -- | -- | -- |

SYRACUSE CITY SCHOOL DISTRICT GRANT MIDDLE SCHOOL

| ROOM No. & LOCATION | FIXTURE (Sink / Fountain) | ACCESSIBILITY | LAB SAMPLE I.D. No. | TDK SAMPLE I.D. No. | 12/22/23 RESULTS (ppb) | 12/22/23 ACTIONS | LAB SAMPLE I.D. No. | 05/17/24 RE-SAMPLE RESULTS (ppb) | 05/17/24 RE-SAMPLE ACTIONS | LAB SAMPLE I.D. No. | 06/21/24 RE-SAMPLE RESULTS (ppb) | 06/21/24 RE-SAMPLE ACTIONS |
|----------------------------------------|------------------------------|---------------|---------------------------|---------------------------|------------------------------|---------------------|---------------------------|-------------------------------------------|----------------------------------|---------------------------|-------------------------------------------|----------------------------------|
| Rm. 273 - Boy's Bathroom | Sink | Public Access | 010 | GT-S1031 | 3.5 | None | -- | -- | -- | -- | -- | -- |
| Rm. 132G - Medical Assistance Bathroom | Sink | Public Access | 055 | GT-S110 | <1.0 | None | -- | -- | -- | -- | -- | -- |
| Rm. 182E - Bathroom | Sink | Public Access | 060 | GT-S107 | <1.0 | None | -- | -- | -- | -- | -- | -- |

Notes [December 22, 2023 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-032
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70282363.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture replaced by SCSD.
7. Fixture repaired by SCSD.
8. Fixture inoperative. SCSD to evaluate for repair or removal.
9. Fixture not accessible.

Notes [May 17, 2024 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-032
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70298418
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed by SCSD.
7. Fixture repaired by SCSD.
8. Fixture removed and replaced by SCSD.
9. Fixture signed by SCSD. No further action required.

Notes [June 21, 2024 Event]

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-032
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project No. 70302477
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
7. Fixture repaired by SCSD.