

SYRACUSE CITY SCHOOL DISTRICT  
CORCORAN HIGH SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	02/09/24 RESULTS (ppb)	02/09/24 ACTIONS	LAB SAMPLE I.D. No.	06/18/24 RE-SAMPLE RESULTS (ppb)	06/18/24 RE- SAMPLE ACTIONS	LAB SAMPLE I.D. No.	08/14/24 RE-SAMPLE RESULTS (ppb)	08/14/24 RE-SAMPLE ACTIONS	LAB SAMPLE I.D. No.	10/18/24 RE-SAMPLE RESULTS (ppb)	10/18/24 RE-SAMPLE ACTIONS	LAB SAMPLE I.D. No.	10/23/24 RE-SAMPLE RESULTS (ppb)	10/23/24 RE-SAMPLE ACTIONS
<b>BUILDING SECTION 'A'</b>																		
Rm. A100C - Conference Room	Sink	Public Access	018	CN-S425	1.8	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. A155 - Cafeteria	Fountain	Public Access	014	CN-F5001A	1.2	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. A155 - Cafeteria	Fountain	Public Access	012	CN-F5000	1.4	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. A109 - Clinic Office	Sink	Public Access	019	CN-S409	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. A111 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	020	CN-S412	3.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. A155 - Kitchen	Combitherm	Public Access	002	CN-C5001	5.3	See Note 8.	002	7.4	See Note 6.	005	1.6	None	---	---	---	---	---	---
Rm. A157 - Kitchen	Ice Machine	Public Access	001	CN-S408	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. A157 - Kitchen	Sink	Public Access	003	CN-S5001	11.8	See Note 8.	001	21.8	See Note 7.	004	4.8	None	---	---	---	---	---	---
Rm. A157 - Kitchen	Kettle	Secured - SCSD Staff Only	011	CN-S407	4.3	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. A157 - Kitchen	Sink	Secured - SCSD Staff Only	007	CN-S406	6.4	See Note 8.	004	4.7	None.	---	---	---	---	---	---	---	---	---
Rm. A157 - Kitchen	Sink	Secured - SCSD Staff Only	006	CN-S405	3.4	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. A157 - Kitchen	Sink	Secured - SCSD Staff Only	005	CN-S404	19.7	See Note 8.	003	3.7	None.	---	---	---	---	---	---	---	---	---
Rm. A116 - Classroom	Sink	Public Access	021	CN-S422	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. A157 - Kitchen	Sink	Secured - SCSD Staff Only	009	CN-S403	13.9	See Note 8.	007	31.7	See Note 7.	003	2.6	None	---	---	---	---	---	---
Rm. A116B - Kitchen	Sink	Public Access	022	CN-S423	1.1	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. A117 - Classroom	Sink	Public Access	023	CN-S424	3.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. A157 - Kitchen	Sink	Public Access	010	CN-S401	16.8	See Note 8.	006	13.1	See Note 7.	001	250.0	See Note 6.	001	2.9	None	---	---	---
Rm. A157 - Kitchen	Sink	Secured - SCSD Staff Only	008	CN-S402	24.2	See Note 8.	005	15.4	See Note 6.	002	17.2	See Note 6.	002	1.1	None	---	---	---
Rm. A157 - Kitchen	iCombi Pro	Secured - SCSD Staff Only	004	CN-C5000	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. A155 - Cafeteria	Fountain	Public Access	013	CN-F5001	1.5	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - A151	Fountain	Public Access	015	CN-F5002	2.2	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - A151	Fountain	Public Access	016	CN-F5003	6.5	See Note 8.	008	<1.0	None.	---	---	---	---	---	---	---	---	---
Hallway/Corridor - A151	Fountain	Public Access	017	CN-F5004	57.3	See Note 7.	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - A356	Fountain	Public Access	024	CN-F7000	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - A356	Fountain	Public Access	025	CN-F7001	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. A328B - Teacher Planning Room	Sink	Secured - SCSD Staff Only	026	CN-S446	13.7	See Note 8.	009	12.3	See Note 8.	---	---	---	---	---	---	---	---	---
Rm. A216 - Librarian's Office	Sink	Secured - SCSD Staff Only	027	CN-S433	1.5	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - A252	Fountain	Public Access	028	CN-F6000	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - A252	Fountain	Public Access	029	CN-F6001	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---

SYRACUSE CITY SCHOOL DISTRICT  
CORCORAN HIGH SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	02/09/24 RESULTS (ppb)	02/09/24 ACTIONS	LAB SAMPLE I.D. No.	06/18/24 RE-SAMPLE RESULTS (ppb)	06/18/24 RE- SAMPLE ACTIONS	LAB SAMPLE I.D. No.	08/14/24 RE-SAMPLE RESULTS (ppb)	08/14/24 RE-SAMPLE ACTIONS	LAB SAMPLE I.D. No.	10/18/2024 RE-SAMPLE RESULTS (ppb)	10/18/24 RE-SAMPLE ACTIONS	LAB SAMPLE I.D. No.	10/23/2024 RE-SAMPLE RESULTS (ppb)	10/23/24 RE-SAMPLE ACTIONS
<b>BUILDING SECTION 'C'</b>																		
Hallway/Corridor - C108	Fountain	Public Access	030	CN-F100	15.4	See Note 8.	011	126.0	See Note 6.	006	<1.0	None	006	<1.0	None	006	<1.0	None
<b>BUILDING SECTION 'B'</b>																		
Rm. B104 - Classroom	Sink	Public Access	033	CN-S503	2.5	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - B1	Fountain	Public Access	031	CN-F4004	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - B1	Fountain	Public Access	032	CN-F4005	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - B124	Fountain	Public Access	034	CN-F5005	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - B124	Fountain	Public Access	035	CN-F5006	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - B54	Fountain	Public Access	036	CN-F4003	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. B005 - Gym Storage Room	Sink	Secured - SCSD Staff Only	037	CN-S115	8.4	See Note 8.	012	<1.0	None.	---	---	---	004	<1.0	None	---	---	---
Rm. B05 - Tech Classroom	Sink	Secured - SCSD Staff Only	038	CN-S4006	1.9	None	---	---	---	---	---	---	---	---	---	---	---	---
Lobby - B001	Fountain	Public Access	039	CN-F4000	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Lobby - B001	Fountain	Public Access	040	CN-F4001	<1.0	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. B023 - Boy's Pool Lockerroom	Fountain	Public Access	041	CN-F109	1.4	None	---	---	---	---	---	---	---	---	---	---	---	---
Rm. B104 - Classroom	Sink	Secured - SCSD Staff Only	042	CN-S506	12.8	See Note 8.	010	8.7	See Note 8.	---	---	---	---	---	---	---	---	---
Rm. B017 - Girl's Pool Lockers	Fountain	Public Access	---	CN-F110	---	See Note 6.	013	2.3	None.	---	---	---	---	---	---	---	---	---
Hallway/Corridor - B55	Fountain	Public Access	---	CN-F107	---	See Note 6.	014	13.3	See Note 6.	007	6.4	See Note 6.	003	3.2	None	---	---	---
Rm. B61 - Pool	Fountain	Public Access	---	CN-F108	---	See Note 6.	---	---	---	---	---	---	---	---	---	---	---	---
Hallway/Corridor - B54	Fountain	Public Access	---	CN-F4002	---	See Note 6.	---	---	---	---	---	---	---	---	---	001	1.8	None
Rm. B04 - Ag. Shop	Fountain	Public Access	---	CN-F102	---	See Note 7.	---	---	---	---	---	---	---	---	---	---	---	---
Rm. B04 - Ag. Shop	Sink	Public Access	---	CN-S4000	---	See Note 7.	---	---	---	---	---	---	---	---	---	---	---	---
Rm. B04 - Ag. Shop	Sink	Public Access	---	CN-S4001	---	See Note 7.	---	---	---	---	---	---	---	---	---	---	---	---
Rm. B04 - Ag. Shop	Sink	Public Access	---	CN-S4001	---	See Note 7.	---	---	---	---	---	---	---	---	---	---	---	---
Rm. B04 - Ag. Shop	Sink	Public Access	---	CN-S4002	---	See Note 7.	---	---	---	---	---	---	---	---	---	---	---	---
Rm. B04 - Ag. Shop	Sink	Public Access	---	CN-S4003	---	See Note 7.	---	---	---	---	---	---	---	---	---	---	---	---
Rm. B04 - Ag. Shop	Sink	Public Access	---	CN-S4004	---	See Note 7.	---	---	---	---	---	---	---	---	---	---	---	---

# SYRACUSE CITY SCHOOL DISTRICT CORCORAN HIGH SCHOOL

## Notes [02/09/2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-025
2. Water samples analyzed by: Pace Analytical Services, LLC. Pace Project No. 70286977.
  3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture inoperative.
7. Fixture removed by SCSD.
8. Fixture repaired by SCSD.

## Notes [06/18/2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-025A
2. Water samples analyzed by: Pace Analytical Services, LLC. Pace Project No. 70302043.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.
7. Fixture removed and replaced by SCSD.
8. Fixture signed by SCSD.

## Notes [08/14/2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-025A
2. Water samples analyzed by: Pace Analytical Services, LLC. Pace Project No. 70309137.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.

## Notes [10/18/2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-025A
2. Water samples analyzed by: Pace Analytical Services, LLC. Pace Project No. 70318533.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.

## Notes [10/23/2024 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-025A
2. Water samples analyzed by: Pace Analytical Services, LLC. Pace Project No. 70318925.
3. New York State Department of Health Standard for Lead in Drinking Water is 5 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.