

SYRACUSE CITY SCHOOL DISTRICT
CORCORAN HIGH SCHOOL FIELD HOUSE

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	06/12/2024 SAMPLE RESULTS (ppb)	06/12/2024 ORIGINAL ACTIONS	LAB SAMPLE I.D. No.	08/08/2024 RE-SAMPLE RESULTS (ppb)	08/08/2024 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	10/18/2024 RE-SAMPLE RESULTS (ppb)	10/18/2024 RE-SAMPLE ACTIONS	LAB RE-SAMPLE I.D. No.	11/26/2024 RE-SAMPLE RESULTS (ppb)	11/26/2024 RE-SAMPLE ACTIONS
Outside Wall Mount	Fountain	Public Access	008	CFH-F100	<1.0	None	--	---	---	--	---	---	--	---	---
Outside Wall Mount	Fountain	Public Access	009	CFH-F101	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. A1 - Concession Stand	Sink	Secured - SCSD Staff Only	001	CFH-S100	19.3	See Note .	001	25.3	See Note 6.	001	7.4	See Note 6.	001	9.5	See Note 6.
Rm. A1 - Concession Stand	Sink	Secured - SCSD Staff Only	002	CFH-S101	2.1	None	---	---	---	---	---	---	---	---	---
Rm. A1 - Concession Stand	Sink	Secured - SCSD Staff Only	003	CFH-S102	2.8	None	---	---	---	---	---	---	---	---	---
Rm. A5 - Home Team Locker Room	Ice Machine	Public Access	007	CFH-S110	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. A5 - Home Team Locker Room	Hose Bib	Public Access	006	CFH-S111	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. A8 - Visiting Team Locker Room	High Hose Bib	Public Access	004	CFH-S112	<1.0	None	---	---	---	---	---	---	---	---	---
Rm. A8 - Visiting Team Locker Room	Low Hose Bib	Public Access	005	CFH-S115	4.1	None	---	---	---	---	---	---	---	---	---

Notes [June 12, 2024]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-045
2. Water samples analyzed By: Pace Analytical Services, LLC. Pace Project No. 70301307
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture replaced by SCSD.

Notes [August 8, 2024]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-045
2. Water samples analyzed By: Pace Analytical Services, LLC. Pace Project No. 70308212
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.

Notes [October 18, 2024]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-045
2. Water samples analyzed By: Pace Analytical Services, LLC. Pace Project No. 70318536
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture repaired by SCSD.

Notes [November 26, 2024]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-045
2. Water samples analyzed By: Pace Analytical Services, LLC. Pace Project No. 70324965
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. SCSD to evaluate fixture for repair or removal.