

**SYRACUSE CITY SCHOOL DISTRICT
MSAP (SHEA) SCHOOL**

SAMPLE DATE: 11/07/24

ANALYSIS DATE: 11/18/24

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE I.D. No.	TDK SAMPLE I.D. No.	11/07/24 RESULTS (ppb)	11/07/24 ACTIONS
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	006	MSAP-S115	201	See Note 6.
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	001	MSAP-S117	3.9	None
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	002	MSAP-S118	63.4	See Note 6.
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	003	MSAP-S119	4.1	None
Rm. 106 - Kitchen	Sink	Secured - SCSD Staff Only	004	MSAP-S120	1.2	None
Rm. 114 - Classroom	Sink	Public Access	009	MSAP-S105	5.9	See Note 6.
Rm. 116 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	008	MSAP-S100	<1.0	None
Rm. 120 - Girl's Locker Room	Fountain	Public Access	013	MSAP-F101	<1.0	None
Rm. 130A - Hallway/Corridor	Fountain	Public Access	007	MSAP-F103	<1.0	None
Rm. 130J - Hallway/Corridor	Fountain	Public Access	012	MSAP-F100	7.8	See Note 6.
Rm. 211P - Storage Room	Sink	Secured - SCSD Staff Only	025	MSAP-S138	9.1	See Note 6.
Rm. 225 - Hallway/Corridor	Fountain	Public Access	026	MSAP-F104	<1.0	None
Rm. 225H - Hallway/Corridor	Fountain	Public Access	015	MSAP-F107	1.6	None
Rm. 225J - Hallway/Vestibule	Fountain	Public Access	014	MSAP-F106	<1.0	None
Rm. 225N - Hallway/Corridor	Fountain	Public Access	018	MSAP-F105	<1.0	None
Rm. 225N - Hallway/Corridor	Fountain	Public Access	017	MSAP-F105A	<1.0	None
Rm. 235 - Exam Office	Sink	Public Access	023	MSAP-S141	5.1	See Note 6.
Rm. 237 - Nurse's Office	Sink	Public Access	020	MSAP-S145	6.1	See Note 6.
Rm. 238 - Exam Room	Sink	Public Access	022	MSAP-S143	6.7	See Note 6.
Rm. 238 - Exam Room	Sink	Public Access	021	MSAP-S143A	42.6	See Note 6.
Rm. 239 - Conference Room	Sink	Secured - SCSD Staff Only	024	MSAP-S142	2.4	None
Rm. 245 - Clinic Office	Sink	Public Access	016	MSAP-S150	8.3	See Note 6.
Kitchenette in Renovated Area	Sink	Public Access	010	MSAP-S1000	5.9	See Note 6.
Kitchenette in Renovated Area	Sink	Public Access	011	MSAP-S1001	<1.0	None
Rm. 232 - Waiting Room	Sink	Public Access	019	MSAP-S3000	8.1	See Note 6.
Rm. 106 - Kitchen	Convotherm (Oven)	Secured - SCSD Staff Only	005	MSAP-C1001	3.7	None

SYRACUSE CITY SCHOOL DISTRICT
MSAP (SHEA) SCHOOL

SAMPLE DATE: 11/07/24

ANALYSIS DATE: 11/18/24

Notes [November 07, 2024 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-033
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70321289
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. SCSD to evaluate fixture for repair or removal.