

SYRACUSE CITY SCHOOL DISTRICT
McCARTHY AT BEARD SPECIAL EDUCATION SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	07/09/20 RESULTS (ppb)	07/09/20 ORIGINAL ACTIONS	11/04/20 RESULTS (ppb)	11/04/20 RESAMPLE ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 RESAMPLE ACTIONS
Rm. 101A - Teacher's Lounge	Sink	Secured - SCSD Staff Only	--	BD-S100	--	See Note 7	--	--	--	--
Rm. 101A - Kitchen	Sink	Secured - SCSD Staff Only	011	BD-S108	2.0	None	--	--	--	--
Rm. 101A - Kitchen	Sink	Secured - SCSD Staff Only	012	BD-S109	9.7	None	--	--	--	--
Rm. 108 - Boy's Bathroom	Sink	Public Access	015 / 002	BD-S111	20.6	See Note 6	1.1	None	--	--
Rm. 108 - Boy's Bathroom	Sink	Public Access	016	BD-S112	13.4	None	--	--	--	--
Rm. 110 - Hallway/Corridor	Fountain	Public Access	014	BD-F103	1.2	None	--	--	--	--
Rm. 111B - Clinic Room	Sink	Public Access	009	BD-S106	6.1	None	--	--	--	--
Rm. 111C - Clinic Bathroom	Sink	Public Access	010	BD-S107	5.8	None	--	--	--	--
Rm. 112 - Boy's Bathroom	Sink	Public Access	004	BD-S102	3.8	None	--	--	--	--
Rm. 113 - Girl's Bathroom	Sink	Public Access	003	BD-S103	12.5	None	--	--	--	--
Rm. 114D - Office Bathroom	Sink	Secured - SCSD Staff Only	008	BD-S104	6.6	None	--	--	--	--
Rm. 129 - Hallway/Corridor	Fountain	Public Access	005	BD-F100	<1.0	None	--	--	--	--
Rm. 137 - Men's Bathroom	Sink	Secured - SCSD Staff Only	006	BD-S101C	1.9	None	--	--	--	--
Rm. 158 - Storage Room Bathroom	Bathroom Sink	Secured - SCSD Staff Only	002 / 001	BD-S105	169.0	See Note 6	17.6	See Note 6	--	--
Rm. 163 - Hallway/Corridor	Fountain	Public Access	001	BD-F102	<1.0	None	--	--	--	--
Rm. 210 - Boy's Bathroom	Sink	Public Access	022	BD-S116	3.0	None	--	--	--	--
Rm. 210 - Boy's Bathroom	Sink	Public Access	023	BD-S117	2.0	None	--	--	--	--
Rm. 217 - Boy's Bathroom	Sink	Public Access	018	BD-S113	6.7	None	--	--	--	--
Rm. 217 - Boy's Bathroom	Sink	Public Access	017	BD-S114	11.2	None	--	--	--	--
Rm. 223 - Hallway/Corridor	Fountain	Public Access	019	BD-F104	<1.0	None	--	--	--	--
Rm. 239 - Staff Bathroom	Bathroom Sink	Secured - SCSD Staff Only	--- / --- / 001	BD-S118	--	See Note 7	--	See Note 7	4.0	None
Rm. 115 - Official Meeting Room	Sink	Public Access	007	BD-S1000	13.2	None	--	--	--	--
Rm. 101A - Kitchen	Sink	Secured - SCSD Staff Only	013	BD-S1001	4.4	None	--	--	--	--
Rm. 211 - Girl's Bathroom	Sink	Public Access	020	BD-S1002	3.7	None	--	--	--	--
Rm. 211 - Girl's Bathroom	Sink	Public Access	021 / 003	BD-S1003	27.2	See Note 6	<1.0	None	--	--

SYRACUSE CITY SCHOOL DISTRICT

McCARTHY AT BEARD SPECIAL EDUCATION SCHOOL

Original Sample Notes (July 9, 2020 Event):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-011
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70138736
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed, replaced and resampled.
7. Fixture not operating.

Re-Sample Notes (November 4, 2020 Event):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-011
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70152552
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture placarded/signed by SCSD.
7. Fixture not accessible.

Re-Sample Notes (December 30, 2020 Event):

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-011
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70158348
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.