

**SYRACUSE CITY SCHOOL DISTRICT
BELLEVUE ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	06/18/20 RESULTS (ppb)	06/18/20 ORIGINAL ACTIONS
Rm. C205 - Hallway/Corridor	Fountain	Public Access	---	BE-F107	---	See Note 6
Rm. 210 - Cafetorium	Fountain	Public Access	013	BE-F111	<1.0	
Rm. 208 - Kitchen	Sink	Secured - SCSD Staff Only	021	BE-S138	3.3	
Rm. 208 - Kitchen	Sink	Secured - SCSD Staff Only	018	BE-S139	1.5	
Rm. C200 - Hallway/Corridor	Fountain	Public Access	045	BE-F114	2.8	
Rm. 201 - Nurse's Office	Sink	Public Access	055	BE-S148	1.4	
Rm. 100 - Pre-K Classroom	Sink	Public Access	002	BE-S1000	<1.0	
Rm. 100 - Pre-K Classroom	Fountain	Public Access	003	BE-F1000	1.9	
Rm. 100a - Bathroom	Sink	Public Access	004	BE-S1001	2.3	
Rm. 101 - Pre-K Classroom	Sink	Public Access	008	BE-S1002	1.4	
Rm. 101 - Pre-K Classroom	Fountain	Public Access	009	BE-F1001	1.7	
Rm. 101a - Bathroom	Sink	Public Access	010	BE-S1003	2.7	
Rm. 102 - Pre-K Classroom	Sink	Public Access	014	BE-S1004	3.1	
Rm. 102 - Pre-K Classroom	Fountain	Public Access	017	BE-F1002	2.7	
Rm. 102a - Bathroom	Sink	Public Access	015	BE-S1005	2.5	
Rm. 111 - Kindergarten Classroom	Sink	Public Access	024	BE-S1006	3.5	
Rm. 111 - Kindergarten Classroom	Fountain	Public Access	025	BE-F1003	1.7	
Rm. 111a - Bathroom	Sink	Public Access	026	BE-S1007	1.0	
Rm. 112 - Kindergarten Classroom	Sink	Public Access	029	BE-S1008	1.1	
Rm. 112 - Kindergarten Classroom	Fountain	Public Access	030	BE-F1004	1.9	
Rm. 112a - Bathroom	Sink	Public Access	032	BE-S1009	<1.0	
Rm. 116 - Kindergarten Classroom	Sink	Public Access	034	BE-S1010	1.1	
Rm. 116 - Kindergarten Classroom	Fountain	Public Access	035	BE-F1005	1.1	
Rm. 116a - Bathroom	Sink	Public Access	036	BE-S1011	1.2	
Rm. 117 - Kindergarten Classroom	Fountain	Public Access	043	BE-F1006	<1.0	
Rm. 117 - Kindergarten Classroom	Sink	Public Access	042	BE-S1012	1.1	
Rm. 117a - Bathroom	Sink	Public Access	044	BE-S1013	1.9	
Rm. 110 - Men's Bathroom	Sink	Public Access	022	BE-S1014	<1.0	
Rm. 118 - Women's Bathroom	Sink	Public Access	046	BE-S1015	2.2	
Rm. 121 - Girl's Bathroom	Sink	Public Access	047	BE-S1016	1.5	
Rm. C104 - Hallway/Corridor	Sink	Public Access	048	BE-S1017	<1.0	

**SYRACUSE CITY SCHOOL DISTRICT
BELLEVUE ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	06/18/20 RESULTS (ppb)	06/18/20 ORIGINAL ACTIONS
Rm. C104 - Hallway/Corridor	Sink	Public Access	049	BE-S1018	<1.0	
Rm. C104 - Hallway/Corridor	Sink	Public Access	050	BE-S1019	<1.0	
Rm. C105 - Hallway/Corridor	Fountain	Public Access	052	BE-F1007	<1.0	
Rm. C105 - Hallway/Corridor	Fountain	Public Access	051	BE-F1008	<1.0	
Rm. 205 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	005	BE-S1020	<1.0	
Rm. 207c - Bathroom	Sink	Public Access	001	BE-S1021	1.1	
Rm. 206a - Change Room	Sink	Public Access	006	BE-S1022	2.0	
Rm. 210a - Bathroom	Sink	Public Access	007	BE-S1023	1.4	
Rm. 208a - Bathroom	Sink	Secured - SCSD Staff Only	016	BE-S1024	<1.0	
Rm. 208 - Kitchen	Sink (Faucet)	Secured - SCSD Staff Only	023	BE-S1025	2.8	
Rm. 208 - Kitchen	Sink (Spray)	Secured - SCSD Staff Only	027	BE-S1026	1.4	
Rm. 212 - Men's Bathroom	Sink	Public Access	037	BE-S1027	<1.0	
Rm. 213 - Women's Bathroom	Sink	Public Access	031	BE-S1028	<1.0	
Rm. C204 - Hallway/Corridor	Sink	Public Access	039	BE-S1029	<1.0	
Rm. C204 - Hallway/Corridor	Sink	Public Access	040	BE-S1030	<1.0	
Rm. C204 - Hallway/Corridor	Sink	Public Access	041	BE-S1031	<1.0	
Rm. C205 - Hallway/Corridor	Fountain	Public Access	033	BE-F1009	<1.0	
Rm. C205 - Hallway/Corridor	Fountain	Public Access	038	BE-F1010	<1.0	
Rm. 202b - Bathroom	Sink	Public Access	054	BE-S1032	1.4	
Rm. 201a - Bathroom	Sink	Public Access	056	BE-S1033	<1.0	
Rm. 200b - Bathroom	Sink	Secured - SCSD Staff Only	053	BE-S1034	<1.0	
Rm. 210b - Bathroom	Sink	Public Access	012	BE-S1035	<1.0	
Rm. 210b - Bathroom	Sink	Public Access	011	BE-S1036	<1.0	
Rm. C103 - Hallway/Corridor	Fountain	Public Access	019	BE-F3000	<1.0	
Rm. C103 - Hallway/Corridor	Fountain	Public Access	020	BE-F3001	<1.0	
Rm. 211 - Parent Room	Sink	Public Access	028	BE-S2000	5.5	

Original Sample Notes [June 18, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-009.
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project ID No. 70135581
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation of Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture not operating / subsequently removed.

