

**SYRACUSE CITY SCHOOL DISTRICT
WESTSIDE ACADEMY AT BLODGETT SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	07/09/20 RESULTS (ppb)	07/09/20 ORIGINAL ACTIONS	08/08/20 RESULTS (ppb)	08/08/20 RE- SAMPLE ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 RE- SAMPLE ACTIONS	01/23/21 RESULTS (ppb)	01/23/21 RE- SAMPLE ACTIONS
Rm. 113 - Classroom	Sink	Public Access	008/002	BT-S408	86.1	See Note 6	10.4	None	---	---	---	---
Rm. 111 - Classroom	Sink	Public Access	025	BT-S412	5.6	None	---	---	---	---	---	---
Rm. 111 - Classroom	Sink	Public Access	026	BT-S413	1.7	None	---	---	---	---	---	---
Rm. 116 - Music Classroom	Fountain	Public Access	040	BT-F401	<1.0	None	---	---	---	---	---	---
Rm. 110 - F.A.C.S Classroom	Sink	Public Access	019	BT-S410	<1.0	None	---	---	---	---	---	---
Rm. 110 - F.A.C.S Classroom	Sink	Public Access	020	BT-S411	3.3	None	---	---	---	---	---	---
Rm. 118 - Art Room	Sink	Public Access	045	BT-S418	3.0	None	---	---	---	---	---	---
Rm. 119 - Classroom	Sink	Public Access	036	BT-S417	8.0	None	---	---	---	---	---	---
Rm. 113 - Classroom Bathroom	Sink	Public Access	007	BT-S407	8.7	None	---	---	---	---	---	---
Rm. 104 - Storage Bathroom	Sink	Public Access	003/001	BT-S409	21.6	See Note 6	<1.0	None	---	---	---	---
Rm. 125 - Locker Room Bathroom	Sink	Public Access	054	BT-S422	5.2	None	---	---	---	---	---	---
Rm. 125 - Locker Room Bathroom	Sink	Public Access	053/003	BT-S423	50.9	See Note 6	13.6	None	---	---	---	---
Rm. 120 - Hallway/Corridor	Fountain	Public Access	---/---/002	BT-F403	---	See Note 7	---	See Note 6	2.3	None	---	---
Rm. 120 - Hallway/Corridor	Fountain	Public Access	055	BT-F402	<1.0	None	---	---	---	---	---	---
Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	058	BT-S424	4.1	None	---	---	---	---	---	---
Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	059	BT-S425	2.0	None	---	---	---	---	---	---
Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	056	BT-S420	1.9	None	---	---	---	---	---	---
Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	057	BT-S421	8.1	None	---	---	---	---	---	---
Rm. 121 - Custodian's Bathroom	Sink	Secured - SCSD Staff Only	051	BT-S419	2.5	None	---	---	---	---	---	---
Rm. 202 - Social Worker Room	Sink	Public Access	060	BT-S324	3.3	None	---	---	---	---	---	---
Rm. 204 - Health Center	Sink	Public Access	062	BT-S325	2.1	None	---	---	---	---	---	---
Rm. 204 - Health Center	Sink	Public Access	062	BT-S326	3.9	None	---	---	---	---	---	---
Rm. 204 - Health Center Bathroom	Sink	Public Access	063	BT-S327	3.5	None	---	---	---	---	---	---
Rm. 204 - Health Center	Sink	Public Access	066/005	BT-S328	21.3	See Note 6	8.6	None	---	---	---	---
Rm. 204 - Health Center	Sink	Public Access	067	BT-S329	2.6	None	---	---	---	---	---	---
Rm. 204 - Health Center	Sink	Public Access	065/004	BT-S330	17.8	See Note 6	7.7	None	---	---	---	---
Rm. 206 - Nurse's Office	Sink	Public Access	068	BT-S331	2.3	None	---	---	---	---	---	---
Rm. 206 - Nurse's Office	Sink	Public Access	070	BT-S332	2.5	None	---	---	---	---	---	---
Rm. 206 - Nurse's Office Bathroom	Sink	Public Access	071	BT-S333	2.9	None	---	---	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
WESTSIDE ACADEMY AT BLODGETT SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	07/09/20 RESULTS (ppb)	07/09/20 ORIGINAL ACTIONS	08/08/20 RESULTS (ppb)	08/08/20 RE- SAMPLE ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 RE- SAMPLE ACTIONS	01/23/21 RESULTS (ppb)	01/23/21 RE- SAMPLE ACTIONS
Rm. 207 - Office Bathroom	Sink	Secured - SCSD Staff Only	081	BT-S334	4.3	None	---	---	---	---	---	---
Rm. 226 - Cafeteria	Fountain	Public Access	074	BT-F404	4.8	None	---	---	---	---	---	---
Kitchen	Sink (Faucet)	Secured - SCSD Staff Only	078	BT-S429	5.7	None	---	---	---	---	---	---
Kitchen	Sink (Spray)	Secured - SCSD Staff Only	079	BT-S430	1.8	None	---	---	---	---	---	---
Rm. 226A - Serving Room	Sink	Secured - SCSD Staff Only	075	BT-S428	4.9	None	---	---	---	---	---	---
Rm. 400B - Classroom	Sink	Public Access	011	BT-S302	1.2	None	---	---	---	---	---	---
Rm. 401 - Classroom	Sink	Public Access	010	BT-S301	5.5	None	---	---	---	---	---	---
Rm. 102 - Girl's Bathroom	Sink	Public Access	014	BT-S1000	4.0	None	---	---	---	---	---	---
Rm. 102 - Girl's Bathroom	Sink	Public Access	016	BT-S1001	<1.0	None	---	---	---	---	---	---
Rm. 102 - Girl's Bathroom	Sink	Public Access	017	BT-S1002	<1.0	None	---	---	---	---	---	---
Rm. 100A - Hallway/Corridor	Fountain	Public Access	012	BT-F1000	<1.0	None	---	---	---	---	---	---
Rm. 108 - OT/PT	Sink	Public Access	048	BT-S1003	6.4	None	---	---	---	---	---	---
Rm. 103 - Boys Bathroom	Sink	Public Access	030	BT-S1004	1.7	None	---	---	---	---	---	---
Rm. 103 - Boys Bathroom	Sink	Public Access	031	BT-S1005	1.9	None	---	---	---	---	---	---
Rm. 103 - Boys Bathroom	Sink	Public Access	032	BT-S1006	1.9	None	---	---	---	---	---	---
Rm. 103 - Boys Bathroom	Sink	Public Access	033	BT-S1007	1.8	None	---	---	---	---	---	---
Rm. 100C - Hallway/Corridor	Fountain	Public Access	027	BT-F1001	<1.0	None	---	---	---	---	---	---
Rm. 100C - Hallway/Corridor	Fountain	Public Access	028	BT-F1002	<1.0	None	---	---	---	---	---	---
Rm. 103B - Staff Bathroom	Sink	Secured - SCSD Staff Only	029	BT-S1008	1.9	None	---	---	---	---	---	---
Rm. 116 - Music Classroom	Sink	Public Access	041	BT-S2001	1.2	None	---	---	---	---	---	---
Passageway	Sink	Public Access	042	BT-S1009	3.6	None	---	---	---	---	---	---
Custodian's Bathroom	Sink	Secured - SCSD Staff Only	064	BT-S1010	10.4	None	---	---	---	---	---	---
Rm. 203A - Girl's Bathroom	Sink	Public Access	077	BT-S1011	<1.0	None	---	---	---	---	---	---
Rm. 203A - Girl's Bathroom	Sink	Public Access	076	BT-S1012	1.7	None	---	---	---	---	---	---
Rm. 203A - Girl's Bathroom	Sink	Public Access	080	BT-S1013	1.0	None	---	---	---	---	---	---
Rm. 221 - Hallway/Corridor	Fountain	Public Access	072	BT-F1003	<1.0	None	---	---	---	---	---	---
Rm. 221 - Hallway/Corridor	Fountain	Public Access	073	BT-F1004	<1.0	None	---	---	---	---	---	---
Rm. 217A - Boys Bathroom	Sink	Public Access	086	BT-S1014	1.1	None	---	---	---	---	---	---
Rm. 217A - Boys Bathroom	Sink	Public Access	085	BT-S1015	<1.0	None	---	---	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
WESTSIDE ACADEMY AT BLODGETT SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	07/09/20 RESULTS (ppb)	07/09/20 ORIGINAL ACTIONS	08/08/20 RESULTS (ppb)	08/08/20 RE- SAMPLE ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 RE- SAMPLE ACTIONS	01/23/21 RESULTS (ppb)	01/23/21 RE- SAMPLE ACTIONS
Rm. 217A - Boys Bathroom	Sink	Public Access	083	BT-S1016	<1.0	None	---	---	---	---	---	---
Rm. 217A - Boys Bathroom	Sink	Public Access	082	BT-S1017	<1.0	None	---	---	---	---	---	---
Rm. 221 - Hallway/Corridor	Fountain	Public Access	088	BT-F1005	<1.0	None	---	---	---	---	---	---
Rm. 221 - Hallway/Corridor	Fountain	Public Access	087	BT-F1006	<1.0	None	---	---	---	---	---	---
Rm. 221A - Staff Bathroom	Sink	Secured - SCSD Staff Only	084	BT-S2018	<1.0	None	---	---	---	---	---	---
Rm. 303 - Girl's Bathroom	Sink	Public Access	039	BT-S1019	2.7	None	---	---	---	---	---	---
Rm. 303 - Girl's Bathroom	Sink	Public Access	038	BT-S1020	<1.0	None	---	---	---	---	---	---
Rm. 318 - Hallway/Corridor	Fountain	Public Access	034	BT-F1007	<1.0	None	---	---	---	---	---	---
Rm. 318 - Hallway/Corridor	Fountain	Public Access	035	BT-F1008	<1.0	None	---	---	---	---	---	---
Rm. 303 - Girl's Bathroom	Sink	Public Access	037	BT-S1021	2.2	None	---	---	---	---	---	---
Rm. 311 - Boy's Bathroom	Sink	Public Access	047	BT-S1022	1.6	None	---	---	---	---	---	---
Rm. 311 - Boy's Bathroom	Sink	Public Access	046	BT-S1023	<1.0	None	---	---	---	---	---	---
Rm. 311 - Boy's Bathroom	Sink	Public Access	044	BT-S1024	<1.0	None	---	---	---	---	---	---
Rm. 318 - Hallway/Corridor	Fountain	Public Access	050	BT-F1009	<1.0	None	---	---	---	---	---	---
Rm. 318 - Hallway/Corridor	Fountain	Public Access	049	BT-F1010	<1.0	None	---	---	---	---	---	---
Rm. 311 - Boy's Bathroom	Sink	Public Access	043	BT-S1025	<1.0	None	---	---	---	---	---	---
Rm. 309 - Staff Bathroom	Sink	Secured - SCSD Staff Only	052	BT-S1026	1.0	None	---	---	---	---	---	---
Rm. 413- Girl's Bathroom	Sink	Public Access	006	BT-S1027	1.4	None	---	---	---	---	---	---
Rm. 413 - Girl's Bathroom	Sink	Public Access	005	BT-S1028	1.3	None	---	---	---	---	---	---
Rm. 423 - Hallway/Corridor	Fountain	Public Access	001	BT-F1011	<1.0	None	---	---	---	---	---	---
Rm. 423 - Hallway/Corridor	Fountain	Public Access	002	BT-F1012	<1.0	None	---	---	---	---	---	---
Rm. 413- Girl's Bathroom	Sink	Public Access	004	BT-S1029	1.5	None	---	---	---	---	---	---
Rm. 430 - Boy's Bathroom	Sink	Public Access	023	BT-S1030	1.1	None	---	---	---	---	---	---
Rm. 430 - Boy's Bathroom	Sink	Public Access	022	BT-S1031	<1.0	None	---	---	---	---	---	---
Rm. 430 - Boy's Bathroom	Sink	Public Access	021	BT-S1032	1.6	None	---	---	---	---	---	---
Rm. 430 - Boy's Bathroom	Sink	Secured - SCSD Staff Only	018	BT-S1033	<1.0	None	---	---	---	---	---	---
Rm. 423 - Hallway/Corridor	Fountain	Public Access	015	BT-F1013	<1.0	None	---	---	---	---	---	---
Rm. 423 - Hallway/Corridor	Fountain	Public Access	013	BT-F1014	<1.0	None	---	---	---	---	---	---
Rm. 411 - Classroom	Sink	Public Access	---/---/001/001	BT-S3003	---	See Note 7	---	---	25.4	See Note 6	2.4	None

SYRACUSE CITY SCHOOL DISTRICT WESTSIDE ACADEMY AT BLODGETT SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	07/09/20 RESULTS (ppb)	07/09/20 ORIGINAL ACTIONS	08/08/20 RESULTS (ppb)	08/08/20 RE-SAMPLE ACTIONS	12/30/20 RESULTS (ppb)	12/30/20 RE-SAMPLE ACTIONS	01/23/21 RESULTS (ppb)	01/23/21 RE-SAMPLE ACTIONS
Rm. 113 - Classroom	Fountain	Public Access	009	BT-F5000	1,620	See Note 8	---	See Note 6	---	See Note 7	---	---
Rm. 430A - Staff Bathroom	Sink	Secured - SCSD Staff Only	024	BT-S1034	<1.0	None	---	---	---	---	---	---
Rm. 120 - Storage	Sink	Secured - SCSD Staff Only	069	BT-S5000	3.1	None	---	---	---	---	---	---

Original Sample Notes: [June 17, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-034
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70135461
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed, replaced and resampled.
7. Fixture not operating.
8. Fixture disconnected.

Re-Sample Notes: [August 8, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-034
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70141473
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture not operating.

Re-Sample Notes: [December 30, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-034
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70158349
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed, replaced and resampled.
7. Fixture removed.

Re-Sample Notes: [January 23, 2021 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-034
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70160643
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.