

**SYRACUSE CITY SCHOOL DISTRICT
DELAWARE ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	6/18/2020 RESULTS (ppb)	6/18/2020 ORIGINAL ACTIONS	8/12/2020 RESULTS (ppb)	8/12/2020 RESAMPLE ACTIONS
Rm. 101 - Classroom	Sink	Public Access	076	DE-S332	1.1	None	---	---
Rm. 101 - Classroom	Fountain	Public Access	077	DE-F310	2.6	None	---	---
Rm. 101A - Classroom Bathroom	Sink	Public Access	078	DE-S333	6.6	None	---	---
Rm. 102 - Classroom	Sink	Public Access	065	DE-S330	1.7	None	---	---
Rm. 102 - Classroom	Fountain	Public Access	068	DE-F309	2.8	None	---	---
Rm. 102A - Classroom Bathroom	Sink	Public Access	069	DE-S331	<1.0	None	---	---
Rm. 103 - Classroom	Sink	Public Access	057	DE-S325	<1.0	None	---	---
Rm. 103 - Classroom	Fountain	Public Access	056	DE-F307	4.7	None	---	---
Rm. 103A - Classroom Bathroom	Sink	Public Access	058	DE-S326	1.2	None	---	---
Rm. 104 - Classroom	Sink	Public Access	050	DE-S324	1.1	None	---	---
Rm. 104 - Classroom	Fountain	Public Access	051	DE-F306	1.9	None	---	---
Rm. 104A - Classroom Bathroom	Sink	Public Access	049	DE-S323	2.1	None	---	---
Rm. 105 - Classroom	Sink	Public Access	054	DE-S328	<1.0	None	---	---
Rm. 105 - Classroom	Fountain	Public Access	052	DE-F308	<1.0	None	---	---
Rm. 105A - Classroom Bathroom	Sink	Public Access	053	DE-S327	1.6	None	---	---
Rm. 108 - Classroom	Sink	Public Access	045	DE-S320	1.5	None	---	---
Rm. 108 - Classroom	Fountain	Public Access	044	DE-F304	1.8	None	---	---
Rm. 108A - Classroom Bathroom	Sink	Public Access	047	DE-S319	<1.0	None	---	---
Rm. 110 - Classroom	Sink	Public Access	035	DE-S318	2.7	None	---	---
Rm. 110 - Classroom	Fountain	Public Access	037	DE-F303	3.3	None	---	---
Rm. 112 - Classroom	Sink	Public Access	025	DE-S316	1.2	None	---	---
Rm. 112 - Classroom	Fountain	Public Access	026	DE-F302	5.5	None	---	---
Rm. 112A - Classroom Bathroom	Sink	Public Access	024	DE-S315	1.5	None	---	---
Rm. 113 - Art Room	Sink	Public Access	032	DE-S314	<1.0	None	---	---
Rm. 114A - Girl's Locker Room Bathroom	Sink	Public Access	022	DE-S312	8.7	None	---	---
Rm. 114A - Girl's Locker Room Bathroom	Sink	Public Access	023	DE-S313	3.2	None	---	---
Rm. 115B - Boy's Locker Room Bathroom	Sink	Public Access	020	DE-S311	5.0	None	---	---
Rm. 118 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	014	DE-S306	1.1	None	---	---
Rm. 118A - Teacher's Lounge Bathroom	Sink	Secured - SCSD Staff Only	015	DE-S307	<1.0	None	---	---
Rm. 119D - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	018	DE-S310	4.6	None	---	---

**SYRACUSE CITY SCHOOL DISTRICT
DELAWARE ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	6/18/2020 RESULTS (ppb)	6/18/2020 ORIGINAL ACTIONS	8/12/2020 RESULTS (ppb)	8/12/2020 RESAMPLE ACTIONS
Rm. 120 - Serving Room	Sink	Secured - SCSD Staff Only	001	DE-S301	1.9	None	---	---
Rm. 120 - Serving Room	Sink	Secured - SCSD Staff Only	002	DE-S302	1.9	None	---	---
Rm. 120 - Serving Room	Sink	Secured - SCSD Staff Only	003	DE-S303	<1.0	None	---	---
Rm. 120 - Serving Room	Sink	Secured - SCSD Staff Only	004	DE-S304	<1.0	None	---	---
Rm. 120A - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	005	DE-S305	2.3	None	---	---
Rm. 123A - Hallway/Corridor	Fountain	Public Access	013	DE-F301	2.0	None	---	---
Rm. 129 - Hallway/Corridor	Fountain	Public Access	038	DE-F305	<1.0	None	---	---
Rm. 134B - Staff Bathroom	Sink	Secured - SCSD Staff Only	059	DE-S329	1.1	None	---	---
Rm. 141A - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	039	DE-S321	2.4	None	---	---
Rm. 141B - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	041	DE-S322	2.3	None	---	---
Rm. 145A - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	016	DE-S308	1.9	None	---	---
Rm. 145B - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	017	DE-S309	3.2	None	---	---
Rm. 190A - Classroom Bathroom	Sink	Public Access	034	DE-S317	1.0	None	---	---
Rm. 206A - Clinic Bathroom	Sink	Public Access	074	DE-S342	2.4	None	---	---
Rm. 206B - Clinical Lab	Sink	Public Access	075	DE-S341	15.0	None	---	---
Rm. 206C - Treatment Center	Sink	Public Access	079	DE-S340	7.3	None	---	---
Rm. 206D - Dental Room	Sink	Public Access	082	DE-S339	1.7	None	---	---
Rm. 206E - Sick/Rest Room	Sink	Public Access	080	DE-S338	3.4	None	---	---
Rm. 206F - Nurse's Room	Sink	Public Access	081	DE-S337	10.5	None	---	---
Rm. 208C - Storage Room Bathroom	Sink	Secured - SCSD Staff Only	073	DE-S343	<1.0	None	---	---
Rm. 209 - Nurse's Room	Sink	Public Access	071	DE-S345	1.3	None	---	---
Rm. 209A - Nurse's Bathroom	Sink	Public Access	070	DE-S344	1.3	None	---	---
Rm. 211A - Office Bathroom	Sink	Secured - SCSD Staff Only	061	DE-S351	1.2	None	---	---
Rm. 211B - Office Bathroom	Sink	Secured - SCSD Staff Only	060	DE-S350	1.6	None	---	---
Rm. 232 - Hallway/Corridor	Fountain	Public Access	084	DE-F311	<1.0	None	---	---
Rm. 235 - Hallway/Vestibule	Sink	Public Access	087	DE-S334	1.4	None	---	---
Rm. 235 - Hallway/Vestibule	Sink	Public Access	086	DE-S335	1.7	None	---	---
Rm. 235 - Hallway/Vestibule	Sink	Public Access	085	DE-S336	<1.0	None	---	---
Rm. 240 - Hallway/Vestibule	Sink	Public Access	062	DE-S346	1.2	None	---	---

**SYRACUSE CITY SCHOOL DISTRICT
DELAWARE ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	6/18/2020 RESULTS (ppb)	6/18/2020 ORIGINAL ACTIONS	8/12/2020 RESULTS (ppb)	8/12/2020 RESAMPLE ACTIONS
Rm. 240 - Hallway/Vestibule	Sink	Public Access	063	DE-S347	1.6	None	---	---
Rm. 240 - Hallway/Vestibule	Sink	Public Access	066	DE-S348	3.3	None	---	---
Rm. 240 - Hallway/Vestibule	Sink	Public Access	067	DE-S349	1.3	None	---	---
Rm. 240 - Hallway/Vestibule	Fountain	Public Access	064	DE-F312	<1.0	None	---	---
Rm. 245 - Gym Lobby	Fountain	Public Access	055	DE-F313	<1.0	None	---	---
Rm. 306A - Classroom Bathroom	Sink	Public Access	040	DE-S359	1.6	None	---	---
Rm. 308A - Classroom Bathroom	Sink	Public Access	036	DE-S358	<1.0	None	---	---
Rm. 319 - Work Room	Sink	Public Access	027	DE-S352	8.7	None	---	---
Rm. 324A - Hallway/Corridor	Fountain	Public Access	021	DE-F314	<1.0	None	---	---
Rm. 330A - Hallway/Vestibule	Fountain	Public Access	048	DE-F317	<1.0	None	---	---
Rm. 335 - Hallway/Vestibule	Sink	Public Access	042	DE-S360	1.4	None	---	---
Rm. 335 - Hallway/Vestibule	Sink	Public Access	043	DE-S361	<1.0	None	---	---
Rm. 335 - Hallway/Vestibule	Sink	Public Access	046	DE-S362	1.8	None	---	---
Rm. 340 - Hallway/Vestibule	Sink	Public Access	033	DE-S354	1.6	None	---	---
Rm. 340 - Hallway/Vestibule	Sink	Public Access	031	DE-S355	1.1	None	---	---
Rm. 340 - Hallway/Vestibule	Sink	Public Access	029	DE-S356	5.6	None	---	---
Rm. 340 - Hallway/Vestibule	Sink	Public Access	028	DE-S357	2.6	None	---	---
Rm. 340 - Hallway/Vestibule	Fountain	Public Access	030	DE-F315	<1.0	None	---	---
Rm. 345A - Teacher's Lounge Bathroom	Sink	Secured - SCSD Staff Only	019	DE-S353	<1.0	None	---	---
Rm. 405 - Girl's Bathroom	Sink	Public Access	008	DE-S363	3.5	None	---	---
Rm. 405 - Girl's Bathroom	Sink	Public Access	007	DE-S364	1.9	None	---	---
Rm. 406 - Boy's Bathroom	Sink	Public Access	011	DE-S366	1.6	None	---	---
Rm. 406 - Boy's Bathroom	Sink	Public Access	010	DE-S367	<1.0	None	---	---
Rm. 407 - Staff Bathroom	Sink	Secured - SCSD Staff Only	012	DE-S365	1.5	None	---	---
Rm. 429 - Hallway/Corridor	Fountain	Public Access	009	DE-F316	<1.0	None	---	---
Rm. 120 - Serving Room	Convotherm Oven	Secured - SCSD Staff Only	006 / 001	DE-C1000	180.0	See Note 6	54.0	See Note 6
Rm. 209 - Nurse's Room	Sink (Spray Hose)	Public Access	072	DE-S1000	5.7	None	---	---
Rm. 206C - Treatment Center	Sink (Spray Hose)	Public Access	083	DE-S1001	4.4	None	---	---
Rm. 206B - Clinical Lab	Sink (Spray Hose)	Public Access	088 / 002	DE-S1002	117.0	See Note 7	43.4	See Note 7

SYRACUSE CITY SCHOOL DISTRICT DELAWARE ELEMENTARY SCHOOL

Original Sample Notes [June 18, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-022
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70135572
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. In-line filter installed by SCSD and resampling performed.
7. Remediation performed by SCSD.

Re-Sample Notes [August 12, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-022
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70142047
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed from service. Evaluation being performed by SCSD.
7. Remediation performed by SCSD.