

**SYRACUSE CITY SCHOOL DISTRICT  
DR. KING ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	02/29/20 RESULTS (ppb)	02/29/20 ORIGINAL ACTIONS	08/12/20 RE-SAMPLE RESULTS (ppb)	08/12/20 RE-SAMPLE ACTIONS	11/14/20 RE-SAMPLE RESULTS (ppb)	11/14/20 RE-SAMPLE ACTIONS
Rm. A102 - Hallway/Corridor	Fountain	Public Access	118	DK-F301	<1.0	None	---	---	---	---
Rm. A102 - Hallway/Corridor	Fountain	Public Access	116	DK-F302	<1.0	None	---	---	---	---
Rm. A113 - Kitchenette	Sink	Secured - SCSD Staff Only	056	DK-S325	<1.0	None	---	---	---	---
Rm. A113 - Kitchenette	Cooker Spray	Secured - SCSD Staff Only	060	DK-S501	<1.0	None	---	---	---	---
Rm. A116 - Classroom	Sink	Public Access	025	DK-S313	<1.0	None	---	---	---	---
Rm. A116 - Classroom	Fountain	Public Access	021	DK-F500	<1.0	None	---	---	---	---
Rm. A116A - Classroom Bathroom	Sink	Public Access	022	DK-S314	<1.0	None	---	---	---	---
Rm. A117 - Classroom	Sink	Public Access	012	DK-S311	1.6	None	---	---	---	---
Rm. A117 - Classroom	Fountain	Public Access	007	DK-F306	<1.0	None	---	---	---	---
Rm. A117A - Classroom Bathroom	Sink	Public Access	001	DK-S312	<1.0	None	---	---	---	---
Rm. A118 - Classroom	Sink	Public Access	108	DK-S309	<1.0	None	---	---	---	---
Rm. A118 - Classroom	Fountain	Public Access	112	DK-F305	<1.0	None	---	---	---	---
Rm. A118A - Classroom Bathroom	Sink	Public Access	113	DK-S310	<1.0	None	---	---	---	---
Rm. A119 - Classroom	Sink	Public Access	098	DK-S307	<1.0	None	---	---	---	---
Rm. A119 - Classroom	Fountain	Public Access	100	DK-F304	<1.0	None	---	---	---	---
Rm. A119A - Classroom Bathroom	Sink	Public Access	105	DK-S308	1.1	None	---	---	---	---
Rm. A120 - Classroom	Sink	Public Access	088	DK-S305	<1.0	None	---	---	---	---
Rm. A120 - Classroom	Fountain	Public Access	093	DK-F303	<1.0	None	---	---	---	---
Rm. A120A - Classroom Bathroom	Sink	Public Access	091	DK-S306	<1.0	None	---	---	---	---
Rm. A122 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	084	DK-S302	<1.0	None	---	---	---	---
Rm. A123 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	083	DK-S304	<1.0	None	---	---	---	---
Rm. A124 - Girl's Bathroom	Sink	Public Access	079	DK-S303	<1.0	None	---	---	---	---
Rm. A125 - Boy's Bathroom	Sink	Public Access	077	DK-S301	<1.0	None	---	---	---	---
Rm. A129 - Classroom	Sink	Public Access	071	DK-S323	<1.0	None	---	---	---	---
Rm. A129 - Classroom	Fountain	Public Access	075	DK-F311	<1.0	None	---	---	---	---
Rm. A129A - Classroom Bathroom	Sink	Public Access	070	DK-S324	<1.0	None	---	---	---	---
Rm. A130 - Classroom	Sink	Public Access	064	DK-S321	<1.0	None	---	---	---	---
Rm. A130 - Classroom	Fountain	Public Access	066	DK-F310	<1.0	None	---	---	---	---
Rm. A130A - Classroom Bathroom	Sink	Public Access	061	DK-S322	<1.0	None	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT  
DR. KING ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	02/29/20 RESULTS (ppb)	02/29/20 ORIGINAL ACTIONS	08/12/20 RE-SAMPLE RESULTS (ppb)	08/12/20 RE-SAMPLE ACTIONS	11/14/20 RE-SAMPLE RESULTS (ppb)	11/14/20 RE-SAMPLE ACTIONS
Rm. A131 - Classroom	Sink	Public Access	047	DK-S319	<1.0	None	---	---	---	---
Rm. A131 - Classroom	Fountain	Public Access	050	DK-F309	<1.0	None	---	---	---	---
Rm. A131A - Classroom Bathroom	Sink	Public Access	054	DK-S320	<1.0	None	---	---	---	---
Rm. A132 - Classroom	Sink	Public Access	040	DK-S317	<1.0	None	---	---	---	---
Rm. A132A - Classroom Bathroom	Sink	Public Access	041	DK-S318	<1.0	None	---	---	---	---
Rm. A133 - Classroom	Sink	Public Access	030	DK-S315	<1.0	None	---	---	---	---
Rm. A133 - Classroom	Fountain	Public Access	033	DK-F308	<1.0	None	---	---	---	---
Rm. A133A - Classroom Bathroom	Sink	Public Access	035	DK-S316	<1.0	None	---	---	---	---
Rm. B102 - Hallway/Corridor	Fountain	Public Access	150	DK-F312	<1.0	None	---	---	---	---
Rm. B102 - Hallway/Corridor	Fountain	Public Access	151	DK-F313	<1.0	None	---	---	---	---
Rm. B112 - Classroom	Sink	Public Access	124	DK-S326	4.4	None	---	---	---	---
Rm. B112 - Classroom	Sink	Public Access	125	DK-S327	1.4	None	---	---	---	---
Rm. B112 - Classroom	Sink	Public Access	126	DK-S328	3.1	None	---	---	---	---
Rm. B112 - Classroom	Sink	Public Access	131	DK-S329	<1.0	None	---	---	---	---
Rm. B115 - Resource & Staff Development	Sink	Secured - SCSD Staff Only	136	DK-S125	<1.0	None	---	---	---	---
Rm. B116 - Science Office	Sink	Public Access	132	DK-S330	<1.0	None	---	---	---	---
Rm. B118A - Boy's/Girl's Bathroom	Sink	Public Access	141	DK-S127	<1.0	None	---	---	---	---
Rm. B118B - Staff's Bathroom	Sink	Secured - SCSD Staff Only	143	DK-S126	<1.0	None	---	---	---	---
Rm. B122 - Media Work Room	Sink	Public Access	149	DK-S128	<1.0	None	---	---	---	---
Rm. B125 - Staff's Bathroom	Sink	Secured - SCSD Staff Only	153	DK-S124	<1.0	None	---	---	---	---
Rm. B126 - Boy's Bathroom	Sink	Public Access	156	DK-S123	1.2	None	---	---	---	---
Rm. B127 - Girl's Bathroom	Sink	Public Access	160	DK-S122	<1.0	None	---	---	---	---
Rm. B128 - Staff Lounge	Sink	Secured - SCSD Staff Only	155	DK-S121	<1.0	None	---	---	---	---
Rm. B128A - Staff Bathroom	Sink	Secured - SCSD Staff Only	152	DK-S120	<1.0	None	---	---	---	---
Rm. B129 - Classroom	Sink	Public Access	158	DK-S224	1.5	None	---	---	---	---
Rm. B129 - Classroom	Fountain	Public Access	161	DK-F203	1.6	None	---	---	---	---
Rm. B130 - Classroom	Sink	Public Access	140	DK-S223	<1.0	None	---	---	---	---
Rm. B133 - Music Room	Sink	Public Access	128	DK-S222	3.6	None	---	---	---	---
Rm. B134 - Classroom	Sink	Public Access	145	DK-S119	<1.0	None	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT  
DR. KING ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	02/29/20 RESULTS (ppb)	02/29/20 ORIGINAL ACTIONS	08/12/20 RE-SAMPLE RESULTS (ppb)	08/12/20 RE-SAMPLE ACTIONS	11/14/20 RE-SAMPLE RESULTS (ppb)	11/14/20 RE-SAMPLE ACTIONS
Rm. B134 - Classroom	Fountain	Public Access	146	DK-F107	1.0	None	---	---	---	---
Rm. B134A - Classroom Bathroom	Sink	Public Access	142	DK-S118	<1.0	None	---	---	---	---
Rm. B136 - Classroom	Sink	Public Access	135	DK-S117A	<1.0	None	---	---	---	---
Rm. B136 - Classroom	Fountain	Public Access	139	DK-S117B	<1.0	None	---	---	---	---
Rm. B136A - Classroom Bathroom	Sink	Public Access	134	DK-S116	1.0	None	---	---	---	---
Rm. C106 - Hallway/Corridor	Fountain	Public Access	107	DK-F100	<1.0	None	---	---	---	---
Rm. C106 - Hallway/Corridor	Fountain	Public Access	110	DK-F101	<1.0	None	---	---	---	---
Rm. C108 - Hallway/Corridor	Sink	Public Access	053	DK-S214	1.5	None	---	---	---	---
Rm. C108 - Hallway/Corridor	Sink	Public Access	052	DK-S216	<1.0	None	---	---	---	---
Rm. C111 - Staff Bathroom	Sink	Secured - SCSD Staff Only	114	DK-S114	<1.0	None	---	---	---	---
Rm. C112 - Café	Fountain	Public Access	103	DK-F201	<1.0	None	---	---	---	---
Rm. C112 - Café	Fountain	Public Access	106	DK-F202	<1.0	None	---	---	---	---
Rm. C113 - Girl's Bathroom	Sink	Public Access	099	DK-S203	<1.0	None	---	---	---	---
Rm. C113 - Girl's Bathroom	Sink	Public Access	102	DK-S204	<1.0	None	---	---	---	---
Rm. C115 - Boy's Bathroom	Sink	Public Access	096	DK-S201	<1.0	None	---	---	---	---
Rm. C115 - Boy's Bathroom	Sink	Public Access	097	DK-S202	<1.0	None	---	---	---	---
Rm. C117 - Kitchen	Sink	Secured - SCSD Staff Only	078	DK-S205	<1.0	None	---	---	---	---
Rm. C117 - Kitchen	Sink	Secured - SCSD Staff Only	082	DK-S206	<1.0	None	---	---	---	---
Rm. C117 - Kitchen	Sink	Secured - SCSD Staff Only	085	DK-S207	<1.0	None	---	---	---	---
Rm. C117 - Kitchen	Sink	Secured - SCSD Staff Only	087	DK-S208	<1.0	None	---	---	---	---
Rm. C117 - Kitchen	Stove Nozzle	Secured - SCSD Staff Only	090	DK-S-A	1.4	None	---	---	---	---
Rm.s C123 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	074	DK-S210	<1.0	None	---	---	---	---
Rm. C126 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	073	DK-S211	<1.0	None	---	---	---	---
Rm. C129 - Custodian Shop	Sink	Secured - SCSD Staff Only	068	DK-S209	<1.0	None	---	---	---	---
Rm. C132 - Nurse's Bathroom	Sink	Public Access	044	DK-S221	<1.0	None	---	---	---	---
Rm. C133 - Nurse's Room	Sink	Public Access	045	DK-S219	<1.0	None	---	---	---	---
Rm. C136 - Clean Room	Sink	Secured - SCSD Staff Only	049	DK-S217	1.1	None	---	---	---	---
Rm. C137 - Staff's Bathroom	Sink	Secured - SCSD Staff Only	065	DK-S215	<1.0	None	---	---	---	---
Rm. C138 - Sick Room	Sink	Public Access	043	DK-S220	<1.0	None	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT  
DR. KING ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	02/29/20 RESULTS (ppb)	02/29/20 ORIGINAL ACTIONS	08/12/20 RE-SAMPLE RESULTS (ppb)	08/12/20 RE-SAMPLE ACTIONS	11/14/20 RE-SAMPLE RESULTS (ppb)	11/14/20 RE-SAMPLE ACTIONS
Rm. C140 - Exam Room	Sink	Public Access	055	DK-S218	<1.0	None	---	---	---	---
Rm.s C141 - Exam Room	Sink	Public Access	057	DK-S213	1.9	None	---	---	---	---
Rm. C142 - Dental Room	Sink	Public Access	067	DK-S212	<1.0	None	---	---	---	---
Rm. C146A - Staff Bathroom	Sink	Secured - SCSD Staff Only	120/001	DK-S115	68.1	See Note 6	1.4	None	---	---
Rm. C147 - Mail Room	Sink	Secured - SCSD Staff Only	123	DK-S100	<1.0	None	---	---	---	---
Rm. C148 - Staff Bathroom	Sink	Secured - SCSD Staff Only	127	DK-S101	3.6	None	---	---	---	---
Rm. D101 - Hallway/Corridor	Fountain	Public Access	031	DK-F102	<1.0	None	---	---	---	---
Rm. D101 - Hallway/Corridor	Fountain	Public Access	034	DK-F103	<1.0	None	---	---	---	---
Rm. D108A - Hallway/Corridor	Fountain	Public Access	020	DK-F104	<1.0	None	---	---	---	---
Rm. D108A - Hallway/Corridor	Fountain	Public Access	024	DK-F105	<1.0	None	---	---	---	---
Rm. D113 - Kitchen	Sink	Secured - SCSD Staff Only	037	DK-S102	<1.0	None	---	---	---	---
Rm. D114 - Staff's Bathroom	Sink	Secured - SCSD Staff Only	029	DK-S103	<1.0	None	---	---	---	---
Rm. D115 - Staff's Bathroom	Sink	Secured - SCSD Staff Only	026	DK-S105	<1.0	None	---	---	---	---
Rm. D121A - PE Bathroom	Sink	Secured - SCSD Staff Only	018	DK-S104	<1.0	None	---	---	---	---
Rm. D127 - Classroom	Sink	Public Access	006	DK-S113	<1.0	None	---	---	---	---
Rm. D127A - Classroom Bathroom	Sink	Public Access	009	DK-S112	<1.0	None	---	---	---	---
Rm. D128 - Classroom	Sink	Public Access	003	DK-S111	<1.0	None	---	---	---	---
Rm. D128A - Classroom Bathroom	Sink	Public Access	002	DK-S110	1.1	None	---	---	---	---
Rm. D130 - Boy's Locker Room	Sink	Public Access	015	DK-S106	<1.0	None	---	---	---	---
Rm. D130 - Boy's Locker Room	Sink	Public Access	014	DK-S107	<1.0	None	---	---	---	---
Rm. D131 - Girl's Locker Room	Sink	Public Access	013	DK-S108	<1.0	None	---	---	---	---
Rm. D131 - Girl's Locker Room	Sink	Public Access	011	DK-S109	<1.0	None	---	---	---	---
Rm. A202 - Hallway/Corridor	Fountain	Public Access	111	DK-F314	<1.0	None	---	---	---	---
Rm. A202 - Hallway/Corridor	Fountain	Public Access	109	DK-F315	<1.0	None	---	---	---	---
Rm. A213 - Kitchenette	Sink	Public Access	175	DK-S353	<1.0	None	---	---	---	---
Rm. A217 - Classroom	Sink	Public Access	163	DK-S342	<1.0	None	---	---	---	---
Rm. A217 - Classroom	Fountain	Public Access	162	DK-F320	<1.0	None	---	---	---	---
Rm. A217A - Classroom Bathroom	Sink	Public Access	164	DK-S343	<1.0	None	---	---	---	---
Rm. A218 - Classroom	Sink	Public Access	157	DK-S340	1.6	None	---	---	---	---



**SYRACUSE CITY SCHOOL DISTRICT  
DR. KING ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	02/29/20 RESULTS (ppb)	02/29/20 ORIGINAL ACTIONS	08/12/20 RE-SAMPLE RESULTS (ppb)	08/12/20 RE-SAMPLE ACTIONS	11/14/20 RE-SAMPLE RESULTS (ppb)	11/14/20 RE-SAMPLE ACTIONS
Rm. A218 - Classroom	Fountain	Public Access	154	DK-F319	<1.0	None	---	---	---	---
Rm. A218A - Classroom Bathroom	Sink	Public Access	159	DK-S341	1.0	None	---	---	---	---
Rm. A219 - Classroom	Sink	Public Access	147	DK-S338	1.2	None	---	---	---	---
Rm. A219 - Classroom	Fountain	Public Access	144	DK-F318	<1.0	None	---	---	---	---
Rm. A219A - Classroom Bathroom	Sink	Public Access	148	DK-S339	<1.0	None	---	---	---	---
Rm. A220 - Classroom	Sink	Public Access	137	DK-S337	<1.0	None	---	---	---	---
Rm. A220 - Classroom	Fountain	Public Access	138	DK-F317	<1.0	None	---	---	---	---
Rm. A221 - Classroom	Sink	Public Access	122	DK-S335	<1.0	None	---	---	---	---
Rm. A221 - Classroom	Fountain	Public Access	121	DK-F316	<1.0	None	---	---	---	---
Rm. A221A - Classroom Bathroom	Sink	Public Access	133	DK-S336	<1.0	None	---	---	---	---
Rm. A222 - Staff Bathroom	Sink	Secured - SCSD Staff Only	130	DK-S334	<1.0	None	---	---	---	---
Rm. A223 - Staff Bathroom	Sink	Secured - SCSD Staff Only	119	DK-S333	<1.0	None	---	---	---	---
Rm. A224 - Girl's Bathroom	Sink	Public Access	117	DK-S332	<1.0	None	---	---	---	---
Rm. A225 - Boy's Bathroom	Sink	Public Access	115	DK-S331	<1.0	None	---	---	---	---
Rm. A233 - Classroom	Sink	Public Access	176	DK-S351	<1.0	None	---	---	---	---
Rm. A233 - Classroom	Fountain	Public Access	177	DK-F325	<1.0	None	---	---	---	---
Rm. A233A - Classroom Bathroom	Sink	Public Access	178	DK-S352	<1.0	None	---	---	---	---
Rm. A234 - Classroom	Sink	Public Access	171	DK-S350	<1.0	None	---	---	---	---
Rm. A234 - Classroom	Fountain	Public Access	174	DK-F324	<1.0	None	---	---	---	---
Rm. A235 - Classroom	Sink	Public Access	172	DK-S348	<1.0	None	---	---	---	---
Rm. A235 - Classroom	Fountain	Public Access	170	DK-F323	<1.0	None	---	---	---	---
Rm. A235A - Classroom Bathroom	Sink	Public Access	173	DK-S349	<1.0	None	---	---	---	---
Rm. A236 - Classroom	Sink	Public Access	169	DK-S346	<1.0	None	---	---	---	---
Rm. A236 - Classroom	Fountain	Public Access	167	DK-F322	<1.0	None	---	---	---	---
Rm. A236A - Classroom Bathroom	Sink	Public Access	168	DK-S347	4.2	None	---	---	---	---
Rm. A237 - Classroom	Sink	Public Access	129	DK-S344	2.0	None	---	---	---	---
Rm. A237 - Classroom	Fountain	Public Access	165	DK-F321	<1.0	None	---	---	---	---
Rm. A237A - Classroom Bathroom	Sink	Public Access	166	DK-S345	<1.0	None	---	---	---	---
Rm. B202 - Hallway/Corridor	Fountain	Public Access	094	DK-F205	<1.0	None	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT  
DR. KING ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	02/29/20 RESULTS (ppb)	02/29/20 ORIGINAL ACTIONS	08/12/20 RE-SAMPLE RESULTS (ppb)	08/12/20 RE-SAMPLE ACTIONS	11/14/20 RE-SAMPLE RESULTS (ppb)	11/14/20 RE-SAMPLE ACTIONS
Rm. B202 - Hallway/Corridor	Fountain	Public Access	095	DK-F206	<1.0	None	---	---	---	---
Rm. B211 - Classroom	Sink	Public Access	101	DK-S238	<1.0	None	---	---	---	---
Rm. B211 - Classroom	Sink	Public Access	104	DK-S239	<1.0	None	---	---	---	---
Rm. B214 - Boy's Bathroom	Sink	Public Access	092	DK-S236	<1.0	None	---	---	---	---
Rm. B214 - Boy's Bathroom	Sink	Public Access	089	DK-S237	<1.0	None	---	---	---	---
Rm. B216 - Girl's Bathroom	Sink	Public Access	051	DK-S234	<1.0	None	---	---	---	---
Rm. B216 - Girl's Bathroom	Sink	Public Access	086	DK-S235	<1.0	None	---	---	---	---
Rm. B217 - Classroom	Sink	Public Access	080	DK-S233	1.7	None	---	---	---	---
Rm. B217 - Classroom	Fountain	Public Access	076	DK-F204	<1.0	None	---	---	---	---
Rm. B217A - Classroom Bathroom	Sink	Public Access	081	DK-S232	<1.0	None	---	---	---	---
Rm. B218 - Classroom	Sink	Public Access	072	DK-S230	<1.0	None	---	---	---	---
Rm. B222 - Commons Kitchenette	Sink	Secured - SCSD Staff Only	069	DK-S231	<1.0	None	---	---	---	---
Rm. B223 - Classroom	Sink	Public Access	062	DK-S228	14.5	None	---	---	---	---
Rm. B224 - Classroom	Sink	Public Access	063	DK-S229	<1.0	None	---	---	---	---
Rm. B225 - Classroom	Sink	Public Access	059	DK-S227	<1.0	None	---	---	---	---
Rm. C202 - Hallway/Corridor	Fountain	Public Access	027	DK-F108	<1.0	None	---	---	---	---
Rm. C202 - Hallway/Corridor	Fountain	Public Access	032	DK-F109	<1.0	None	---	---	---	---
Rm. C213 - Staff's Bathroom	Sink	Secured - SCSD Staff Only	058	DK-S226	<1.0	None	---	---	---	---
Rm. C216 - Kitchenette	Sink	Secured - SCSD Staff Only	028	DK-S130	<1.0	None	---	---	---	---
Rm. C218 - Classroom	Sink	Public Access	038	DK-S129	<1.0	None	---	---	---	---
Rm. C219 - Classroom	Sink	Public Access	036	DK-S131	<1.0	None	---	---	---	---
Rm. C220 - Classroom	Sink	Public Access	023	DK-S132	<1.0	None	---	---	---	---
Rm. C221 - Classroom	Sink	Public Access	016	DK-S133	<1.0	None	---	---	---	---
Rm. C221 - Classroom	Fountain	Public Access	017	DK-F110	<1.0	None	---	---	---	---
Rm. C221A - Classroom Bathroom	Sink	Public Access	019	DK-S134	<1.0	None	---	---	---	---
Rm. C225 - Classroom	Sink	Public Access	004	DK-S136	<1.0	None	---	---	---	---
Rm. C225 - Classroom	Fountain	Public Access	005	DK-F111	<1.0	None	---	---	---	---
Rm. C225A - Classroom Bathroom	Sink	Public Access	008	DK-S135	<1.0	None	---	---	---	---
Rm. C226 - Classroom	Sink	Public Access	010	DK-S137	<1.0	None	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT  
DR. KING ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	02/29/20 RESULTS (ppb)	02/29/20 ORIGINAL ACTIONS	08/12/20 RE-SAMPLE RESULTS (ppb)	08/12/20 RE-SAMPLE ACTIONS	11/14/20 RE-SAMPLE RESULTS (ppb)	11/14/20 RE-SAMPLE ACTIONS
Rm. C227 - Classroom	Sink	Public Access	039/002	DK-S138	17.0	See Note 6	1.1	None	---	---
Rm. C228 - Classroom	Sink	Public Access	042	DK-S139	<1.0	None	---	---	---	---
Rm. C229 - Girl's Bathroom	Sink	Public Access	046	DK-S140	<1.0	None	---	---	---	---
Rm. C230 - Boy's Bathroom	Sink	Public Access	048	DK-S141	<1.0	None	---	---	---	---
Rm. A132 - Classroom	Fountain	Public Access	---/---/001	DK-F2000	---	See Note 7	---	See Note 6	2.9	None

Original Sample Notes [February 29, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-017
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70123874
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Remediation performed by SCSD.
7. Fixture not operating.

Re-Sample Notes [August 12, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-017
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70142048
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture not operating.

Re-Sample Notes [November 14, 2020 Event]:

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-017
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70153829
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.