

**SYRACUSE CITY SCHOOL DISTRICT
DR. WEEKS ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	03/07/2020 ORIGINAL RESULTS (ppb)	03/07/2020 ORIGINAL ACTIONS	08/08/2020 RE-SAMPLE RESULTS (ppb)	08/08/2020 RE-SAMPLE ACTIONS	10/24/2020 RE-SAMPLE RESULTS (ppb)	10/24/2020 RE-SAMPLE ACTIONS
Rm. 101 - Classroom	Fountain	Public Access	130	DW-F101	<1.0	None	--	--	--	--
Rm. 101 - Classroom	Sink	Public Access	135	DW-S105	<1.0	None	--	--	--	--
Rm. 101 - Classroom	Sink	Public Access	133	DW-S106	<1.0	None	--	--	--	--
Rm. 101B - Classroom Bathroom	Sink	Public Access	137	DW-S107	<1.0	None	--	--	--	--
Rm. 102 - Classroom	Sink	Public Access	143	DW-S103	<1.0	None	--	--	--	--
Rm. 102 - Classroom	Sink	Public Access	152	DW-S104	<1.0	None	--	--	--	--
Rm. 102 - Classroom	Fountain	Public Access	--/007	DW-F100	--	Fixture not operating.	4.6	None	--	--
Rm. 102A - Classroom Bathroom	Sink	Public Access	144	DW-S102	<1.0	None	--	--	--	--
Rm. 103 - Hallway/Corridor	Fountain	Public Access	148	DW-F102	<1.0	None	--	--	--	--
Rm. 103 - Hallway/Corridor	Fountain	Public Access	146	DW-F103	<1.0	None	--	--	--	--
Rm. 106 - Art Room	Sink	Public Access	031	DW-S100	1.6	None	--	--	--	--
Rm. 106 - Art Room	Sink	Public Access	030	DW-S101	<1.0	None	--	--	--	--
Rm. 110 - Hallway/Corridor	Fountain	Public Access	034	DW-F205	<1.0	None	--	--	--	--
Rm. 110 - Hallway/Corridor	Fountain	Public Access	033	DW-F206	<1.0	None	--	--	--	--
Rm. 113 - Staff Bathroom	Sink	Secured - SCSD Staff Only	013	DW-S204	1.1	None	--	--	--	--
Rm. 114 - Staff Bathroom	Sink	Secured - SCSD Staff Only	011	DW-S203	<1.0	None	--	--	--	--
Rm. 115 - Classroom	Fountain	Public Access	006	DW-F201	<1.0	None	--	--	--	--
Rm. 115 - Classroom	Sink	Public Access	004	DW-S201	1.0	None	--	--	--	--
Rm. 115 - Classroom	Sink	Public Access	007	DW-S202	6.3	None	--	--	--	--
Rm. 119 - Hallway/Corridor	Fountain	Public Access	009	DW-F202	<1.0	None	--	--	--	--
Rm. 119 - Hallway/Corridor	Fountain	Public Access	010	DW-F203	<1.0	None	--	--	--	--
Rm. 124 - Girl's Locker Room	Sink	Public Access	018	DW-S205	1.7	None	--	--	--	--
Rm. 125 - Boy's Locker Room	Sink	Public Access	020	DW-S206	1.3	None	--	--	--	--
Rm. 128 - Gym Office	Sink	Secured - SCSD Staff Only	026	DW-S207	4.5	None	--	--	--	--
Rm. 129 - Pool	Fountain	Public Access	025	DW-F204	8.1	None	--	--	--	--
Rm. 132 - Teacher's Room	Sink	Secured - SCSD Staff Only	032	DW-S208	1.3	None	--	--	--	--
Rm. 134 - Staff Bathroom	Sink	Secured - SCSD Staff Only	036	DW-S209	3.4	None	--	--	--	--
Rm. 135 - Hallway/Corridor	Fountain	Public Access	059	DW-F210A	<1.0	None	--	--	--	--
Rm. 135 - Hallway/Corridor	Fountain	Public Access	060	DW-F210B	<1.0	None	--	--	--	--
Rm. 136 - Classroom	Sink	Public Access	043	DW-S211	1.8	None	--	--	--	--
Rm. 136 - Classroom	Fountain	Public Access	042	DW-F207	<1.0	None	--	--	--	--

**SYRACUSE CITY SCHOOL DISTRICT
DR. WEEKS ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	03/07/2020 ORIGINAL RESULTS (ppb)	03/07/2020 ORIGINAL ACTIONS	08/08/2020 RE-SAMPLE RESULTS (ppb)	08/08/2020 RE-SAMPLE ACTIONS	10/24/2020 RE-SAMPLE RESULTS (ppb)	10/24/2020 RE-SAMPLE ACTIONS
Rm. 136A - Classroom Bathroom	Sink	Public Access	044	DW-S210	<1.0	None	--	--	--	--
Rm. 137 - Staff Bathroom	Sink	Secured - SCSD Staff Only	038	DW-S216	<1.0	None	--	--	--	--
Rm. 138 - Hallway/Vestibule	Sink	Public Access	045	DW-S214	<1.0	None	--	--	--	--
Rm. 139 - Hallway/Vestibule	Sink	Public Access	046	DW-S215	<1.0	None	--	--	--	--
Rm. 140 - Classroom	Sink	Public Access	052	DW-S213	1.1	None	--	--	--	--
Rm. 140 - Classroom	Fountain	Public Access	049	DW-F208	<1.0	None	--	--	--	--
Rm. 140A - Classroom Bathroom	Sink	Public Access	051	DW-S212	1.2	None	--	--	--	--
Rm. 141 - Classroom	Sink	Public Access	056	DW-S218	<1.0	None	--	--	--	--
Rm. 141 - Classroom	Fountain	Public Access	055	DW-F209	<1.0	None	--	--	--	--
Rm. 141A - Classroom Bathroom	Sink	Public Access	057	DW-S217	<1.0	None	--	--	--	--
Rm. 146 - Teacher's Work Room	Sink	Secured - SCSD Staff Only	066	DW-S220	<1.0	None	--	--	--	--
Rm. 147 - Classroom	Sink	Public Access	064	DW-S219	<1.0	None	--	--	--	--
Rm. 148 - Classroom	Sink	Public Access	075	DW-S222	1.1	None	--	--	--	--
Rm. 148 - Classroom	Fountain	Public Access	073	DW-F211A	<1.0	None	--	--	--	--
Rm. 148A - Classroom Bathroom	Sink	Public Access	074	DW-S221	<1.0	None	--	--	--	--
Rm. 149 - Classroom	Sink	Public Access	081	DW-S224	1.8	None	--	--	--	--
Rm. 149 - Classroom	Fountain	Public Access	079	DW-F211B	<1.0	None	--	--	--	--
Rm. 149A - Classroom Bathroom	Sink	Public Access	080	DW-S223	<1.0	None	--	--	--	--
Rm. 151 - Classroom	Sink	Public Access	084	DW-S225	1.7	None	--	--	--	--
Rm. 152 - Classroom	Sink	Public Access	090	DW-S227	1.1	None	--	--	--	--
Rm. 152 - Classroom	Fountain	Public Access	087	DW-F212	<1.0	None	--	--	--	--
Rm. 152A - Classroom Bathroom	Sink	Public Access	089	DW-S226	1.6	None	--	--	--	--
Rm. 154 - Classroom	Sink	Public Access	101	DW-S126B	<1.0	None	--	--	--	--
Rm. 154 - Classroom	Fountain	Public Access	098	DW-F111	<1.0	None	--	--	--	--
Rm. 154A - Classroom Bathroom	Sink	Public Access	102	DW-S126A	<1.0	None	--	--	--	--
Rm. 156 - Classroom	Sink	Public Access	117	DW-S228	2.6	None	--	--	--	--
Rm. 157 - Classroom	Sink	Public Access	114	DW-S125	<1.0	None	--	--	--	--
Rm. 157 - Classroom	Fountain	Public Access	107	DW-F110	<1.0	None	--	--	--	--
Rm. 157A - Classroom Bathroom	Sink	Public Access	115	DW-S124	<1.0	None	--	--	--	--
Rm. 158 - Staff Bathroom	Sink	Secured - SCSD Staff Only	118	DW-S123	1.4	None	--	--	--	--
Rm. 159 - Staff Bathroom	Sink	Secured - SCSD Staff Only	119	DW-S122	1.4	None	--	--	--	--

**SYRACUSE CITY SCHOOL DISTRICT
DR. WEEKS ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	03/07/2020 ORIGINAL RESULTS (ppb)	03/07/2020 ORIGINAL ACTIONS	08/08/2020 RE-SAMPLE RESULTS (ppb)	08/08/2020 RE-SAMPLE ACTIONS	10/24/2020 RE-SAMPLE RESULTS (ppb)	10/24/2020 RE-SAMPLE ACTIONS
Rm. 160 - Classroom	Sink	Public Access	120	DW-S121	2.0	None	--	--	--	--
Rm. 160 - Classroom	Fountain	Public Access	122	DW-F109	4.0	None	--	--	--	--
Rm. 160A - Classroom Bathroom	Sink	Public Access	121	DW-S120	<1.0	None	--	--	--	--
Rm. 162 - Classroom	Fountain	Public Access	125	DW-F108	<1.0	None	--	--	--	--
Rm. 162 - Classroom	Sink	Public Access	127	DW-S119	<1.0	None	--	--	--	--
Rm. 162A - Classroom Bathroom	Sink	Public Access	126	DW-S118	1.1	None	--	--	--	--
Rm. 165 - Classroom	Sink	Public Access	134	DW-S117	1.7	None	--	--	--	--
Rm. 165 - Classroom	Fountain	Public Access	131	DW-F107	<1.0	None	--	--	--	--
Rm. 165A - Classroom Bathroom	Sink	Public Access	132	DW-S116	1.3	None	--	--	--	--
Rm. 166 - Classroom	Sink	Public Access	139	DW-S115	<1.0	None	--	--	--	--
Rm. 166 - Classroom	Fountain	Public Access	136	DW-F106B	<1.0	None	--	--	--	--
Rm. 166A - Classroom Bathroom	Sink	Public Access	138	DW-S114	1.2	None	--	--	--	--
Rm. 168 - Hallway/Vestibule	Sink	Public Access	129	DW-S128	<1.0	None	--	--	--	--
Rm. 168 - Hallway/Vestibule	Sink	Public Access	128	DW-S129	<1.0	None	--	--	--	--
Rm. 167 - Classroom	Sink	Public Access	142	DW-S131	1.2	None	--	--	--	--
Rm. 167A - Classroom Bathroom	Sink	Public Access	141	DW-S130	<1.0	None	--	--	--	--
Rm. 173A - Classroom Bathroom	Sink	Public Access	150	DW-S132	<1.0	None	--	--	--	--
Rm. 174 - Classroom	Sink	Public Access	149	DW-S113	<1.0	None	--	--	--	--
Rm. 174 - Classroom	Fountain	Public Access	147	DW-F106A	<1.0	None	--	--	--	--
Rm. 174A - Classroom Bathroom	Sink	Public Access	145	DW-S112	<1.0	None	--	--	--	--
Rm. 176 - Classroom	Sink	Public Access	155	DW-S111	1.8	None	--	--	--	--
Rm. 176 - Classroom	Fountain	Public Access	154	DW-F105	<1.0	None	--	--	--	--
Rm. 176A - Classroom Bathroom	Sink	Public Access	156	DW-S110	<1.0	None	--	--	--	--
Rm. 177 - Classroom	Sink	Public Access	153	DW-S109	<1.0	None	--	--	--	--
Rm. 177 - Classroom	Fountain	Public Access	140	DW-F104	<1.0	None	--	--	--	--
Rm. 177A - Classroom Bathroom	Sink	Public Access	151	DW-S108	<1.0	None	--	--	--	--
Rm. 203 - Kitchen	Sink	Secured - SCSD Staff Only	029	DW-S321	<1.0	None	--	--	--	--
Rm. 204 - Staff Bathroom	Sink	Secured - SCSD Staff Only	028	DW-S312	1.2	None	--	--	--	--
Rm. 210 - Exam Room	Sink	Public Access	037	DW-S314	<1.0	None	--	--	--	--
Rm. 211 - Exam Room Bathroom	Sink	Public Access	040	DW-S316	<1.0	None	--	--	--	--
Rm. 212 - Dental Room	Sink	Public Access	041	DW-S317	1.3	None	--	--	--	--

**SYRACUSE CITY SCHOOL DISTRICT
DR. WEEKS ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	03/07/2020 ORIGINAL RESULTS (ppb)	03/07/2020 ORIGINAL ACTIONS	08/08/2020 RE-SAMPLE RESULTS (ppb)	08/08/2020 RE-SAMPLE ACTIONS	10/24/2020 RE-SAMPLE RESULTS (ppb)	10/24/2020 RE-SAMPLE ACTIONS
Rm. 213 - Clinic Room	Sink	Public Access	035	DW-S313	<1.0	None	--	--	--	--
Rm. 214 - Exam Room	Sink	Public Access	039	DW-S315	3.8	None	--	--	--	--
Rm. 216 - Treatment Room	Sink	Public Access	047	DW-S318	<1.0	None	--	--	--	--
Rm. 217 - Nurse's Room	Sink	Public Access	048	DW-S319	1.5	None	--	--	--	--
Rm. 217A - Exam Room Bathroom	Sink	Public Access	050	DW-S320	<1.0	None	--	--	--	--
Rm. 221 - Kitchen	Sink	Secured - SCSD Staff Only	022	DW-S305	3.5	None	--	--	--	--
Rm. 221 - Kitchen	Sink	Secured - SCSD Staff Only	012	DW-S306	<1.0	None	--	--	--	--
Rm. 221 - Kitchen	Convotherm (Left)	Secured - SCSD Staff Only	019/002	DW-A	23.2	Refer to Note 6	9.5	None	--	--
Rm. 221 - Kitchen	Convotherm (Right)	Secured - SCSD Staff Only	021/001/001	DW-B	48.0	Refer to Note 6	25.9	Refer to Note 6.	11.5	None
Rm. 221B - Kitchen	Sink	Secured - SCSD Staff Only	016	DW-S307	1.1	None	--	--	--	--
Rm. 221B - Kitchen	Sink	Secured - SCSD Staff Only	017/003	DW-S308	31.0	Refer to Note 7	2.4	None	--	--
Rm. 222 - Receiving Room	Sink	Secured - SCSD Staff Only	023	DW-S309	1.0	None	--	--	--	--
Rm. 222 - Receiving Room	Sink	Secured - SCSD Staff Only	024/005	DW-S310	67.5	Refer to Note 7	4.4	None	--	--
Rm. 222B - Staff Bathroom	Sink	Secured - SCSD Staff Only	027	DW-S311	1.4	None	--	--	--	--
Rm. 223 - Cafeteria	Fountain	Public Access	003	DW-F301	<1.0	None	--	--	--	--
Rm. 223 - Cafeteria	Fountain	Public Access	005	DW-F302	<1.0	None	--	--	--	--
Rm. 223 (225) - Hallway/Vestibule	Sink	Public Access	008	DW-S302	<1.0	None	--	--	--	--
Rm. 223 (224) - Hallway/Vestibule	Sink	Public Access	014	DW-S303	<1.0	None	--	--	--	--
Rm. 234A - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	002	DW-S304	<1.0	None	--	--	--	--
Rm. 228 - Staff Bathroom	Sink	Secured - SCSD Staff Only	001	DW-S301	1.3	None	--	--	--	--
Rm. 240 - Teacher's Room	Sink	Secured - SCSD Staff Only	062	DW-S244	<1.0	None	--	--	--	--
Rm. 241 - Staff Bathroom	Sink	Secured - SCSD Staff Only	063	DW-S243	8.8	None	--	--	--	--
Rm. 243 - Hallway/Corridor	Fountain	Public Access	078	DW-F213	<1.0	None	--	--	--	--
Rm. 243 - Hallway/Corridor	Fountain	Public Access	--/--/002	DW-F214	--	Fixture Not Operating.	--	--	<1.0	None
Rm. 244 (256) - Hallway/Vestibule	Sink	Public Access	108	DW-S229	<1.0	None	--	--	--	--
Rm. 244 (257) - Hallway/Vestibule	Sink	Public Access	106	DW-S230	<1.0	None	--	--	--	--
Rm. 244 (237) - Hallway/Vestibule	Sink	Public Access	086	DW-S239	<1.0	None	--	--	--	--
Rm. 244 (238) - Hallway/Vestibule	Sink	Public Access	085	DW-S238	<1.0	None	--	--	--	--
Rm. 245 - Classroom	Sink	Public Access	070	DW-S242	1.1	None	--	--	--	--
Rm. 245 - Classroom	Fountain	Public Access	067	DW-F215	<1.0	None	--	--	--	--
Rm. 245A - Classroom Bathroom	Sink	Public Access	071	DW-S241	<1.0	None	--	--	--	--

**SYRACUSE CITY SCHOOL DISTRICT
DR. WEEKS ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	03/07/2020 ORIGINAL RESULTS (ppb)	03/07/2020 ORIGINAL ACTIONS	08/08/2020 RE-SAMPLE RESULTS (ppb)	08/08/2020 RE-SAMPLE ACTIONS	10/24/2020 RE-SAMPLE RESULTS (ppb)	10/24/2020 RE-SAMPLE ACTIONS
Rm. 246 - Staff Bathroom	Sink	Secured - SCSD Staff Only	077	DW-S240	1.1	None	--	--	--	--
Rm. 250 - Classroom	Sink	Public Access	092	DW-S237	2.8	None	--	--	--	--
Rm. 251 - Classroom	Sink	Public Access	093	DW-S236	2.9	None	--	--	--	--
Rm. 252 - Classroom	Sink	Public Access	096	DW-S235	<1.0	None	--	--	--	--
Rm. 253 - Classroom	Sink	Public Access	099	DW-S234	1.8	None	--	--	--	--
Rm. 254 - Classroom	Sink	Secured - SCSD Staff Only	103	DW-S233	<1.0	None	--	--	--	--
Rm. 255B - Work Room	Sink	Secured - SCSD Staff Only	123	DW-S231	13.2	None	--	--	--	--
Rm. 255E - Media Center Bathroom	Sink	Public Access	124	DW-S245	<1.0	None	--	--	--	--
Rm. 258 - Classroom	Sink	Public Access	110	DW-S232	2.1	None	--	--	--	--
Rm. 261 - Classroom	Sink	Public Access	116	DW-S133	2.0	None	--	--	--	--
Rm. 262 - Classroom	Sink	Public Access	112	DW-S134	<1.0	None	--	--	--	--
Rm. 262 - Classroom	Fountain	Public Access	111	DW-F112	<1.0	None	--	--	--	--
Rm. 262A - Classroom Bathroom	Sink	Public Access	113/006	DW-S135	129.0	Refer to Note 7	3.4	None	--	--
Rm. 265 - Staff Bathroom	Sink	Secured - SCSD Staff Only	109	DW-S143	1.1	None	--	--	--	--
Rm. 267 - Staff Bathroom	Sink	Secured - SCSD Staff Only	015	DW-S142	1.2	None	--	--	--	--
Rm. 268 - Classroom	Sink	Public Access	105	DW-S136	1.5	None	--	--	--	--
Rm. 270 - Hallway/Vestibule	Sink	Public Access	094	DW-S140	<1.0	None	--	--	--	--
Rm. 270 - Hallway/Vestibule	Sink	Public Access	095	DW-S141	<1.0	None	--	--	--	--
Rm. 270 - Hallway/Corridor	Fountain	Public Access	097	DW-F113	<1.0	None	--	--	--	--
Rm. 270 - Hallway/Corridor	Fountain	Public Access	100	DW-F114	<1.0	None	--	--	--	--
Rm. 273 - Classroom	Sink	Public Access	104	DW-S137	1.9	None	--	--	--	--
Rm. 274 - Classroom	Sink	Public Access	091	DW-S138	2.2	None	--	--	--	--
Rm. 275 - Classroom	Sink	Public Access	088	DW-S139	<1.0	None	--	--	--	--
Rm. 277 - Classroom	Sink	Public Access	083	DW-S329	1.4	None	--	--	--	--
Rm. 278 - Classroom	Sink	Public Access	082	DW-S328	<1.0	None	--	--	--	--
Rm. 279 - Classroom	Sink	Public Access	068	DW-S326	<1.0	None	--	--	--	--
Rm. 279 - Classroom	Fountain	Public Access	065	DW-F305	<1.0	None	--	--	--	--
Rm. 279A - Classroom Bathroom	Sink	Public Access	069	DW-S327	<1.0	None	--	--	--	--
Rm. 280 - Staff Bathroom	Sink	Secured - SCSD Staff Only	076	DW-S325	1.3	None	--	--	--	--
Rm. 281 - Staff Bathroom	Sink	Secured - SCSD Staff Only	072	DW-S324	1.2	None	--	--	--	--
Rm. 283 - Hallway/Corridor	Fountain	Public Access	058	DW-F303	<1.0	None	--	--	--	--

**SYRACUSE CITY SCHOOL DISTRICT
DR. WEEKS ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	03/07/2020 ORIGINAL RESULTS (ppb)	03/07/2020 ORIGINAL ACTIONS	08/08/2020 RE-SAMPLE RESULTS (ppb)	08/08/2020 RE-SAMPLE ACTIONS	10/24/2020 RE-SAMPLE RESULTS (ppb)	10/24/2020 RE-SAMPLE ACTIONS
Rm. 283 - Hallway/Corridor	Fountain	Public Access	061	DW-F304	<1.0	None	--	--	--	--
Rm. 291 - Mail Room	Sink	Secured - SCSD Staff Only	054	DW-S323	5.5	None	--	--	--	--
Rm. 221B - Wash Room	Sink	Secured - SCSD Staff Only	--/004	DW-S3000	--	Fixture Not Operating	<1.0	None	--	--
Rm. 294 - Office Staff Bathroom	Sink	Secured - SCSD Staff Only	053	DW-S322	<1.0	None	--	--	--	--

Original Sample Notes: [March 7, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-004
2. Water samples analyzed By: Pace Analytical Services - Pace Project ID 70124741
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Filter installed by SCSD and resampling performed.
7. Fixture removed, replaced and resampled.

Re-Sample Notes: [August 8, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-004
2. Water samples analyzed By: Pace Analytical Services - Pace Project ID 70141475
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Evaluation performed by SCSD.

Re-Sample Notes: [October 24, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-004
2. Water samples analyzed By: Pace Analytical Services - Pace Project ID 70151484
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.