

**SYRACUSE CITY SCHOOL DISTRICT  
EXPEDITIONARY LEARNING CENTER MIDDLE SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	07/23/2020 ORIGINAL RESULTS (ppb)	07/23/2020 ORIGINAL ACTIONS	08/28/2020 RE-SAMPLE RESULTS (ppb)	08/28/2020 RE-SAMPLE ACTIONS	10/10/2020 RE-SAMPLE RESULTS (ppb)	10/10/2020 RE-SAMPLE ACTIONS
Rm. 106 - Nurse's Office	Sink	Public Access	036	ELMS-S316	13.9	None	--	--	--	--
Rm. 106A - Nurse's Office Bathroom	Sink	Public Access	037	ELMS-S317	6.4	None	--	--	--	--
Rm. 110 - Hallway/Corridor	Fountain	Public Access	004	ELMS-F311	<1.0	None	--	--	--	--
Rm. 116A - Locker Room Bathroom	Sink	Public Access	030	ELMS-S331	14.0	None	--	--	--	--
Rm. 119A - Classroom Bathroom	Sink	Public Access	031/001	ELMS-S334	23.8	See Note 6.	8.7	None	--	--
Rm. 120A - Classroom Bathroom	Sink	Public Access	033	ELMS-S336	3.1	None	--	--	--	--
Rm. 123 - Hallway/Corridor	Fountain	Public Access	028	ELMS-F332	<1.0	None	--	--	--	--
Rm. 124 - Staff Bathroom	Sink	Secured - SCSD Staff Only	035	ELMS-S337	1.8	None	--	--	--	--
Rm. 125A - Classroom Bathroom	Sink	Public Access	034	ELMS-S335	2.7	None	--	--	--	--
Rm. 127A - Classroom Bathroom	Sink	Public Access	032	ELMS-S333	6.9	None	--	--	--	--
Rm. 130A - Library Bathroom	Sink	Public Access	029	ELMS-S330	10.4	None	--	--	--	--
Rm. 135 - Hallway/Corridor	Fountain	Public Access	027	ELMS-F324	3.3	None	--	--	--	--
Rm. 137 - Girl's Locker Room Bathroom	Sink	Public Access	020/007/001	ELMS-S325	180.0	See Note 6.	19.1	See Note 6.	4.0	None
Rm. 137 - Girl's Locker Room Bathroom	Sink	Public Access	019/006	ELMS-S326	32.4	See Note 6.	6.0	None	--	--
Rm. 143 - Gym Office	Sink	Secured - SCSD Staff Only	016/005	ELMS-S329	16.1	See Note 6.	4.0	None	--	--
Rm. 145 - Kitchen	Sink	Secured - SCSD Staff Only	022	ELMS-S320	2.7	None	--	--	--	--
Rm. 145 - Kitchen	Sink	Secured - SCSD Staff Only	023	ELMS-S321	2.7	None	--	--	--	--
Rm. 145 - Kitchen	Sink	Secured - SCSD Staff Only	024	ELMS-S322	<1.0	None	--	--	--	--
Rm. 145 - Kitchen	Sink	Secured - SCSD Staff Only	025	ELMS-S323	8.7	None	--	--	--	--
Rm. 147 - Boy's Locker Room Bathroom	Sink	Public Access	017	ELMS-S327	10.9	None	--	--	--	--
Rm. 147 - Boy's Locker Room Bathroom	Sink	Public Access	018/004	ELMS-S328	16.9	See Note 6.	7.4	None	--	--
Rm. 150 - Staff's Bathroom	Sink	Secured - SCSD Staff Only	021	ELMS-S319	4.3	None	--	--	--	--
Rm. 154 - Kitchenette	Sink	Secured - SCSD Staff Only	026/002	ELMS-S318	15.3	See Note 6.	2.3	None	--	--
Rm. 165 - Break Room	Sink	Secured - SCSD Staff Only	002	ELMS-S315	1.3	None	--	--	--	--
Rm. 165A - Break Room Bathroom	Sink	Secured - SCSD Staff Only	001	ELMS-S313	8.8	None	--	--	--	--
Rm. 165B - Break Room Bathroom	Sink	Secured - SCSD Staff Only	003	ELMS-S314	4.5	None	--	--	--	--
Rm. 167 - Principal's Bathroom	Sink	Secured - SCSD Staff Only	005	ELMS-S312	6.1	None	--	--	--	--
Rm. 168 - Hallway/Vestibule	Sink	Public Access	007/003/002	ELMS-S309	15.9	See Note 6.	16.0	See Note 6.	8.7	None
Rm. 168 - Hallway/Vestibule	Sink	Public Access	006	ELMS-S310	12.4	None	--	--	--	--
Rm. 172A - Classroom Bathroom	Sink	Public Access	008	ELMS-S308	1.7	None	--	--	--	--
Rm. 176A - Classroom Bathroom	Sink	Public Access	009	ELMS-S307	2.4	None	--	--	--	--

**SYRACUSE CITY SCHOOL DISTRICT  
EXPEDITIONARY LEARNING CENTER MIDDLE SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	07/23/2020 ORIGINAL RESULTS (ppb)	07/23/2020 ORIGINAL ACTIONS	08/28/2020 RE-SAMPLE RESULTS (ppb)	08/28/2020 RE-SAMPLE ACTIONS	10/10/2020 RE-SAMPLE RESULTS (ppb)	10/10/2020 RE-SAMPLE ACTIONS
Rm. 178 - Classroom	Sink	Public Access	010	ELMS-S304	4.3	None	--	--	--	--
Rm. 178 - Classroom	Sink	Public Access	011	ELMS-S305	1.6	None	--	--	--	--
Rm. 178A - Classroom Bathroom	Sink	Public Access	012	ELMS-S306	13.9	None	--	--	--	--
Rm. 182 - Hallway/Corridor	Fountain	Public Access	013	ELMS-F303	<1.0	None	--	--	--	--
Rm. 189 - Art Room	Sink	Public Access	015	ELMS-S302	6.5	None	--	--	--	--
Rm. 190 - Kitchen	Sink	Secured - SCSD Staff Only	014	ELMS-S301	1.8	None	--	--	--	--

Original Sample Notes: [July 23, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-031
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70140232
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed, replaced and resampled.

Re-Sample Notes: [August 28, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-031
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70143985
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed, replaced and resampled.

SYRACUSE CITY SCHOOL DISTRICT  
EXPEDITIONARY LEARNING CENTER MIDDLE SCHOOL

Re-Sample Notes: [October 10, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-031
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70149567
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.