

**SYRACUSE CITY SCHOOL DISTRICT
ED SMITH PK - GRADE 8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	06/25/2020 SAMPLE RESULTS (ppb)	06/25/2020 ORIGINAL ACTIONS	08/12/2020 RE-SAMPLE RESULTS (ppb)	08/12/2020 RE-SAMPLE ACTIONS
Rm. 122 - Classroom	Sink	Public Access	004	EH-S103	1.8	None	--	--
Rm. 124 - Classroom	Sink	Public Access	009	EH-S106	<1.0	None	--	--
Rm. 124 - Toilet	Sink	Public Access	008	EH-S105	2.9	None	--	--
Rm. 156 - Classroom	Sink	Public Access	070	EH-S137	4.1	None	--	--
Rm. 158 - Classroom	Sink	Public Access	072	EH-S135	1.8	None	--	--
Rm. 160 - Classroom	Sink	Public Access	074	EH-S136	1.1	None	--	--
Rm. 104A - Work Room	Sink	Secured - SCSD Staff Only	083	EH-S150	5.5	None	--	--
Rm. 104B - Toilet	Sink	Public Access	081	EH-S147	1.4	None	--	--
Rm. 120 - Nurse's Office	Sink	Public Access	002	EH-S101	4.3	None	--	--
Rm. 133B - Copy Room	Sink	Secured - SCSD Staff Only	075	EH-S138	11.3	None	--	--
Rm. 127 - Kitchen	Sink- Faucet	Secured - SCSD Staff Only	042	EH-S123A	<1.0	None	--	--
Rm. 127 - Kitchen	Sink - Sprayer	Secured - SCSD Staff Only	044	EH-S123B	<1.0	None	--	--
Rm. 127 - Kitchen	Sink	Secured - SCSD Staff Only	043	EH-S124	1.7	None	--	--
Rm. 127 - Kitchen	Sink	Secured - SCSD Staff Only	045	EH-S125	13.7	None	--	--
Rm. 127 - Kitchen	Sink	Secured - SCSD Staff Only	048	EH-S126	8.9	None	--	--
Rm. 127 - Kitchen	Sink	Secured - SCSD Staff Only	049	EH-S127	15.6	See Note 6	1.4	None
Rm. 127 - Kitchen	Sink	Secured - SCSD Staff Only	050	EH-S128	3.0	None	--	--
Rm. 115 - Library Lounge	Sink	Secured - SCSD Staff Only	078	EH-S139	3.4	None	--	--
Rm. 013 - Classroom	Sink	Public Access	059	EH-S141	6.9	None	--	--
Rm. 013 - Classroom	Sink	Public Access	058	EH-S142	11.3	None	--	--
Rm. 201A - Storage Room	Sink	Secured - SCSD Staff Only	007	EH-S155	31.3	See Note 7	---	--
Rm. 127A - Toilet	Sink	Secured - SCSD Staff Only	039	EH-S122	10.8	None	--	--
Rm. 155 - ADA Toilet	Sink	Public Access	056	EH-S1000	<1.0	None	--	--
Rm. 139 - Art Classroom	Sink	Public Access	060	EH-S1001	1.7	None	--	--
Rm. 139 - Art Classroom	Sink	Public Access	061	EH-S1002	1.6	None	--	--
Rm. 154 - Girl's Toilet	Sink	Public Access	065	EH-S1003	<1.0	None	--	--
Rm. 154 - Girl's Toilet	Sink	Public Access	066	EH-S1004	<1.0	None	--	--
Rm. 152 - Boy's Toilet	Sink	Public Access	067	EH-S1005	<1.0	None	--	--
Rm. 152 - Boy's Toilet	Sink	Public Access	068	EH-S1006	<1.0	None	--	--
Rm. 131 - Boy's Toilet	Sink	Public Access	052	EH-S1007	<1.0	None	--	--
Rm. 129 - Girl's Toilet	Sink	Public Access	053	EH-S1008	<1.0	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT
ED SMITH PK - GRADE 8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	06/25/2020 SAMPLE RESULTS (ppb)	06/25/2020 ORIGINAL ACTIONS	08/12/2020 RE-SAMPLE RESULTS (ppb)	08/12/2020 RE-SAMPLE ACTIONS
Rm. 123 - Cafeteria	Fountain	Public Access	034	EH-F1000	<1.0	None	--	--
Rm. 123 - Cafeteria	Fountain	Public Access	035	EH-F1001	<1.0	None	--	--
Rm. 126F - Hallway/ Corridor	Fountain	Public Access	024	EH-F1002	<1.0	None	--	--
Rm. 126F - Hallway/ Corridor	Fountain	Public Access	025	EH-F1003	<1.0	None	--	--
Rm. 137A - Girl's Toilet	Sink	Public Access	027	EH-S1009	<1.0	None	--	--
Rm. 137A - Girl's Toilet	Sink	Public Access	028	EH-S1010	<1.0	None	--	--
Rm. 134 - Classroom	Sink	Public Access	021	EH-S1011	<1.0	None	--	--
Rm. 137B - Boy's Toilet	Sink	Public Access	031	EH-S2000	<1.0	None	--	--
Rm. 137B - Boy's Toilet	Sink	Public Access	032	EH-S2001	<1.0	None	--	--
Rm. 130/132 - ADA Toilet	Sink	Public Access	018	EH-S1012	<1.0	None	--	--
Rm. 117 - Women's Toilet	Sink	Public Access	076	EH-S1013	<1.0	None	--	--
Rm. 125 - Men's Toilet	Sink	Public Access	077	EH-S1014	<1.0	None	--	--
Rm. 126D - Hallway/ Corridor	Fountain	Public Access	006	EH-F1004	<1.0	None	--	--
Rm. 126 - Classroom	Sink	Public Access	014	EH-S2002	6.1	None	--	--
Rm. 126 - Toilet	Sink	Public Access	015	EH-S2003	1.0	None	--	--
Rm. 122 - Toilet	Sink	Public Access	005	EH-S2004	5.0	None	--	--
Rm. 114B - Toilet	Sink	Public Access	003	EH-S1015	<1.0	None	--	--
Rm. 118D - Toilet	Sink	Public Access	001	EH-S1016	<1.0	None	--	--
Rm. 116 - Girl's Toilet	Sink	Public Access	079	EH-S1017	<1.0	None	--	--
Rm. 116 - Girl's Toilet	Sink	Public Access	080	EH-S1018	<1.0	None	--	--
Rm. 126B - Hallway/ Corridor	Fountain	Public Access	082	EH-F1005	<1.0	None	--	--
Rm. 126B - Hallway/ Corridor	Fountain	Public Access	084	EH-F1006	<1.0	None	--	--
Rm. 106 - Boy's Toilet	Sink	Public Access	085	EH-S1019	<1.0	None	--	--
Rm. 106 - Boy's Toilet	Sink	Public Access	086	EH-S1020	<1.0	None	--	--
Rm. 228 - Girl's Locker	Sink	Public Access	040	EH-S1021	<1.0	None	--	--
Rm. 228 - Girl's Locker	Sink	Public Access	041	EH-S1022	<1.0	None	--	--
Rm. 230 - Gym	Fountain	Public Access	033	EH-F1009	<1.0	None	--	--
Rm. 230 - Gym	Fountain	Public Access	036	EH-F1010	<1.0	None	--	--
Rm. 234 - Boy's Locker	Sink	Public Access	037	EH-S1023	2.0	None	--	--
Rm. 234 - Boy's Locker	Sink	Public Access	038	EH-S1024	<1.0	None	--	--
Rm. 231 - Toilet	Sink	Public Access	030	EH-S1025	<1.0	None	--	--

**SYRACUSE CITY SCHOOL DISTRICT
ED SMITH PK - GRADE 8 SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink/Fountain)	ACCESSIBILITY	LABORATORY SAMPLE ID No.	TDK SAMPLE ID No.	06/25/2020 SAMPLE RESULTS (ppb)	06/25/2020 ORIGINAL ACTIONS	08/12/2020 RE-SAMPLE RESULTS (ppb)	08/12/2020 RE-SAMPLE ACTIONS
Rm. 229 - Toilet	Sink	Public Access	029	EH-S1026	<1.0	None	--	--
Rm. 227 - Boy's Toilet	Sink	Public Access	023	EH-S1027	<1.0	None	--	--
Rm. 227 - Boy's Toilet	Sink	Public Access	026	EH-S1028	<1.0	None	--	--
Rm. 225 - Girl's Toilet	Sink	Public Access	020	EH-S1029	<1.0	None	--	--
Rm. 225 - Girl's Toilet	Sink	Public Access	022	EH-S1030	<1.0	None	--	--
Rm. 219A - Hallway/ Corridor	Fountain	Public Access	019	EH-F1011	<1.0	None	--	--
Rm. 218 - Boy's Toilet	Sink	Public Access	016	EH-S1031	<1.0	None	--	--
Rm. 218 - Boy's Toilet	Sink	Public Access	017	EH-S1032	<1.0	None	--	--
Rm. 211 - Girl's Toilet	Sink	Public Access	012	EH-S1033	<1.0	None	--	--
Rm. 211 - Girl's Toilet	Sink	Public Access	013	EH-S1034	<1.0	None	--	--
Rm. 216 - Hallway/ Corridor	Fountain	Public Access	011	EH-F1007	<1.0	None	--	--
Rm. 216 - Hallway/ Corridor	Fountain	Public Access	010	EH-F1008	<1.0	None	--	--
Rm. 002B - Technology Shop	Sink	Public Access	073	EH-S1035	1.7	None	--	--
Rm. 012 - Hallway/ Corridor	Fountain	Public Access	069	EH-F1012	<1.0	None	--	--
Rm. 017 - Home & Careers	Sink	Public Access	054	EH-S1036	2.0	None	--	--
Rm. 017 - Home & Careers	Sink	Public Access	051	EH-S1037	1.3	None	--	--
Rm. 018 - ADA Toilet	Sink	Public Access	063	EH-S1038	<1.0	None	--	--
Rm. 016 - ADA Toilet	Sink	Public Access	062	EH-S1039	<1.0	None	--	--
Rm. 020 - Conference Room	Sink	Secured - SCSD Staff Only	047	EH-S2005	3.8	None	--	--
Rm. 127 - Kitchen	Convotherm Oven	Secured - SCSD Staff Only	046	EH-C1000	17.9	See Note 8	8.4	None
Rm. 017 - Home & Careers	Sink (Spray)	Public Access	055	EH-S3000	<1.0	None	--	--
Rm. 017 - Home & Careers	Sink (Spray)	Public Access	057	EH-S3001	<1.0	None	--	--
Hallway/ Corridor	Fountain	Public Access	064	EH-F2000	<1.0	None	--	--
Rm. 012 - Hallway/ Corridor	Fountain	Public Access	071	EH-F3002	<1.0	None	--	--

SYRACUSE CITY SCHOOL DISTRICT

ED SMITH PK - GRADE 8 SCHOOL

Original Sample Notes: [June 25, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-010
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70136247
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed, replaced and resampled.
7. Fixture removed.
8. In-line filter installed by SCSD and resampling performed.

Re-Sample Notes: [August 12, 2020 Event]

1. Water samples collected By: TDK Engineering Associates, P.C. - TDK Project No. 2016068-010
2. Water samples analyzed By: Pace Analytical Services, LLC - Pace Project No. 70142049
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.