

**SYRACUSE CITY SCHOOL DISTRICT
ELMWOOD ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	07/01/20 RESULTS (ppb)	07/01/20 ORIGINAL ACTIONS	08/05/20 RESULTS (ppb)	08/05/20 RE- SAMPLE ACTIONS	11/06/20 RESULTS (ppb)	11/06/20 RE- SAMPLE ACTIONS
Rm. 04 - Kitchen	Sink	Secured - SCSD Staff Only	002	ELM-S202	8.3	None	---	---	---	---
Rm. 04 - Kitchen	Sink	Secured - SCSD Staff Only	003	ELM-S203	1.7	None	---	---	---	---
Rm. 04 - Kitchen	Sink	Secured - SCSD Staff Only	008	ELM-S204	4.2	None	---	---	---	---
Rm. 08 - Kitchen Bathroom	Sink	Secured - SCSD Staff Only	011	ELM-M(S)200	7.8	None	---	---	---	---
Rm. 31A - Custodian's Bathroom	Sink	Secured - SCSD Staff Only	001	ELM-S211	<1.0	None	---	---	---	---
Rm. 40 - Hallway/Vestibule	Fountain	Public Access	016	ELM-F201	1.1	None	---	---	---	---
Rm. 40 - Hallway/Vestibule	Sink	Public Access	017/002	ELM-S206	29.3	See Note 6	13.1	None	---	---
Rm. 40 - Hallway/Vestibule	Sink	Public Access	020	ELM-S207	3.7	None	---	---	---	---
Rm. 40 - Hallway/Vestibule	Sink	Public Access	021	ELM-S208	9.8	None	---	---	---	---
Rm. 47 - Staff Bathroom	Sink	Secured - SCSD Staff Only	026	ELM-S109	1.7	None	---	---	---	---
Rm. 55 - Gym Office Bathroom	Sink	Secured - SCSD Staff Only	033	ELM-S106	2.8	None	---	---	---	---
Rm. 59 - Classroom	Sink	Public Access	037	ELM-S100	1.3	None	---	---	---	---
Rm. 59 - Classroom	Sink	Public Access	038	ELM-S101	6.7	None	---	---	---	---
Rm. 61 - Classroom	Sink	Public Access	035	ELM-S102	2.8	None	---	---	---	---
Rm. 61 - Classroom	Sink	Public Access	036	ELM-S103	<1.0	None	---	---	---	---
Rm. 63 - Classroom	Sink	Public Access	028	ELM-S107	<1.0	None	---	---	---	---
Rm. 63 - Classroom	Sink	Public Access	030	ELM-S108	<1.0	None	---	---	---	---
Rm. 68 - Storage Room	Sink	Secured - SCSD Staff Only	---/---/003	ELM-S105	---	See Note 7	---	---	26.7	See Note 6
Rm. 69 - PT Office	Sink	Secured - SCSD Staff Only	065/003/001	ELM-S104	91.5	See Note 6	2.3	---	4.6	None
Rm. 105 - Resource Room	Sink	Public Access	048	ELM-S125	1.4	None	---	---	---	---
Rm. 106 - Teacher's Lounge	Sink	Secured - SCSD Staff Only	041	ELM-S122	<1.0	None	---	---	---	---
Rm. 107 - Men's Staff Bathroom	Sink	Secured - SCSD Staff Only	044	ELM-S124	10.8	None	---	---	---	---
Rm. 109 - Women's Staff Bathroom	Sink	Secured - SCSD Staff Only	045	ELM-S123	1.9	None	---	---	---	---
Rm. 121A - Parent Room	Sink	Secured - SCSD Staff Only	057	ELM-S119	1.5	None	---	---	---	---
Rm. 124 - Hallway/Vestibule	Fountain	Public Access	051	ELM-F101	<1.0	None	---	---	---	---
Rm. 124 - Hallway/Vestibule	Sink	Public Access	052	ELM-S115	11.0	None	---	---	---	---
Rm. 124 - Hallway/Vestibule	Sink	Public Access	053	ELM-S116	1.5	None	---	---	---	---
Rm. 124 - Hallway/Vestibule	Sink	Public Access	054	ELM-S117	<1.0	None	---	---	---	---
Rm. 133 - Staff Bathroom	Sink	Public Access	047	ELM-S216	1.9	None	---	---	---	---

**SYRACUSE CITY SCHOOL DISTRICT
ELMWOOD ELEMENTARY SCHOOL**

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	07/01/20 RESULTS (ppb)	07/01/20 ORIGINAL ACTIONS	08/05/20 RESULTS (ppb)	08/05/20 RE- SAMPLE ACTIONS	11/06/20 RESULTS (ppb)	11/06/20 RE- SAMPLE ACTIONS
Rm. 134 - Classroom	Sink	Public Access	049	ELM-S212	2.1	None	---	---	---	---
Rm. 135 - Classroom Bathroom	Sink	Public Access	046	ELM-S213	5.0	None	---	---	---	---
Rm. 136 - Classroom	Sink	Public Access	042	ELM-S214	4.8	None	---	---	---	---
Rm. 137 - Classroom	Sink	Public Access	043	ELM-S215	<1.0	None	---	---	---	---
Rm. 138 - Classroom	Sink	Public Access	050	ELM-S217	8.8	None	---	---	---	---
Rm. 139 - Hallway/Corridor	Fountain	Public Access	060	ELM-F102	<1.0	None	---	---	---	---
Rm. 139 - Hallway/Corridor	Fountain	Public Access	061	ELM-F103	1.3	None	---	---	---	---
Rm. 142A - Classroom	Sink	Public Access	058	ELM-S113	4.4	None	---	---	---	---
Rm. 142A - Classroom	Fountain	Public Access	056	ELM-F100	4.4	None	---	---	---	---
Rm. 142B - Resource Room	Sink	Public Access	059	ELM-S110	<1.0	None	---	---	---	---
Rm. 146 - Classroom	Sink	Public Access	062	ELM-S111	<1.0	None	---	---	---	---
Rm. 146 - Classroom	Sink	Public Access	063	ELM-S112	1.1	None	---	---	---	---
Rm. 153 - Nurse's Office Bathroom	Sink	Public Access	064	ELM-S121	7.3	None	---	---	---	---
Rm. 156 - Main Office Bathroom	Sink	Secured - SCSD Staff Only	055	ELM-S120	4.2	None	---	---	---	---
Rm. 205 - Staff Bathroom	Sink	Secured - SCSD Staff Only	014	ELM-S228	2.3	None	---	---	---	---
Rm. 208 - Classroom	Sink	Public Access	012	ELM-S232	12.0	None	---	---	---	---
Rm. 212 - Work Room	Sink	Secured - SCSD Staff Only	005	ELM-S237	1.0	None	---	---	---	---
Rm. 215 - Hallway/Vestibule	Sink	Public Access	009	ELM-S233	4.0	None	---	---	---	---
Rm. 215 - Hallway/Vestibule	Sink	Public Access	010	ELM-S234	8.7	None	---	---	---	---
Rm. 215 - Hallway/Vestibule	Sink	Public Access	007	ELM-S235	3.7	None	---	---	---	---
Rm. 215 - Hallway/Vestibule	Sink	Public Access	006	ELM-S236	4.3	None	---	---	---	---
Rm. 215 - Hallway/Vestibule	Fountain	Public Access	004	ELM-F203	<1.0	None	---	---	---	---
Rm. 221 - Classroom	Sink	Public Access	024/004	ELM-S231	15.5	See Note 6	<1.0	None	---	---
Rm. 224 - Classroom	Sink	Public Access	025	ELM-S223	13.3	None	---	---	---	---
Rm. 225 - Classroom	Sink	Public Access	027/006	ELM-S220	63.0	See Note 6	1.1	None	---	---
Rm. 226 - Classroom	Sink	Public Access	029/007	ELM-S218	32.7	See Note 6	5.7	None	---	---
Rm. 227 - Classroom	Sink	Public Access	034	ELM-S219	1.8	None	---	---	---	---
Rm. 228 - Classroom	Sink	Public Access	032/008	ELM-S221	123.0	See Note 6	2.3	None	---	---
Rm. 229 - Classroom	Sink	Public Access	031	ELM-S222	4.2	None	---	---	---	---

SYRACUSE CITY SCHOOL DISTRICT ELMWOOD ELEMENTARY SCHOOL

ROOM No. & LOCATION	FIXTURE (Sink / Fountain)	ACCESSIBILITY	LAB SAMPLE ID No.	TDK SAMPLE ID No.	07/01/20 RESULTS (ppb)	07/01/20 ORIGINAL ACTIONS	08/05/20 RESULTS (ppb)	08/05/20 RE-SAMPLE ACTIONS	11/06/20 RESULTS (ppb)	11/06/20 RE-SAMPLE ACTIONS
Rm. 230 - Hallway/Vestibule	Fountain	Public Access	015	ELM-F202	<1.0	None	---	---	---	---
Rm. 230 - Hallway/Vestibule	Sink	Public Access	018	ELM-S224	2.2	None	---	---	---	---
Rm. 230 - Hallway/Vestibule	Sink	Public Access	019	ELM-S225	2.4	None	---	---	---	---
Rm. 230 - Hallway/Vestibule	Sink	Public Access	022/005	ELM-S226	19.4	See Note 6	<1.0	None	---	---
Rm. 230 - Hallway/Vestibule	Sink	Public Access	023	ELM-S227	2.0	None	---	---	---	---
Rm. 233 - Classroom	Sink	Public Access	039	ELM-S229	6.4	None	---	---	---	---
Rm. 235 - Classroom	Sink	Public Access	040	ELM-S230	14.8	None	---	---	---	---
Rm. 04 - Kitchen	Convotherm Oven	Secured - SCSD Staff Only	013/001/002	ELM-C1000	79.3	See Note 8	29.7	See Note 6	3.2	None

Original Sample Notes [July 1 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-039
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project ID No. 70137222
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture removed, replaced and resampled.
7. Fixture not operating.
8. In-line filter installed by SCSD and resampling performed.

Re-Sample Notes [August 8 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-039
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project ID No. 70141219
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Remediation performed by SCSD.

Re-Sample Notes [November 6 Event]:

1. Water samples collected by: TDK Engineering Associates, P.C. - TDK Project No. 2016068-039
2. Water samples analyzed by: Pace Analytical Services, LLC - Pace Project ID No. 70152549
3. New York State Department of Health Standard for Lead in Drinking Water is 15 parts per billion (ppb).
4. The water sampling and analysis program was conducted in substantial conformance with Title 10 (Health) of Official Compilation Codes, Rules and Regulations of the State of New York (10NYCRR) - Subpart 67-4: Lead Testing in School Drinking Water.
5. Water Samples Analyzed for Metals (Lead) in Accordance with EPA 200.8.
6. Fixture signed/placarded.